

March 15, 2005

David R. Roberts, P.E.
Senior Engineer
Architectural Energy Corporation
2540 Frontier Avenue, Suite 201
Boulder, CO 80301

Re: REM/Rate, version 11.4

Dear Mr. Roberts,

In response to your request, the Division of Code Enforcement and Administration has reviewed REM/Rate, version 11.4, the energy modeling software produced by Architectural Energy Corporation. In accordance with Section 101.3.1 of the *Energy Conservation Construction Code of New York State (State Energy Code)* we have determined that the Overall Building U_o Compliance Report demonstrates compliance with Section 502.2 of the *State Energy Code*. Effective immediately, code enforcement officials shall accept the compliance report as compliance documentation in accordance with Section 104.

Please be advised that regulated parties are still required to demonstrate compliance with the general provisions of Sections 502, 503, 504 and 505. In addition, code officials are advised to review whether areas shown for building elements reflect actual design conditions.

If you have questions regarding this matter, please call me at (518) 474-4073.

Sincerely,

Steven Rocklin, RA
Assistant Director for Energy Services
Division of Code Enforcement and Administration