

PROPOSED TEXT

Subdivision (c) of section 1220.1 of Title 19 NYCRR is amended by adding a new paragraph (12), to read as follows:

(12) 2010 RCNYS Section 703.7.3. Section 703.7.3 of the 2010 RCNYS shall be deemed to be amended by the addition of a new Table R703.7.3, to read as follows:

**TABLE R703.7.3
ALLOWABLE SPANS FOR LINTELS SUPPORTING MASONRY VENEER^{a, b, c}**

SIZE OF STEEL ANGLE^{a, c} (inches)	NO STORY ABOVE	ONE STORY ABOVE	TWO STORIES ABOVE	NO. OF 1/2" OR EQUIVALENT REINFORCING BARS^c
3×3×1/4	6'-0"	4'-6"	3'-0"	1
4×3×1/4	8'-0"	6'-0"	4'-6"	1
5×3 ¹ / ₂ × ⁵ / ₁₆	10'-0"	8'-0"	6'-0"	2
6×3 ¹ / ₂ × ⁵ / ₁₆	14'-0"	9'-6"	7'-0"	2
2-6×3 ¹ / ₂ × ⁵ / ₁₆	20'-0"	12'-0"	9'-6"	4

For SI: 1 inch = 25.4 mm, 1 foot = 304.8 mm.

- a. Long leg of the angle shall be placed in a vertical position.
- b. Depth of reinforced lintels shall not be less than 8 inches and all cells of hollow masonry lintels shall be grouted solid. Reinforcing bars shall extend not less than 8 inches into the support.
- c. Steel members indicated are adequate typical examples; other steel members meeting structural design requirements may be used.