

Clarifications of the Fire Code of New York State
Publication Date May 2002

202 In the definition of Occupancy Classification, modify the 2nd line of R-1: "... primarily transient in nature (~~less than 30 days~~) including."

Correlate with BCNYS.

1005.3.2 In exception number 7, modify 2nd line "... for the Building Code of New York State for stages are not required to be enclosed."

Text inadvertently omitted

1008.5.2.1 Re-insert paragraph entitled "Smoke Control" from IFC and BCNY.

Section inadvertently omitted.

1010.21.2.1 **Limited area sprinkler system.** A limited-area sprinkler system conforming to the requirements of Section 903.3.5.1.1 that protects all interior stairs serving as a means of ~~that~~ egress.

Typographical error.

3405.3.8 Table 3405.3.8.5 Should be Table 2405.3.8.~~2.5~~

Typographical error.