

# ICC Code Changes- committee workbook

Instructions on use of workbook (the tabs at the bottom of the

"Significant Code Changes" are those identified by staff as issues worth discussion. Committee added issues will be denoted by the prefix 'C'. Public added issues will be denoted by the prefix 'P'. Colors are based on committee discussion- green is no object/concern, red is committee object/concern, orange is the need for correlation with other State Law or Regulation.

"All code changes" is a correlated list of code changes of both the 2009 and 2012 International Fire Code. Colors are staff recommendations- Green is an editorial, update, or clarification; yellow is a significant issue, orange requires coordination with other

"2012IFC changes" is an unrefined list of all 2012 changes, without administration or correlation changes

"2009IFC changes" is an unrefined list of all 2012 changes, without administration or correlation changes

Issue Number	Brief Description	Item Numbers	2009 Code Sections	2012 IFC Code Sections	Code Change Proposals	Committee Discussion
1	Addition of emergency responder radio coverage	102, 103, 104, 105, 106, 107, 108, 109, 110, 806, 807, 808, 809, 810, 811, 812, 813, 814, 815, 816, 817, 818	510.1, 510.2.1, 510.2.2, 510.2, 510.3, 510.5, 510.6, 510.2 (New), 510.4 (New), J103.1.1, J103.1.2, J103.1.3, J103.1.4, J103.1.5, J103.1, J103.2.1, J103.2.3, J103.2.4, J103.2.5, J103.3.3, J103.3.4, J103.3.5	510.1, 510.4.1.1, 510.4.1.2, 510.4.1, 510.3, 510.5, 510.6, 510.2 (New), 510.4 (New), 510.4.2.1, 510.4.2.2, 510.4.2.3, 510.4.2.4, 510.4.2.5, 510.4.2, 510.5.1, 510.5.3, 510.5.4, 510.5.5, 510.6.1, 510.6.2, 510.6.3	F27-09/10, F29-09/10	Committee generally agreed to the need for such systems in certain buildings. Questions/concerns are: 1) Should not be a blanket requirement with the CEO judgement being the way not to requirement 2) Should be a triggering list for a need, not a performance requirement at the end of the construction process 3) Standardized testing and inspection standards or guidelines should be incorporated.
2	Addition of regulation on waste containers in student housing	202	808.2 (New)	808.2 (New)	F60-09/10	Agreed to by consent of committee- No objections or issues
3	Addition of requirements for PV (solar) panel installations	124	605.11-605.11.4 (New)	605.11-605.11.4 (New)	F30-09/10	Agreed to by consent of committee- No objections or issues
4	Additional requirements for sprinkler and standpipe systems for rubbish and linen chutes	225	903.2.11.2	903.2.11.2	F77-09/10	Agreed to by consent of committee- No objections or issues
5	Additional requirements for the code official to post signs and barrier tape regarding vacant buildings	37	311.2.1	311.2.1	F29-06/07	Committee agreed that the placarding requirements that are in the current code are overburdensome in some ways, such as the sign is too big. Committee discussed the ability for alternative notifications, such as 911 centers, paint, and pre-planning that is approve by the FD.
6	Addresses dealing with fire alarms in multiple Group A occupancies	279, 307	907.2.1, 907.2.9.3 (New)	907.2.1, 907.2.9.3 (New)	F100-09/10, F109-09/10	Agreed to by consent of committee- No objections or issues
7	Addresses design and maintenance of rooftop gardens	61	317 (All; New)	317 (All; New)	F8-09/10, F9-09/10	Agreed to by consent of committee- No objections or issues
8	Addresses lockdown plans	71, 74, 78, 81	402.1, 404.1, 404.3.3 through 404.3.3	402.1, 404.1, 404.3.3 through 404.3.3 (New),	F61-07/08	Agreed to by consent of committee- No objections or issues
9	Addresses obstructions on roofs	57	316.4 (New)	316.4 (New)	F7-09/10	Agreed to by consent of committee- No objections or issues
10	Adds allowances for portable electrostatic paint-spraying apparatus	460, 461, 462, 463	1507.2, 1507.3.1, 1507.3, 1507.5.1	2407.2, 2407.3.1, 2407.3, 2407.5.1	F145-06/07	Agreed to by consent of committee- No objections or issues
11	Adds Group F into fire safety and evacuation plan/drill requirements	75, 80	404.2, 405.2 Table	404.2, 405.2 Table	F60-07/08	Agreed to by consent of committee- No objections or issues
12	Adds Group I-1 to smoke alarm requirements. Allows for wireless alarms.	310, 775	907.2.11.3, 4603.7	907.2.11.3, 1103.8	F114-09/10, Part I; F115-09/10, Part I	Agreed to by consent of committee- No objections or issues
13	Adds hood cleaning requirements to Chapter 6 of the Fire Code	145, 146, 147, 148	609.3.3.1 (New), 609.3.3.1 Table (New), 609.3.3.2 (New), 609.3.3.3 (New)	609.3.3.1 (New), 609.3.3.1 Table (New), 609.3.3.2 (New), 609.3.3.3 (New)	F102-06/07	This would match the NYS modification currently in the 2010 FCNYS
14	Adds new chapter regarding marinas	757	Chapter 45 (New)	4500	F210-06/07	Agreed to by consent of committee- No objections or issues
15	Adds requirements for emergency egress and escape routes in a public safety plan.	72	403.2.1	403.2.1	F11-09/10	Agreed to by consent of committee- No objections or issues
16	Adds requirements for emergency responder radio coverage	111, 322	510 (New), 907.2.13.2 907.2.12.2	510 (New), 907.2.13.2 907.2.12.2	F87-07/08, F164-07/08	Same as Issue Number 1
17	Adds requirements for fire alarms and detection in Group R-4 occupancies	309, 326	907.2.10.1.3, 907.2.10 through 907.2.10.3	907.2.10.1.3, 907.2.10 through 907.2.10.3 (New)	F167-07/08, CCC	Agreed to by consent of committee- No objections or issues
18	Adds requirements for Liquid oxygen storage and use in home care	604, 752	3001.1, 4006 (New)	5301.1, 6306	F205-06/07, F290-07/08	Agreed to by consent of committee- No objections or issues
19	Adds smoke partitions to the maintenance requirements. Adds NFPA 80 for opening protective maintenance and inspection requirements.	157, 158	703.1.2, 703.1.3 (New)	703.1.2, 703.1.3 (New)	F59-06/07, F106-07/08, F107-07/08	Committee disagrees with the need for a certified inspection agency for all fire and smoke doors, especially in small buildings.
20	Aligns the terms 'tent' and 'canopy'	274, 538, 539, 540, 541, 542, 543, 544, 546, 547, 548, 549, 551, 552, 554, 555, 556, 558, 559, 560,	#####	#####	F161-06/07, F162-06/07, F243-07/08	Agreed to by consent of committee- No objections or issues
21	Aligns requirements for sprinkler systems in parking garages with repair garages, relative to commercial trucks	238, 267	903.2.9 903.2.8, 905.4	903.2.9 903.2.8, 905.4	F136-07/08, F159-07/08	Agreed to by consent of committee- No objections or issues
22	Allows for code official to require additional premises identification	92	505.1	505.1	F18-09/10	Agreed to by consent of committee- No objections or issues
23	Allows for electronic access to MSDS sheets be approvable	82	407.2	407.2	F62-07/08	Agreed to by consent of committee- No objections or issues
24	Allows for emergency vents on UL 2085 tanks containing Class II or IIIA liquids to discharge inside the building	656	3404.2.7.4	5704.2.7.4	F204-09/10	Agreed to by consent of committee- No objections or issues
25	Allows for the use of certain aerosol based hand rubs	682	3405.5.1	5705.5.1	F190-06/07,	Agreed to by consent of committee- No objections or issues
26	Allows for the use of the same fire test standards in Group I-2 and I-3 occupancies for Group I-1, relative to newly introduced upholstered furnishings, Removes the exception that allowed newly introduced furniture in sprinklered buildings to be exempt for fire testing	185	805.1.1.1	805.1.1.1	F66-06/07, F67-06/07	Agreed to by consent of committee- No objections or issues
27	Angle of approach and departure is added to fire apparatus access road specifications	86	503.2.8 (New)	503.2.8 (New)	F68-07/08	Agreed to by consent of committee- No objections or issues
28	Certification requirements for fire extinguisher service technicians	272	906.2.1 (New)	906.2.1 (New)	F96-09/10	Agreed to by consent of committee- No objections or issues
29	Changes fire pump power from standby power to emergency power	119, 120	604.2.14.1.3 604.2.15.1.3, 604.2.14.3 604.2.15.3	604.2.14.1.3 604.2.15.1.3, 604.2.14.3 604.2.15.3	F89-07/08	Committee thought that this might be overburdensome and could prohibit generator sets with electric fire pumps that have become the industry standard in NYS.
30	Changes the requirements of assembly occupancy sprinkler requirements; between the Group A and the 'highest' level of exit discharge.	213	903.2.1	903.2.1	F85-06/07, E8-07/08	Agreed to by consent of committee- No objections or issues
31	Clarification of the use of 13R sprinkler systems	245	903.3.1	903.3.1	F140-07/08	Agreed to by consent of committee- No objections or issues
32	Clarification on when a Group A is accessory to a Group E	430, 433, 434, 435, 438	1028.10, 1025.10, 1028.1 1025.1, 1028.2 1025.2, 1028.3 1025.3, 1028.9 1025.9	1028.10, 1025.10, 1028.1 1025.1, 1028.2 1025.2, 1028.3 1025.3, 1028.9 1025.9	E158-06/07, E152-06/07	Agreed to by consent of committee- No objections or issues
33	Clarifies placard sign sizes are minimum dimensions	39	311.5.2	311.5.2	F31-06/07	See issue Number 5
34	Clarifies rooftop standpipe connection requirements	266	905.4	905.4	F93-09/10, G31-09/10; CCC10-G10	Agreed to by consent of committee- No objections or issues
35	Clarifies that fuel oil storage for building systems over 660 gallons is a Group H-3	113, 114, 115, 583	603.3.1, 603.3.2 Deleted, 603.3.2 thru 603.3.2.5 (New), 2703.1.1(1) Table	603.3.1, 603.3.2 Deleted, 603.3.2 thru 603.3.2.5 (New), 5003.1.1(1) Table	F46-06/07, F169-06/07, F247-07/08 (p. 492), CCC	Agreed to by consent of committee- No objections or issues
36	Clarifies the standpipe requirements for helistops and heliports	262, 268	905.3.6, 905.5	905.3.6, 2007.5	F92-09/10	Agreed to by consent of committee- No objections or issues

37	Clarifies the triggers for placards; including vacant or abandoned buildings that have structural or interior hazards	41	311.5	311.5	F30-06/07	See issue Number 5
38	Creates the building information sign in an Appendix	805	J Appendix J (New)	J Appendix J (New)	F236-09/10	Agreed to by consent of committee- No objections or issues
39	Defines locking arrangements that are permitted in a Group I-1 occupancy	259	905.3.1	905.3.1	G81-06/07	Agreed to by consent of committee- No objections or issues
40	Elimination of tradeoffs regarding smoke and heat vents	392	910.2.3 Deleted .	910.2.3 Deleted .	F114-07/08	Agreed to by consent of committee- No objections or issues
41	Extension of upholstered furniture limitations to decks, balconies, and porches for Group R-2 student housing	192	805.4	805.4	F53-09/10	Agreed to by consent of committee- No objections or issues
42	In Group E occupancies, removes the allowance for manual pull boxes to be removed because of two-way communications to classrooms. Also requires a voice/alarm communication system.	285	907.2.3	907.2.3	F107-09/10	Committee to review. 2 way communication system are beneficial for more than just fires and manual pull boxes are a source of malicious false alarms.
43	Limits the dispensing into portable container of not more than 5 gallons	494, 526	2204.4.1, 2210.3.4	2304.4.1, 2310.3.4	F226-07/08	Agreed to by consent of committee- No objections or issues
44	Limits the installation of pressure vessels to ASME only; not DOT	589	2703.2.1	5003.2.1	F249-07/08	Committee disagrees with the intent of this change. DOT cylinders are the vast majority of cylinders used in commercial, medical, and industrial operations and the reasoning does not provide any justification for this change.
45	Modification to the general storage section	43, 46, 47, 49	315.1, 315.1(part), 315.3 (All), 315	315.1, 315.2, 315.3 (All), 315	F6-09/10	Agreed to by consent of committee- No objections or issues
46	Modifies the language regarding open burning	7, 9	307.1.1, 307.3	307.1.1, 307.3	F4-09/10, F5-09/10	Will coordinate with NYS DEC.
47	Modifies the motor-fuel distribution facility requirements for Biodiesel	495, 500, 501, 502, 503, 504, 505, 506	2205.1, 2206.2.3, 2206.2.5, 2206.2.3 Tbl, 2206.2, 2206.6.2, 2206.7.6.1, 2206.7.6	2305.1, 2306.2.3, 2306.2.5, 2306.2.3 Table, 2306.2, 2306.6.2, 2306.7.6.1, 2306.7.6	F168-09/10, F171-09/10	Agreed to by consent of committee- No objections or issues
48	Movement of all retroactive construction requirements to a new chapter	132, 161, 162, 253, 270, 575, 791	607.1, 704.1, 704.1 Table Deleted ., 903.6.1, 905.11, 2506.1, 4604 1027	607.1, 704.1, 704.1 Table Deleted ., 903.6.1, 905.11, 3406.1, 1104	F294-07/08	Agreed to by consent of committee- No objections or issues
49	Moves the maintenance of kitchen hoods to Chapter 6	149, 150, 151, 152, 153, 258	609.3.1 904.11.6.1, 609.3.2 904.11.6.2, 609.3.3 904.11.6.3, 609.3.4 (New), 609.3	609.3.1 904.11.6.1, 609.3.2 904.11.6.2, 609.3.3 904.11.6.3, 609.3.4 (New), 609.3 (New), 904.11.6	F55-06/07, F102-06/07	Matches current NYS modification
50	New requirements addressing alcohol blended fuel-dispensing systems	507	2206.7, 2206.8 through 2206.8.5 (New)	2306.7, 2306.8 through 2306.8.5 (new)	F230-07/08	Agreed to by consent of committee- No objections or issues
51	Prohibits storage of propane on roofs	720, 721	3804.3.1, 3804.3.1	6104.3.1 (New), 6104.3.2	F216-09/10	Matches current NYS modification
52	Prohibits the installation of traffic calming devices without approval	88	503.4.1 (New)	503.4.1 (New)	F17-09/10	Agreed to by consent of committee- No objections or issues
53	Provides a trigger for sprinkler protection in enclosed parking structures	232	903.2.10 903.2.9	903.2.10 903.2.9	F89-06/07	Agreed to by consent of committee- No objections or issues
54	Provides more prescriptive requirements for aerial apparatus access roads	799, 801, 802, 803	D105.1, D105.2, D105.3, D105.4 (New)	D105.1, D105.2, D105.3, D105.4 (New)	F231-09/10	Agreed to by consent of committee- No objections or issues
55	Provides requirements for combustible dumpsters	5, 6	304.3.4 (New), 304.3	304.3.4 (New), 304.3	F42-07/08, CCC	Agreed to by consent of committee- No objections or issues
56	Reconfiguration of the fire alarm system requirements, based on workgroup	275, 277, 280, 284, 286, 287, 289, 290, 292, 293, 294, 295, 298, 299, 300, 301, 302, 303, 304, 305, 306, 308, 312, 313, 314, 319, 321, 324, 328, 329, 330, 331, 332, 333, 334, 335, 336, 337, 338, 339, 340, 343, 344, 345, 351, 353, 354, 355, 356, 357.	#####	#####	F122-06/07, F161-07/08, G23-07/08, F164-07/08, F163-07/08, E8-07/08, F173-07/08, F174-07/08, F175-07/08, F294-07/08, F179-07/08	Agreed to by consent of committee- No objections or issues
57	Reconfiguration of the fire alarm system requirements, based on workgroup, updates fire alarms for R-4 occupancies	311, 316, 317, 327, 772	907.2.11.1 907.2.10.1, 907.2.12.2 907.2.11.2, 907.2.12.3 907.2.11.3, 907.2.11 907.2.10, 4603.6.1 through 4603.7.3 907.3.1 through 907.3.4.3	907.2.11.1 907.2.10.1, 907.2.12.2 907.2.11.2, 907.2.12.3 907.2.11.3, 1103.6.1 through 1103.7.3	F122-06/07, F167-07/08, F175-07/08, F176-07/08, F177-07/08, F178-07/08, F294-07/08	Agreed to by consent of committee- No objections or issues
58	Removal of sprinkler tradeoff regarding width of egress components	444, 445	1030.2 (New), 1030.2 Table (New)	1030.2 (New), 1030.2 Table (New)	F19-07/08	Agreed to by consent of committee- No objections or issues
59	Removes the 'areas used for participant sports' exemption for sprinkler	211, 212	903.2.1.3, 903.2.1.4	903.2.1.3, 903.2.1.4	F132-07/08, E10-07/08	Agreed to by consent of committee- No objections or issues
60	Removes the exception for oil tanks under 1,000 gallons to be abandoned in place without fill	667	3404.2.13.1.4	5704.2.13.1.4	F274-07/08	Agreed to by consent of committee- No objections or issues
61	Removes the exception that allowed newly introduced mattresses in sprinklered buildings to be exempt for fire testing	186, 187, 188, 189, 190, 191	805.1.2.1, 805.2.1.1, 805.3.1.1, 805.3.1.2, 805.3.2.1, 805.3.2.2	805.1.2.1, 805.2.1.1, 805.3.1.1, 805.3.1.2, 805.3.2.1, 805.3.2.2	F68-06/07, F69-06/07, F70-06/07, F71-06/07, F72-06/07, F125-07/08	Agreed to by consent of committee- No objections or issues
62	Removes the fire extinguisher exemption for QR sprinklered buildings	271	906.1	906.1	F94-09/10, F95-09/10	Matches current NYS modification
63	Requirement for a maintenance manual for smoke management systems	391	909.19	909.19	F141-09/10	Agreed to by consent of committee- No objections or issues
64	Requirement for smoke and heat vent maintenance	398	910.5 (New)	910.5 (New)	F146-09/10	Agreed to by consent of committee- No objections or issues
65	Requirement for visual designation of storage height in high-rack storage occupancies	533	2305.6 (New)	3205.6	F238-07/08	Agreed to by consent of committee- No objections or issues
66	Requirements for a key box for non-standardized elevator boxes	94, 95	506.1.2 (New), 506.1	506.1.2 (New), 506.1	F19-09/10	Agreed to by consent of committee- No objections or issues
67	Requirements for alcohol based hand rubs	683	3405.5	5705.5	F213-09/10	Agreed to by consent of committee- No objections or issues
68	Requirements for CO alarms	385, 386	908.7.1 (New), 908.7 (New)	908.7.1 (New), 908.7 (New)	F133-09/10, F133-09/10	Reference needs to be removed and match Executive Law 378
69	Requirements for code official notification on changes or termination of fire alarm monitoring	208, 365	901.9 (New), 907.6.5.2 (New)	901.9 (New), 907.6.5.2 (New)	F64-09/10	Agreed to by consent of committee- No objections or issues
70	Requirements for emergency voice/alarm communication captions in stairwells and arenas.	278, 349	907.2.1.2 (New), 907.5.2.2.4 (New)	907.2.1.2 (New), 907.5.2.2.4 (New)	F105-09/10	Agreed to by consent of committee- No objections or issues
71	Requirements for fire evacuation plans and fire safety plans for buildings with areas of assisted rescue	76, 77	404.3.1, 404.3.2	404.3.1, 404.3.2	E38-06/07	Agreed to by consent of committee- No objections or issues
72	Requirements for first responder safeguards in buildings with automatic rack storage	532, 536	2302.1, 2309.4 (New)	3202.1, 3209.4	F240-07/08	Agreed to by consent of committee- No objections or issues
73	Requirements for portable outdoor fireplaces	2	302.1	302.1	F44-07/08	Agreed to by consent of committee- No objections or issues
74	Requirements for portable outdoor fireplaces	10, 11, 12	307.4.3 (New), 307.5, 307 Title	307.4.3 (New), 307.5, 307 Title	F44-07/08	Agreed to by consent of committee- No objections or issues
75	Requirements for portable outdoor gas heaters	116, 117	603.4.2 thru 603.4.2.3.4 (New), 603.4	603.4.2 thru 603.4.2.3.4 (New), 603.4	F47-06/07, CCC	Agreed to by consent of committee- No objections or issues
76	Requirements for retroactive CO alarms	776, 777	4603.9, 4603.1 Table	1103.9 (New), 1103.1 Table	F133-09/10, F219-09/10, F221-09/10, CCC10-IFC-18	See Issue Number 68
77	Requirements for sprinklers in buildings that store, sell, display, or manufacture upholstered furniture or mattresses	216, 218, 222	903.2.4, 903.2.7, 903.2.9	903.2.4, 903.2.7, 903.2.9	F69-09/10	Agreed to by consent of committee- No objections or issues

78	Requirements for the inspection of unit-type emergency lighting	122	604.5 through 604.5.2.1 (New)	604.5 through 604.5.2.1 (New)	F35-09/10	Matches current NYS modification
79	Requirements for upgrade of elevator keys when equipped as Phase 1, Phase 2, or fire service access elevator	134	607.5 thru 607.5.4 (New)	607.5 thru 607.5.4 (New)	F20-09/10, CCC10-IFC2	Agreed to by consent of committee- No objections or issues
80	Requirements regarding ambulatory care facilities	246, 281, 283, 422	903.3.2, 907.2.2.1, 907.2.2, 914.11	903.3.2, 907.2.2.1, 907.2.2, 914.11 through	G15-09/10, G20-09/10	Agreed to by consent of committee- No objections or issues
81	Requirements regarding storage and structures underneath high-voltage transmission lines	48, 52, 53, 59	315.4 (New), 316.5.1 (New), 316.5.2 (New), 316.5 (New)	315.4 (New), 316.5.1 (New), 316.5.2 (New), 316.5 (New)	F78-07/08	Agreed to by consent of committee- No objections or issues
82	Requirements that mechanical smoke exhaust and smoke and heat vents are maintained per NFPA 204	206	901.6.1 Table	901.6.1 Table	F63-09/10	Agreed to by consent of committee- No objections or issues
82	Requirements that mechanical smoke exhaust and smoke and heat vents are maintained per NFPA 204	207	901.6	901.6	F63-09/10	Agreed to by consent of committee- No objections or issues
83	Requires a building information card in the fire command center	98	508.1.5	508.1.5	F25-09/10	Agreed to by consent of committee- No objections or issues
84	Requires venting for Class IIIB liquid tanks	653, 655, 657, 659, 666	3404.2.3.2, 3404.2.7.3.3, 3404.2.7.5.2, 3404.2.7.5.8, 3404.2.9.5 3404.2.9.4	5704.2.3.2, 5704.2.7.3.3, 5704.2.7.5.2, 5704.2.7.5.8, 5704.2.9.5	F271-07/08	Agreed to by consent of committee- No objections or issues
85	Retroactive requirements for sprinklers in Group I-2 occupancies	254	903.6.2 (New)	903.6.2 (New)	F154-07/08	Agreed to by consent of committee- No objections or issues
86	Sets annual inspection requirements for passive fire protection systems	159	703.1	703.1	F105-07/08	Agreed to by consent of committee- No objections or issues
87	Sets furnishing and mattress fire test standards for student housing	193	805.4 through 805.4.2.3 (New)	805.4 through 805.4.2.3 (New)	F75-06/07, F126-07/08	Agreed to by consent of committee- No objections or issues
88	Sets requirements for ambulatory health care facilities	214, 235, 282	903.2.2.1, 903.2.2 (New), 907.2.2.1 (New)	903.2.2.1, 903.2.2 (New), 907.2.2.1 (New)	G23-07/08	Agreed to by consent of committee- No objections or issues
89	Sets requirements for crowd managers	73	403.3 (New)	403.3 (New)	F59-07/08	Agreed to by consent of committee- No objections or issues
90	Sets requirements for the distribution of the fire safety and evacuation plan in mixed use buildings	79	404.5.1 (New)	404.5.1 (New)	F36-06/07	Agreed to by consent of committee- No objections or issues
91	Specifies that combination sprinkler/standpipes are permitted	265	905.3	905.3	F243-09/10	Agreed to by consent of committee- No objections or issues
92	Standpipe requirements for rooftop gardens	264	905.3.8 (New)	905.3.8 (New)	F8-09/10	Agreed to by consent of committee- No objections or issues
93	Update of open burning requirements	8	307.1.1	307.1.1	F43-07/08	To discuss with NYS DEC
94	Update of the hazard placards	40	311.5.4	311.5.4	F54-07/08	See Issue Number 5
95	Updates regarding assisted living and group homes	219	903.2.8.1 (New)	903.2.8.1 (New)	G20-09/10, CCC10-IFC-4	Agreed to by consent of committee- No objections or issues
95	Updates regarding assisted living and group homes	220, 242, 291, 297	903.2.8.2 (New), 903.3.1.3, 907.2.6.2,	903.2.8.2 (New), 903.3.1.3, 907.2.6.2, 907.2.6	G20-09/10, CCC10-IFC-4	Agreed to by consent of committee- No objections or issues
96	Updates requirements and sets an inspection schedule for fire escapes	782, 783	4604.16.5.1, 4604.17.5	1104.16.5.1 (New), 1106.16.5	F227-09/10	Agreed to by consent of committee- No objections or issues
97	Updates to triggers, administrative provisions, and building code requirements relative to retroactive construction requirements	764, 765, 766, 778, 779, 780, 784	4601.2, 4601.3, 4601.4, 4604.1.2, 4604.1, 4604.4.1, 4604.18.2 Table	1101.2, 1101.3, 1101.4, 1101.4.2, 1104.1, 1101.4.1, 1104.17.2 Table	F219-09/10	Agreed to by consent of committee- No objections or issues

All Code Changes- 2010 FCNYS vs. 2009 and 2012 International Fire Code

(arranged by 2010 FCNYS/2009 IFC Section Number)

Item Number	Issue Number	2009 Code Section	2012 IFC Code Section	Code Change Proposal	Brief Description
1	---	301.1	301.1	F40-07/08	Retitle of Chapter 3, Movement of hazards to firefighters to Chapter 3
2	73	302.1	302.1	F44-07/08	Requirements for portable outdoor fireplaces
3	---	304.3.2	304.3.2	F3-09/10	Allowances for wastebaskets to be utilized that are non-metallic and meet the requirements of Section 808.4
4	---	304.3.2	304.3.2	F41-07/08	Adds test requirements for approvable combustible wastebaskets
5	55	304.3.4 (New)	304.3.4 (New)	F42-07/08, CCC	Provides requirements for combustible dumpsters
6	55	304.3	304.3	F42-07/08	Provides requirements for combustible dumpsters
7	46	307.1.1	307.1.1	F4-09/10, F5-09/10	Modifies the language regarding open burning
8	93	307.1.1	307.1.1	F43-07/08	Update of open burning requirements
9	46	307.3	307.3	F5-09/10	Modifies the requirements for prescribed burns, as well as capabilities on extinguishment
10	74	307.4.3 (New)	307.4.3 (New)	F44-07/08	Requirements for portable outdoor fireplaces
11	74	307.5	307.5	F44-07/08	Requirements for portable outdoor fireplaces
12	74	307 Title .	307 Title .	F44-07/08	Requirements for portable outdoor fireplaces
13	---	308.1.1 . 308.2	308.1.1 . 308.2	F51-07/08	Realigns the open flame requirements
14	---	308.1.2 . 308.2.1	308.1.2 . 308.2.1	F51-07/08	Realigns the open flame requirements
15	---	308.1.3 . 308.4	308.1.3 . 308.4	F51-07/08	Realigns the open flame requirements
16	---	308.1.4 . 308.3.1	308.1.4 . 308.3.1	F51-07/08, F28-06/07, F48-07/08	Moves requirement regarding LP-gas cooking appliances under the general cooking appliance section, Realigns the open flame requirements
17	---	308.1.6.1 308.5.1	308.1.6.1 308.5.1	F10-06/07, F51-07/08	Adds the term 'wildfire risk area' for open burning and singal fuse use, realigns the open flame requirements
18	---	308.1.6.2 308.5.2	308.1.6.2 308.5.2	F51-07/08	Realigns the open flame requirements
19	---	308.1.7.1 308.3.4	308.1.7.1 308.3.4	F51-07/08	Realigns the open flame requirements
20	---	308.1.8.1 308.6.1	308.1.8.1 308.6.1	F51-07/08	Realigns the open flame requirements
21	---	308.1.8.2 308.6.2	308.1.8.2 308.6.2	F51-07/08	Realigns the open flame requirements
22	---	308.1.8.3 308.6.3	308.1.8.3 308.6.3	F51-07/08	Realigns the open flame requirements
23	---	308.1.8.4 308.6.4	308.1.8.4 308.6.4	F51-07/08	Realigns the open flame requirements
24	---	308.1.8.5 308.6.5	308.1.8.5 308.6.5	F51-07/08	Realigns the open flame requirements
25	---	308.1.4 Exception 3 . 308.3.1.1	308.1.4 Exception 3 . 308.3.1.1	F28-06/07, F48-07/08	Movement of requirements concerning cooking devices
26	---	308.1.5 308.3.3	308.1.5 308.3.3	F51-07/08	Realigns the open flame requirements
27	---	308.1.6 308.5	308.1.6 308.5	F10-06/07, F51-07/08	Adds the term 'wildfire risk area' for open burning and signal fuse, realigns the open flame requirements
28	---	308.1.7 308.3.5	308.1.7 308.3.5	F51-07/08	Realigns the open flame requirements
29	---	308.1.8 308.6	308.1.8 308.6	F51-07/08	Realigns the open flame requirements
30	---	308.1	308.1	F51-07/08	Realigns the open flame requirements
31	---	308.3.1 308.3.2	308.3.1 308.3.2	F51-07/08	Realigns the open flame requirements
32	---	308.3.2 308.3.6	308.3.2 308.3.6	F51-07/08	Realigns the open flame requirements
33	---	308.4.1 308.3.8	308.4.1 308.3.8	F51-07/08	Realigns the open flame requirements
34	---	308.2 (New)	308.2 (New)	F51-07/08	Realigns the open flame requirements
35	---	308.3 308.3.7	308.3 308.3.7	F51-07/08	Realigns the open flame requirements
36	---	308.4 (New)	308.4 (New)	F51-07/08	Realigns the open flame requirements
37	5	311.2.1	311.2.1	F29-06/07	Additional requirements for the code official to post signs and barrier tape regarding vacant buildings
38	---	311.2.2	311.2.2	F53-07/08	Adds requirements for lithium metal polymer batteries
39	33	311.5.2	311.5.2	F31-06/07	Clarifies placard sign sizes are minimum dimensions
40	94	311.5.4	311.5.4	F54-07/08	Update of the hazard placards
41	37	311.5	311.5	F30-06/07	Clarifies the triggers for placards; including vacant or abandoned buildings that have structural or interior hazards
42	---	313.1	313.1	F55-07/08	Adds portable generators to the list of 'fueled equipment'
43	45	315.1	315.1	F6-09/10	Modification to the general storage section
44	---	315.3.1	315.3.1	F56-07/08	Sets additional sprinkler requirements for storage, display, and handling of combustible materials under eaves and associated construction
45	---	315.3.2	315.3.2	E5-09/10	Clarifies interior stairway and ramp references
46	45	315.1 (part)	315.2	F6-09/10	Modification to the general storage section
47	45	315.3 (All)	315.3 (All)	F6-09/10	Modification to the general storage section
48	81	315.4 (New)	315.4 (New)	F78-07/08	Requirements regarding storage and structures underneath high-voltage transmission lines
49	45	315	315	F6-09/10	Modification to the general storage section

50	---	316.2.1 507.2.1	316.2.1 507.2.1	F40-07/08	Retitle of Chapter 3, Movement of hazards to firefighters to Chapter 3
51	---	316.2.2 507.2.2	316.2.2 507.2.2	F40-07/08	Retitle of Chapter 3, Movement of hazards to firefighters to Chapter 3
52	81	316.5.1 (New)	316.5.1 (New)	F78-07/08	Requirements regarding storage and structures underneath high-voltage transmission lines
53	81	316.5.2 (New)	316.5.2 (New)	F78-07/08	Requirements regarding storage and structures underneath high-voltage transmission lines
54	---	316.1 507.1	316.1 507.1	F40-07/08	Retitle of Chapter 3, Movement of hazards to firefighters to Chapter 3
55	---	316.2 507.2	316.2 507.2	F40-07/08	Retitle of Chapter 3, Movement of hazards to firefighters to Chapter 3
56	---	316.3 507.3	316.3 507.3	F40-07/08	Retitle of Chapter 3, Movement of hazards to firefighters to Chapter 3
57	9	316.4 (New)	316.4 (New)	F7-09/10	Addresses obstructions on roofs
58	---	316.4 401.5	316.4 401.5	F40-07/08	Retitle of Chapter 3, Movement of hazards to firefighters to Chapter 3
59	81	316.5 (New)	316.5 (New)	F78-07/08	Requirements regarding storage and structures underneath high-voltage transmission lines
60	---	316 (New) 507	316 (New) 507	F40-07/08	Retitle of Chapter 3, Movement of hazards to firefighters to Chapter 3
61	7	317 (All; New)	317 (All; New)	F8-09/10, F9-09/10	Addresses design and maintenance of rooftop gardens
62	---	317 (New)	317 (New)	F58-07/08	Adds test standards for laundry carts
63	---	401.3.2	401.3.2	F34-06/07	Clarifies the actions of occupants and employees during a fire event
64	---	401.3.3 . 401.3.2	401.3.3 . 401.3.2	F34-06/07	Clarifies the actions of occupants and employees during a fire event
65	---	401.3.1 401.3	401.3.1 401.3	F34-06/07 (p. 14)	Clarifies the actions of occupants and employees during a fire event
66	---	401.3.4 (New)	401.3.4 (New)	F35-06/07	Prohibits the use of a false alarm to be counted as a fire drill
67	---	401.3	401.3	F34-06/07 (p. 14)	Clarifies the actions of occupants and employees during a fire event
68	---	401.5 . 401.3.1	401.5 . 401.3.1	F34-06/07	Clarifies the actions of occupants and employees during a fire event
69	---	401.6 . 401.3.3	401.6 . 401.3.3	F34-06/07	Clarifies the actions of occupants and employees during a fire event
70	---	401.4 (New)	401.4 (New)	F34-06/07	Clarifies the actions of occupants and employees during a fire event
71	8	402.1	402.1	F61-07/08	Addresses lockdown plans
72	15	403.2.1	403.2.1	F11-09/10	Adds requirements for emergency egress and escape routes in a public safety plan.
73	89	403.3 (New) .	403.3 (New) .	F59-07/08	Sets requirements for crowd managers
74	8	404.1	404.1	F61-07/08	Addresses lockdown plans
75	11	404.2	404.2	F60-07/08	Adds Group F into fire safety and evacuation plan/drill requirements
76	71	404.3.1	404.3.1	E38-06/07	Requirements for fire evacuation plans and fire safety plans for buildings with areas of assisted rescue
77	71	404.3.2	404.3.2	E38-06/07	Requirements for fire evacuation plans and fire safety plans for buildings with areas of assisted rescue
78	8	404.3.3 through 404.3.3 (New)	404.3.3 through 404.3.3 (New)	F61-07/08	Addresses lockdown plans
79	90	404.5.1 (New)	404.5.1 (New)	F36-06/07	Sets requirements for the distribution of the fire safety and evacuation plan in mixed use buildings
80	11	405.2 Table	405.2 Table	F60-07/08	Adds Group F into fire safety and evacuation plan/drill requirements
81	8	406.3.3 (New)	406.3.3 (New)	F61-07/08	Addresses lockdown plans
82	23	407.2	407.2	F62-07/08	Allows for electronic access to MSDS sheets be approvable
83	---	408.11.1	408.11.1	F38-06/07	Adds the requirement for the elevator machine room to be identified on the covered mall building lease plan submission
84	---	501.3	501.3	F65-07/08	Adds security gates as part of the fire apparatus access submission requirements
85	---	503.2.1	503.2.1	F67-07/08	Specifies that shoulders of roads are not permitted to be part of the fire apparatus access road requirements
86	27	503.2.8 (New)	503.2.8 (New)	F68-07/08	Angle of approach and departure is added to fire apparatus access road specifications
87	---	503.3	503.3	F69-07/08	Adds more prescriptive requirements for signs along fire lanes
88	52	503.4.1 (New)	503.4.1 (New)	F17-09/10	Prohibits the installation of traffic calming devices without approval
89	---	503.5	503.5	F70-07/08	Adds a referenced standard for electric gate openers and design criteria for automatic gate operation.
90	---	503.6	503.6	F70-07/08	Adds a referenced standard for electric gate openers and design criteria for automatic gate operation.
91	---	504.3	504.3	F73-07/08	Editorial
92	22	505.1	505.1	F18-09/10	Allows for code official to require additional premises identification
93	---	505.1	505.1	F40-06/07	Modification to the address numbering requirements
94	66	506.1.2 (New)	506.1.2 (New)	F19-09/10	Requirements for a key box for non-standardized elevator boxes
95	66	506.1	506.1	F19-09/10	Requirements for a key box for non-standardized elevator boxes
96	---	507.5.1.1 (New)	507.5.1.1 (New)	F21-09/10	Requires a hydrant within 100 feet of a standpipe FDC, per NFPA 14
97	---	507.5.4 . 508.5.4	507.5.4 . 508.5.4	F133-06/07	Requirements regarding access and protection of fire department connections
98	83	508.1.5	508.1.5	F25-09/10	Requires a building information card in the fire command center
99	---	508 . 509	508 . 509	F43-06/07, F84-07/08, F85-07/08, CCC	Adds additional requirements for elevator controls and functional indicators in the fire command center
100	---	509.1.1 (New)	509.1.1 (New)	F26-09/10	Requires utility controls be identified similar to fire protection equipment locations
101	---	509.2 (New)	509.2 (New)	F44-06/07 (p. 20)	Requirements for keeping clear fire protection system controls
102	1	510.1	510.1	F27-09/10, F29-09/10	Addition of emergency responder radio coverage
103	1	510.2.1	510.4.1.1	F27-09/10	Addition of emergency responder radio coverage

104	1	510.2.2	510.4.1.2	F27-09/10	Addition of emergency responder radio coverage
105	1	510.2	510.4.1	F27-09/10	Addition of emergency responder radio coverage
106	1	510.3	510.3	F27-09/10	Addition of emergency responder radio coverage
107	1	510.5	510.5	F27-09/10	Addition of emergency responder radio coverage
108	1	510.6	510.6	F27-09/10	Addition of emergency responder radio coverage
109	1	510.2 (New)	510.2 (New)	F27-09/10	Addition of emergency responder radio coverage
110	1	510.4 (New)	510.4 (New)	F27-09/10	Addition of emergency responder radio coverage
111	16	510 (New)	510 (New)	F87-07/08 (p. 373)	Adds requirements for emergency responder radio coverage
112	---	601.1	601.1	F44-09/10	Creates requirements for cooking oil storage tank systems
113	35	603.3.1	603.3.1	F46-06/07	Clarifies that fuel oil storage for building systems over 660 gallons is a Group H-3
114	35	603.3.2 Deleted .	603.3.2 Deleted .	F46-06/07	Clarifies that fuel oil storage for building systems over 660 gallons is a Group H-3
115	35	603.3.2 thru 603.3.2.5 (New)	603.3.2 thru 603.3.2.5 (New)	F46-06/07	Clarifies that fuel oil storage for building systems over 660 gallons is a Group H-3
116	75	603.4.2 thru 603.4.2.3.4 (New)	603.4.2 thru 603.4.2.3.4 (New)	F47-06/07, CCC	Requirements for portable outdoor gas heaters
117	75	603.4	603.4	F47-06/07	Requirements for portable outdoor gas heaters
118	---	604.2.13	604.2.13	G31-09/10, CCC10-G10	Addresses open-type mall buildings
119	29	604.2.14.1.3 604.2.15.1.3	604.2.14.1.3 604.2.15.1.3	F89-07/08	Changes fire pump power from standby power to emergency power
120	29	604.2.14.3 604.2.15.3	604.2.14.3 604.2.15.3	F89-07/08	Changes fire pump power from standby power to emergency power
121	---	604.2.13 Deleted .	604.2.13 Deleted .	F206-06/07	Removes language in IFC regarding Silane Gas, references CGA referenced standard
122	78	604.5 through 604.5.2.1 (New)	604.5 through 604.5.2.1 (New)	F35-09/10	Requirements for the inspection of unit-type emergency lighting
123	---	605.1	605.1	F91-07/08	Updates to the electric space heater requirements
124	3	605.11-605.11.4 (New)	605.11-605.11.4 (New)	F30-09/10	Addition of requirements for PV (solar) panel installations
125	---	606.8	606.8	F51-06/07	Sets requirements for the location of the signal sent by a refrigeration leak detector
126	---	606.9.1	606.9.1	F39-09/10	Update to the requirements of refrigeration controls and emergency shutoffs
127	---	606.9.1	606.9.1	F52-06/07	Additional requirements for refrigeration system emergency shutoffs
128	---	606.9	606.9	F39-09/10	Update to the requirements of refrigeration controls and emergency shutoffs
129	---	606.10.1.1	606.10.1.1	F93-07/08	Updates requirements to relief valve settings for refrigeration systems
130	---	606.10.2.2	606.10.2.2	F93-07/08	Updates requirements to relief valve settings for refrigeration systems
131	---	606.13	606.13	F94-07/08	Exempts ammonia from the discharge location requirements in refrigeration machinery rooms
132	48	607.1	607.1	F294-07/08	Movement of all retroactive construction requirements to a new chapter
133	---	607.3 (New)	607.3 (New)	F95-07/08	Clearance of combustibles from fire service access elevator lobbies
134	79	607.5 thru 607.5.4 (New)	607.5 thru 607.5.4 (New)	F20-09/10, CCC10-IFC2	Requirements for upgrade of elevator keys when equipped as Phase 1, Phase 2, or fire service access elevator
135	---	608.1	608.1	F53-06/07	Adds requirements for lithium metal polymer batteries
136	---	608.3	608.3	F53-06/07	Adds requirements for lithium metal polymer batteries
137	---	608.5.1	608.5.1	F98-07/08	Updates the parameters of battery neutralization
138	---	608.5.2	608.5.2	F41-09/10	Increases the recombinant battery requirements to include non-sealed units
139	---	608.5.2	608.5.2	F53-06/07, F98-07/08	Adds requirements for lithium metal polymer batteries
140	---	608.5	608.5	F53-06/07	Adds requirements for lithium metal polymer batteries
141	---	608.6.1	608.6.1	F42-09/10	Coordinates battery room ventilation requirements with the IMC
142	---	608.6.1	608.6.1	F53-06/07	Adds requirements for lithium metal polymer batteries
143	---	608.6.3 (New)	608.6.3 (New)	F54-06/07, F100-07/08	Requires supervision of ventilation systems where battery charging occurs
144	---	608.1 Table	608.1 Table	F53-06/07	Adds requirements for lithium metal polymer batteries
145	13	609.3.3.1 (New)	609.3.3.1 (New)	F102-06/07	Adds hood cleaning requirements to Chapter 6 of the Fire Code
146	13	609.3.3.1 Table (New)	609.3.3.1 Table (New)	F102-06/07	Adds hood cleaning requirements to Chapter 6 of the Fire Code
147	13	609.3.3.2 (New)	609.3.3.2 (New)	F102-06/07	Adds hood cleaning requirements to Chapter 6 of the Fire Code
148	13	609.3.3.3 (New)	609.3.3.3 (New)	F102-06/07	Adds hood cleaning requirements to Chapter 6 of the Fire Code
149	49	609.3.1 904.11.6.1	609.3.1 904.11.6.1	F55-06/07	Moves the maintenance of kitchen hoods to Chapter 6
150	49	609.3.2 904.11.6.2	609.3.2 904.11.6.2	F55-06/07	Moves the maintenance of kitchen hoods to Chapter 6

151	49	609.3.3 904.11.6.3	609.3.3 904.11.6.3	F55-06/07, F102-06/07	Moves the maintenance of kitchen hoods to Chapter 6, Adds hood cleaning requirements to Chapter 6 of the Fire Code
152	49	609.3.4 (New)	609.3.4 (New)	F55-06/07	Moves the maintenance of kitchen hoods to Chapter 6
153	49	609.3 (New)	609.3 (New)	F55-06/07	Moves the maintenance of kitchen hoods to Chapter 6
154	---	610 (New)	610 (New)	F44-09/10	Creates requirements for cooking oil storage tank systems
155	---	701.1	701.1	F103-07/08, F294-07/08	Specifies how to deal with new floor openings in existing buildings,
156	---	701.2 (New)	701.2 (New)	F104-07/08	Recognizes unsafe conditions can exist due to unmaintained fire resistance construction
157	19	703.1.2	703.1.2	F59-06/07, F106-07/08	Adds smoke partitions to the maintenance requirements. Adds NFPA 80 for opening protective maintenance and inspection requirements.
158	19	703.1.3 (New)	703.1.3 (New)	F59-06/07, F107-07/08	Adds smoke partitions to the maintenance requirements. Adds NFPA 80 for opening protective maintenance and inspection requirements.
159	86	703.1	703.1	F105-07/08	Sets annual inspection requirements for passive fire protection systems
160	---	703.2	703.2	F46-09/10	Sets requirements regarding the application of labels to show compliance with opening protective inspections
161	48	704.1	704.1	F294-07/08	Movement of all retroactive construction requirements to a new chapter
162	48	704.1 Table Deleted .	704.1 Table Deleted .	F294-07/08	Movement of all retroactive construction requirements to a new chapter
163	---	801.1	801.1	F114-07/08	Clarifies new vs. existing requirements pertaining to interior finishes
164	---	802.1	802.1	F65-06/07, F119-07/08	Sets requirements for floor-wall base materials
165	---	803.1.2	803.1.2	F61-06/07	Editorial change regarding textile wall and ceiling finishes
166	---	803.5.1	803.5.1	F48-09/10, CCC-F6-09	Addresses textile ceiling coverings
167	---	803.5.1	803.5.1	FS11-06/07	Addition of UL standards
168	---	803.5.2 (New)	803.5.2 (New)	F49-09/10	Addresses textile ceiling coverings
169	---	803.6.2	803.6.2	F118-07/08	Specifies the referenced standard regarding the preparation of interior finish test samples
170	---	803.6.1 Deleted	803.6.1 Deleted	F50-09/10	Addresses vinyl wall or ceiling coverings
171	---	803.6.2 Deleted	803.6.2 Deleted	F50-09/10	Addresses vinyl wall or ceiling coverings
172	---	803.6	803.6	F50-09/10	Addresses vinyl wall or ceiling coverings
173	---	803.7.3	803.7.3	F62-06/07	Editorial change regarding foam plastic trim
174	---	803.8	803.8	FS136-09/10, Part II	Addresses polypropylene use as an interior finish
175	---	803.3 Table	803.3 Table	E5-09/10	Clarifies interior stairway and ramp references
176	---	803.8 (New)	803.8 (New)	FS165-07/08	Recognizes HDPE as an interior finish
177	---	803.9 (New)	803.9 (New)	F119-07/08	Defines and sets requirements for site-fabricated 'stretch systems', a type of interior panel
178	---	804.1.1 (New)	804.1.1 (New)	F64-06/07	Allowance for a room fire test to satisfy the interior finish requirements of interior trim
179	---	804.1	804.1	F63-06/07, F120-07/08, CCC	Clarification on the measurement of 10% as it applies to walls and ceilings
180	---	804.2.3	804.2.3	F63-06/07, F121-07/08	Clarification on the measurement of 10% as it applies to walls and ceilings
181	---	804.2.4	804.2.4	F64-06/07, FS11-06/07, CCC	Allowance for a room fire test to satisfy the interior finish requirements of interior trim
182	---	804.3.3.2 (New)	804.3.3.2 (New)	F51-09/10, E5-09/10	Rewrite of the section regarding interior floor finishes
183	---	804.3 (New)	804.3 (New)	F65-06/07	Sets requirements for floor-wall base materials
184	---	804.3 through 804.3.3.1 (New)	804.3 through 804.3.3.1 (New)	F51-09/10	Rewrite of the section regarding interior floor finishes
185	26	805.1.1.1	805.1.1.1	F66-06/07, F67-06/07	Allows for the use of the same fire test standards in Group I-2 and I-3 occupancies for Group I-1, relative to newly introduced upholstered furnishings, Removes the exception that allowed newly introduced furniture in sprinklered buildings to be exempt for fire testing
186	61	805.1.2.1	805.1.2.1	F68-06/07	Removes the exception that allowed newly introduced mattresses in sprinklered buildings to be exempt for fire testing
187	61	805.2.1.1	805.2.1.1	F69-06/07	Removes the exception that allowed newly introduced furniture in sprinklered buildings to be exempt for fire testing (Group I-2)
188	61	805.3.1.1	805.3.1.1	F70-06/07	Removes the exception that allowed newly introduced furniture in sprinklered buildings to be exempt for fire testing
189	61	805.3.1.2	805.3.1.2	F71-06/07, F125-07/08	Removes the exception that allowed newly introduced furniture and mattresses in sprinklered buildings to be exempt for fire testing
190	61	805.3.2.1	805.3.2.1	F72-06/07	Removes the exception that allowed newly introduced mattresses in sprinklered buildings to be exempt for fire testing
191	61	805.3.2.2	805.3.2.2	F71-06/07	Removes the exception that allowed newly introduced furniture and mattresses in sprinklered buildings to be exempt for fire testing
192	41	805.4	805.4	F53-09/10	Extension of upholstered furniture limitations to decks, balconies, and porches for Group R-2 student housing
193	87	805.4 through 805.4.2.3 (New)	805.4 through 805.4.2.3 (New)	F75-06/07, F126-07/08	Sets furnishing and mattress fire test standards for student housing
194	---	806.2	806.2	F56-09/10	Alternative test requirements for artificial decorative vegetation

195	---	807.1.2	807.1.2	F128-07/08	Clarifies that 10% application of combustible decorative materials is calculated on a per surface basis
196	---	807.1	807.1	F127-07/08	Provides allowances for decorative materials in student housing
197	---	807.4.2.1	807.4.2.1	F58-09/10, Part I	Addition of NFPA 289 as an alternative for fire testing of foam plastic interior products
198	---	807.4.2.1	807.4.2.1	F78-06/07	Editorial, removing extra wording regarding cellular and foam plastic trim
199	---	808.1	808.1	F59-09/10	Addition of Group I-1 to the wastebasket and linen container fire safety requirements
200	---	808.1	808.1	F129-07/08	Expands the requirements for waste and linen containers to Group I-2 occupancies. Requires containers over 32 gallons to be stored in waste or linen collection rooms.
201	---	808.3	808.3	F58-09/10, Part I, F60-09/10	Addition of NFPA 289 as an alternative for fire testing of foam plastic interior products
202	2	808.2 (New)	808.2 (New)	F60-09/10	Addition of regulation on of waste containers in student housing
203	---	808.4 (New)	808.4 (New)	F61-09/10	Address combustible lockers
204	---	901.4.3	901.4.3	FS29-09/10, Part II	Defines how fire area separation should be regulated
205	---	901.4.6 (New)	901.4.6 (New)	F62-09/10	Requirements for fire pump rooms
206	82	901.6.1 Table	901.6.1 Table	F63-09/10	Requirements that mechanical smoke exhaust and smoke and heat vents are maintained per NFPA 204
207	82	901.6	901.6	F63-09/10	Requirements that mechanical smoke exhaust and smoke and heat vents are maintained per NFPA 204
208	69	901.9 (New)	901.9 (New)	F64-09/10	Requirements for code official notification on changes or termination of fire alarm monitoring
209	---	903.2.1.1	903.2.1.1	E10-07/08	Editorial
210	---	903.2.1.2	903.2.1.2	E10-07/08	Editorial
211	59	903.2.1.3	903.2.1.3	F132-07/08, E10-07/08	Removes the 'areas used for participant sports' exemption for sprinkler systems
212	59	903.2.1.4	903.2.1.4	F132-07/08, E10-07/08	Removes the 'areas used for participant sports' exemption for sprinkler systems
213	30	903.2.1	903.2.1	F85-06/07, E8-07/08	Changes the requirements of assembly occupancy sprinkler requirements; between the Group A and the 'highest' level of exit discharge.
214	88	903.2.2.1	903.2.2.1	G23-07/08	Sets requirements for ambulatory health care facilities
215	---	903.2.2	903.2.2	F68-09/10, G15-09/10	Requirements for sprinkler protection coverage area for ambulatory healthcare facilities
216	77	903.2.4	903.2.4	F69-09/10	Requirements for sprinklers in buildings that store, sell, display, or manufacture upholstered furniture or mattresses
217	---	903.2.6	903.2.6	F70-09/10, G16-09/10, G20-09/10	Sets limitations on the use of NFPA 13D in Group I-1 occupancies
218	77	903.2.7	903.2.7	F69-09/10	Requirements for sprinklers in buildings that store, sell, display, or manufacture upholstered furniture or mattresses
219	95	903.2.8.1 (New)	903.2.8.1 (New)	G20-09/10, CCC10-IFC-4	Updates regarding assisted living and group homes
220	95	903.2.8.2 (New)	903.2.8.2 (New)	G20-09/10, CCC10-IFC-4	Updates regarding assisted living and group homes
221	---	903.2.9.1 903.2.8.1	903.2.9.1 903.2.8.1	G8-06/07, F136-07/08, G13-07/08	Requirements for shop drawings of passive fire protection requirements
222	77	903.2.9	903.2.9	F69-09/10	Requirements for sprinklers in buildings that store, sell, display, or manufacture upholstered furniture or mattresses
223	---	903.2.11.1.3	903.2.11.1.3	F76-09/10	Sets additional parameters for basement sprinkler requirements; pertaining to partition installation
224	---	903.2.11.1	903.2.11.1	F75-09/10	Sets a sill height for openings allowed to be used in determining windowless stories
225	4	903.2.11.2	903.2.11.2	F77-09/10	Additional requirements for sprinkler and standpipe systems for rubbish and linen chutes
226	---	903.2.11.1 903.2.10.1	903.2.11.1 903.2.10.1	F90-06/07, G8-06/07	Sets spacing requirements between openings used to meet the windowless opening requirements
227	---	903.2.11.4 903.2.12.1	903.2.11.4 903.2.12.1	F138-07/08	Editorial rewrite of section regarding special sprinkler requirements
228	---	903.2.11.5 903.2.12.2	903.2.11.5 903.2.12.2	F138-07/08	Editorial rewrite of section regarding special sprinkler requirements
229	---	903.2.11.6 903.2.13	903.2.11.6 903.2.13	F138-07/08	Editorial rewrite of section regarding special sprinkler requirements
230	---	903.2.11.6 Table 903.2.13 Table	903.2.11.6 Table 903.2.13 Table	F206-06/07, G131-06/07	Removes language in IFC regarding Silane Gas, references CGA referenced standard
231	---	903.2.11	903.2.11	F74-09/10	Removes Group R-3 from the exemption list for sprinklers in specific hazard areas
232	53	903.2.10 903.2.9	903.2.10 903.2.9	F89-06/07	Provides a trigger for sprinkler protection in enclosed parking structures
233	---	903.2.11 903.2.10	903.2.11 903.2.10	F138-07/08, CCC	Editorial rewrite of section regarding special sprinkler requirements
234	---	903.2.13 Deleted .	903.2.13 Deleted .	F206-06/07, CCC	Removes language in IFC regarding Silane Gas, references CGA referenced standard
235	88	903.2.2 (New)	903.2.2 (New)	G23-07/08	Sets requirements for ambulatory health care facilities
236	---	903.2.3 903.2.2	903.2.3 903.2.2	F85-06/07, F133-07/08, E10-07/08	Changes the requirements of assembly occupancy sprinkler requirements; between the Group A and the 'highest' level of exit discharge.
237	---	903.2.7 903.2.6	903.2.7 903.2.6	F135-07/08	Requirements regarding sprinklers for furniture stores
238	21	903.2.9 903.2.8	903.2.9 903.2.8	F136-07/08	Aligns requirements for sprinkler systems in parking garages with repair garages, relative to commercial trucks
239	---	903.2	903.2	FS37-06/07, CCC	Editorial changes regarding fire barriers
240	---	903.3.1.1.1	903.3.1.1.1	F80-09/10	Addresses sprinkler design criteria regarding occupant evacuation elevators

241	---	903.3.1.2.1	903.3.1.2.1	F96-06/07	Sets requirements for sprinklers to be installed on decks of Type 5 Group R construction only if there is a deck or roof above
242	95	903.3.1.3	903.3.1.3	G20-09/10, CCC-F11-09	Updates regarding assisted living and group homes
243	---	903.3.1.3	903.3.1.3	F144-07/08	Adds townhouses to the allowance use of 13D under the IBC
244	---	903.3.1	903.3.1	F78-09/10	Addresses the sprinkler design requirements in Chapters 23 and 34
245	31	903.3.1	903.3.1	F140-07/08	Clarification of the use of 13R sprinkler systems
246	80	903.3.2	903.3.2	G15-09/10, G20-09/10	Requirements regarding ambulatory care facilities
247	---	903.3.5.2	903.3.5.2	F83-09/10	Clarifies that a required secondary water supply for sprinkler systems needs to be automatic
248	---	903.3.5.2	903.3.5.2	G14-07/08	Attaches requirements for the IBC regarding high rises
249	---	903.4.1	903.4.1	F99-06/07, F147-07/08	Clean up of terms regarding monitoring and supervision of sprinkler systems
250	---	903.4.2	903.4.2	F85-09/10	Updates the language regarding exterior audible alarms for sprinkler activation
251	---	903.4.3	903.4.3	G14-07/08	Attaches requirements for the IBC regarding high rises
252	---	903.4	903.4	F99-06/07	Clean up of terms regarding monitoring and supervision of sprinkler systems
253	48	903.6.1	903.6.1	F294-07/08	Movement of all retroactive construction requirements to a new chapter
254	85	903.6.2 (New)	903.6.2 (New)	F154-07/08	Retroactive requirements for sprinklers in Group I-2 occupancies
255	---	904.1.1 (New)	904.1.1 (New)	F87-09/10	Requirements for the certification of fire extinguishing systems inspectors
256	---	904.3.2	904.3.2	F88-09/10	Regarding the installation of multiple AFSS systems and simultaneous hazards
257	---	904.11.6.1 (New)	904.11.6.1 (New)	F156-07/08	Addresses vehicle fueling ground pads for hydrogen refueling
258	49	904.11.6	904.11.6	F55-06/07	Moves the maintenance of kitchen hoods to Chapter 6
259	39	905.3.1	905.3.1	G81-06/07	Defines locking arrangements that are permitted in a Group I-1 occupancy
260	---	905.3.3	905.3.3	G31-09/10	Addresses open-type mall buildings
261	---	905.3.3	905.3.3	F104-06/07, F157-07/08	Updates the hydraulic requirements for standpipe connections in covered mall buildings
262	36	905.3.6	905.3.6	F92-09/10	Clarifies the standpipe requirements for helistops and heliports
263	---	905.3.7	905.3.7	F158-07/08	Removal of a contradiction in the standpipe section regarding marinas
264	92	905.3.8 (New)	905.3.8 (New)	F8-09/10	Standpipe requirements for rooftop gardens
265	91	905.3	905.3	F243-09/10	Specifies that combination sprinkler/standpipes are permitted
266	34	905.4	905.4	F93-09/10, G31-09/10; CCC10-G10	Clarifies rooftop standpipe connection requirements
267	21	905.4	905.4	F159-07/08	Allowance for not installing a standpipe connection within exit passageways when a connection already exists in a closeby stairway
268	36	905.5	2007.5	F92-09/10	Clarifies the standpipe requirements for helistops and heliports
269	---	905.6.2	905.6.2	F105-06/07	Updates requirements regarding interconnection of standpipe risers
270	48	905.11	905.11	F294-07/08	Movement of all retroactive construction requirements to a new chapter
271	62	906.1	906.1	F94-09/10, F95-09/10	Removes the fire extinguisher exemption for QR sprinklered buildings
272	28	906.2.1 (New)	906.2.1 (New)	F96-09/10	Certification requirements for fire extinguisher service technicians
273	---	906.2	906.2	F160-07/08, CCC	Allows for alternative locations for fire extinguishers in Group I-3 occupancies
274	20	906.1 Table	906.1 Table	F243-07/08	Aligns the terms 'tent' and 'canopy'
275	56	907.1.1	907.1.1	F122-06/07, F161-07/08	Reconfiguration of the fire alarm system requirements, based on workgroup
276	---	907.1.2 (New)	907.1.2 (New)	F161-07/08	More prescriptive requirements for fire alarm shop drawings
277	56	907.2.1.1	907.2.1.1	F122-06/07	Reconfiguration of the fire alarm system requirements, based on workgroup
278	70	907.2.1.2 (New)	907.2.1.2 (New)	F105-09/10	Requirements for emergency voice/alarm communication captions in stadiums and arenas.
279	6	907.2.1	907.2.1	F100-09/10	Addresses dealing with fire alarms in multiple Group A occupancies
280	56	907.2.1	907.2.1	F122-06/07	Reconfiguration of the fire alarm system requirements, based on workgroup
281	80	907.2.2.1	907.2.2.1	G15-09/10	Requirements regarding ambulatory care facilities
282	88	907.2.2.1 (New)	907.2.2.1 (New)	G23-07/08	Sets requirements for ambulatory health care facilities
283	80	907.2.2	907.2.2	G15-09/10	Requirements regarding ambulatory care facilities
284	56	907.2.2	907.2.2	F122-06/07, G23-07/08	Reconfiguration of the fire alarm system requirements, based on workgroup
285	42	907.2.3	907.2.3	F107-09/10	In Group E occupancies, removes the allowance for manual pull boxes to be removed because of two-way communications to classrooms. Also requires a voice/alarm communication system.
286	56	907.2.3	907.2.3	F122-06/07, CCC	Reconfiguration of the fire alarm system requirements, based on workgroup
287	56	907.2.4	907.2.4	F122-06/07	Reconfiguration of the fire alarm system requirements, based on workgroup
288	---	907.2.5	907.2.5	F164-07/08	Updates to notification and communication systems for fire alarms
289	56	907.2.6.1.1 (New)	907.2.6.1.1 (New)	F122-06/07	Reconfiguration of the fire alarm system requirements, based on workgroup
290	56	907.2.6.1	907.2.6.1	F122-06/07	Reconfiguration of the fire alarm system requirements, based on workgroup
291	95	907.2.6.2	907.2.6.2	G20-09/10	Updates regarding assisted living and group homes
292	56	907.2.6.2	907.2.6.2	F122-06/07	Reconfiguration of the fire alarm system requirements, based on workgroup
293	56	907.2.6.3.1	907.2.6.3.1	F122-06/07	Reconfiguration of the fire alarm system requirements, based on workgroup

294	56	907.2.6.3.2	907.2.6.3.2	F122-06/07	Reconfiguration of the fire alarm system requirements, based on workgroup
295	56	907.2.6.3.3	907.2.6.3.3	F122-06/07, F164-07/08	Reconfiguration of the fire alarm system requirements, based on workgroup, clarifies notification and communication systems
296	---	907.2.6.3	907.2.6.3	F163-07/08	Clarifies where fire alarm systems and smoke detection systems are specifically required
297	95	907.2.6	907.2.6	G20-09/10, CCC-F14-09	Updates regarding assisted living and group homes
298	56	907.2.6	907.2.6	F122-06/07, F164-07/08, F165-07/08	Reconfiguration of the fire alarm system requirements, based on workgroup, clarifies notification and communication systems, addresses private mode signaling
299	56	907.2.7.1	907.2.7.1	F122-06/07, F164-07/08	Reconfiguration of the fire alarm system requirements, based on workgroup, , clarifies notification and communication systems
300	56	907.2.7	907.2.7	F122-06/07	Reconfiguration of the fire alarm system requirements, based on workgroup
301	56	907.2.8.1	907.2.8.1	F122-06/07	Reconfiguration of the fire alarm system requirements, based on workgroup
302	56	907.2.8.2	907.2.8.2	F122-06/07, F163-07/08	Reconfiguration of the fire alarm system requirements, based on workgroup, specifies visual alarms not required in elevator cars, Clarifies where fire alarm systems and smoke detection systems are specifically required
303	56	907.2.8.3	907.2.8.3	F122-06/07	Reconfiguration of the fire alarm system requirements, based on workgroup
304	56	907.2.8	907.2.8	F122-06/07	Reconfiguration of the fire alarm system requirements, based on workgroup
305	56	907.2.9.1 (New)	907.2.9.1 (New)	F122-06/07, F166-07/08	Reconfiguration of the fire alarm system requirements, based on workgroup, clarifies needs for fire alarms in Group R-2 occupancies
306	56	907.2.9.2 (New)	907.2.9.2 (New)	F122-06/07	Reconfiguration of the fire alarm system requirements, based on workgroup
307	6	907.2.9.3 (New)	907.2.9.3 (New)	F109-09/10	Addresses dealing with fire alarms in multiple Group A occupancies
308	56	907.2.9	907.2.9	F122-06/07	Reconfiguration of the fire alarm system requirements, based on workgroup
309	17	907.2.10.1.3	907.2.10.1.3	F167-07/08, CCC	Adds requirements for fire alarms and detection in Group R-4 occupancies
310	12	907.2.11.3	907.2.11.3	F114-09/10, Part I; F115-09/10, Part I	Adds Group I-1 to smoke alarm requirements. Allows for wireless alarms.
311	57	907.2.11.1 907.2.10.1	907.2.11.1 907.2.10.1	F122-06/07, F167-07/08	Reconfiguration of the fire alarm system requirements, based on workgroup, updates fire alarms for R-4 occupancies
312	56	907.2.11.2 907.2.10.2	907.2.11.2 907.2.10.2	F122-06/07, F167-07/08	Reconfiguration of the fire alarm system requirements, based on workgroup
313	56	907.2.11.3 907.2.10.3	907.2.11.3 907.2.10.3	F122-06/07	Reconfiguration of the fire alarm system requirements, based on workgroup
314	56	907.2.11.4 907.2.10.4	907.2.11.4 907.2.10.4	F122-06/07	Reconfiguration of the fire alarm system requirements, based on workgroup
315	---	907.2.12.1	907.2.12.1	F118-09/10	Clarification of the term 'activate' rather than 'sound'
316	57	907.2.12.2 907.2.11.2	907.2.12.2 907.2.11.2	F122-06/07, F167-07/08, CCC	Reconfiguration of the fire alarm system requirements, based on workgroup, updates fire alarms for R-4 occupancies
317	57	907.2.12.3 907.2.11.3	907.2.12.3 907.2.11.3	F122-06/07, F167-07/08	Reconfiguration of the fire alarm system requirements, based on workgroup, updates fire alarms for R-4 occupancies
318	---	907.2.13.1.1	907.2.13.1.1	F119-09/10, CCC-F17-09	Clarification of smoke detector requirements in all buildings that have a fire alarm system.
319	56	907.2.13.1.1 907.2.12.1	907.2.13.1.1 907.2.12.1	F122-06/07, F169-07/08	Reconfiguration of the fire alarm system requirements, based on workgroup
320	---	907.2.13.1.2 907.2.12.1	907.2.13.1.2 907.2.12.1	F169-07/08	Clarification of high-rise fire alarm and detection requirements
321	56	907.2.13.1 907.2.12.1	907.2.13.1 907.2.12.1	F122-06/07, F163-07/08, F169-07/08	Reconfiguration of the fire alarm system requirements, based on workgroup, Clarifies where fire alarm systems and smoke detection systems are specifically required
322	16	907.2.13.2 907.2.12.2	907.2.13.2 907.2.12.2	F87-07/08, F164-07/08	Adds requirements for emergency responder radio coverage
323	---	907.2.18.1 Deleted .	907.2.18.1 Deleted .	F172-07/08	Removal of PA system requirement. Conflicts with NFPA 72
324	56	907.2.18.2 907.2.17.2	907.2.18.2 907.2.17.2	F122-06/07	Reconfiguration of the fire alarm system requirements, based on workgroup
325	---	907.2.20	907.2.20	G31-09/10, CCC10-G10	Addresses open-type mall buildings
326	17	907.2.10 through 907.2.10.3 (New)	907.2.10 through 907.2.10.3 (New)	F167-07/08	Adds requirements for fire alarms and detection in Group R-4 occupancies
327	57	907.2.11 907.2.10	907.2.11 907.2.10	F122-06/07, F167-07/08	Reconfiguration of the fire alarm system requirements, based on workgroup, updates fire alarms for R-4 occupancies
328	56	907.2.12 907.2.11	907.2.12 907.2.11	F122-06/07, F163-07/08	Reconfiguration of the fire alarm system requirements, based on workgroup, Clarifies where fire alarm systems and smoke detection systems are specifically required
329	56	907.2.13 907.2.12	907.2.13 907.2.12	F122-06/07, F163-07/08, F168-07/08, G14-07/08, CCC	Reconfiguration of the fire alarm system requirements, based on workgroup, Clarifies where fire alarm systems and smoke detection systems are specifically required

330	56	907.2.14 907.2.13	907.2.14 907.2.13	F122-06/07, F163-07/08	Reconfiguration of the fire alarm system requirements, based on workgroup, Clarifies where fire alarm systems and smoke detection systems are specifically required
331	56	907.2.15 907.2.14	907.2.15 907.2.14	F122-06/07, F163-07/08	Reconfiguration of the fire alarm system requirements, based on workgroup, Clarifies where fire alarm systems and smoke detection systems are specifically required
332	56	907.2.16 907.2.15	907.2.16 907.2.15	F122-06/07	Reconfiguration of the fire alarm system requirements, based on workgroup
333	56	907.2.18 907.2.17	907.2.18 907.2.17	F122-06/07, F163-07/08	Reconfiguration of the fire alarm system requirements, based on workgroup, Clarifies where fire alarm systems and smoke detection systems are specifically required
334	56	907.2.19 907.2.18	907.2.19 907.2.18	F122-06/07, E8-07/08	Reconfiguration of the fire alarm system requirements, based on workgroup
335	56	907.2.20 907.2.19.1	907.2.20 907.2.19.1	F122-06/07	Reconfiguration of the fire alarm system requirements, based on workgroup
336	56	907.2.21 907.2.20	907.2.21 907.2.20	F122-06/07	Reconfiguration of the fire alarm system requirements, based on workgroup
337	56	907.2.22 907.2.21	907.2.22 907.2.21	F122-06/07, F173-07/08	Reconfiguration of the fire alarm system requirements, based on workgroup
338	56	907.2.23 907.2.22	907.2.23 907.2.22	F122-06/07, F174-07/08	Reconfiguration of the fire alarm system requirements, based on workgroup
339	56	907.2	907.2	F122-06/07, F162-07/08, F163-07/08	Reconfiguration of the fire alarm system requirements, based on workgroup
340	56	907.3	907.3	F122-06/07, F175-07/08, F294-07/08	Reconfiguration of the fire alarm system requirements, based on workgroup
341	---	907.4.2.6 (New)	907.4.2.6 (New)	F123-09/10	Prescriptively requires manual fire alarm boxes to be unobstructed and unobscured.
342	---	907.4.1 907.12	907.4.1 907.12	F120-06/07	Specifies the requirements for duct detectors to be connected to required fire alarm systems
343	56	907.4.1 907.12	907.4.1 907.12	F122-06/07, F179-07/08	Reconfiguration of the fire alarm system requirements, based on workgroup
344	56	907.4.2 907.2.15	907.4.2 907.2.15	F122-06/07	Reconfiguration of the fire alarm system requirements, based on workgroup
345	56	907.4.3 through 907.5.1 (New)	907.4.3 through 907.5.1 (New)	F122-06/07	Reconfiguration of the fire alarm system requirements, based on workgroup
346	---	907.5.1	907.5.1	F122-09/10	Removal of the allowance for sprinklers to be able to be used in place of the fire detector above a fire alarm control panel
347	---	907.5.2.1.1	907.5.2.1.1	F125-09/10	Reverts sound levels for audible fire alarm components to that found in NFPA 72
348	---	907.5.2.1	907.5.2.1	F124-09/10	Sets requirements for fire alarm notification in occupant evacuation elevator lobbies
349	70	907.5.2.2.4 (New)	907.5.2.2.4 (New)	F105-09/10	Requirements for emergency voice/alarm communication captions in stadiums and arenas.
350	---	907.5.2.3.4	907.5.2.3.4	F128-09/10, F151-09/10, Pt II	Requirements for fire alarm control units to be able to handle expansion for visual devices in R-2 occupancies
351	56	907.5.2.5 907.4.5	907.5.2.5 907.4.5	F122-06/07	Reconfiguration of the fire alarm system requirements, based on workgroup
352	---	907.5.3.1 (New)	907.5.3.1 (New)	F180-07/08	Clarifies the allowance to use a sprinkler system in place of a heat detection system
353	56	907.5.2 907.4	907.5.2 907.4	F122-06/07	Reconfiguration of the fire alarm system requirements, based on workgroup
354	56	907.5.3 (New)	907.5.3 (New)	F122-06/07, F180-07/08 (p. 438)	Reconfiguration of the fire alarm system requirements, based on workgroup
355	56	907.6.1 . 907.8	907.6.1 . 907.8	F122-06/07	Reconfiguration of the fire alarm system requirements, based on workgroup
356	56	907.6.2.1.1 907.10.2	907.6.2.1.1 907.10.2	F122-06/07, F164-07/08	Reconfiguration of the fire alarm system requirements, based on workgroup, clarifies notification and communication systems
357	56	907.6.2.1.2 907.10.2	907.6.2.1.2 907.10.2	F122-06/07, F164-07/08	Reconfiguration of the fire alarm system requirements, based on workgroup, clarifies notification and communication systems
358	---	907.6.2.2.3 (New)	907.6.2.2.3 (New)	F164-07/08	Updates to notification and communication systems for fire alarms
359	56	907.6.2.2.4 907.2.1.2	907.6.2.2.4 907.2.1.2	F122-06/07	Reconfiguration of the fire alarm system requirements, based on workgroup
360	56	907.6.2.3.3 . Table 907.10.1.3 Table	907.6.2.3.3 . Table 907.10.1.3 Table	F122-06/07	Reconfiguration of the fire alarm system requirements, based on workgroup
361	56	907.6.2.3.3 907.10.1.3	907.6.2.3.3 907.10.1.3	F122-06/07	Reconfiguration of the fire alarm system requirements, based on workgroup
362	56	907.6.2.3.4 907.10.1.4	907.6.2.3.4 907.10.1.4	F122-06/07	Reconfiguration of the fire alarm system requirements, based on workgroup
363	56	907.6.2.2 907.2.12.2.3	907.6.2.2 907.2.12.2.3	F122-06/07, F164-07/08	Reconfiguration of the fire alarm system requirements, based on workgroup, clarifies notification and communication systems
364	56	907.6.2.3 907.10.1	907.6.2.3 907.10.1	F122-06/07, F118-06/07	Reconfiguration of the fire alarm system requirements, based on workgroup, specifies visual alarms not required in elevator cars
365	69	907.6.5.2 (New)	907.6.5.2 (New)	F64-09/10 (Editorial)	Requirements for code official notification on changes or termination of fire alarm monitoring
366	56	907.6 . 907.7	907.6 . 907.7	F122-06/07, F164-07/08	Reconfiguration of the fire alarm system requirements, based on workgroup, clarifies notification and communication systems
367	56	907.7.1 . 907.6	907.7.1 . 907.6	F122-06/07	Reconfiguration of the fire alarm system requirements, based on workgroup
368	56	907.7.2 . 907.5	907.7.2 . 907.5	F122-06/07	Reconfiguration of the fire alarm system requirements, based on workgroup
369	---	907.7.3.2 907.9.2	907.7.3.2 907.9.2	F164-07/08	Updates to notification and communication systems for fire alarms

370	---	907.7.4 . 907.13	907.7.4 . 907.13	F164-07/08	Updates to notification and communication systems for fire alarms
371	56	907.7.5 . 907.15	907.7.5 . 907.15	F122-06/07	Reconfiguration of the fire alarm system requirements, based on workgroup
372	56	907.8.1 . 907.2.10.4	907.8.1 . 907.2.10.4	F122-06/07	Reconfiguration of the fire alarm system requirements, based on workgroup
373	56	907.8.2 . 907.18	907.8.2 . 907.18	F122-06/07	Reconfiguration of the fire alarm system requirements, based on workgroup
374	56	907.8 . 907.17	907.8 . 907.17	F122-06/07	Reconfiguration of the fire alarm system requirements, based on workgroup
375	56	907.9.1 . 907.20.1	907.9.1 . 907.20.1	F122-06/07	Reconfiguration of the fire alarm system requirements, based on workgroup
376	56	907.9.2 . 907.20.2	907.9.2 . 907.20.2	F122-06/07	Reconfiguration of the fire alarm system requirements, based on workgroup
377	56	907.9.3 . 907.20.3	907.9.3 . 907.20.3	F122-06/07	Reconfiguration of the fire alarm system requirements, based on workgroup
378	56	907.9.4 . 907.20.4	907.9.4 . 907.20.4	F122-06/07	Reconfiguration of the fire alarm system requirements, based on workgroup
379	56	907.9.4.1 907.20.4.1	907.9.4.1 907.20.4.1	F122-06/07	Reconfiguration of the fire alarm system requirements, based on workgroup
380	56	907.9.5 . 907.20.5	907.9.5 . 907.20.5	F122-06/07	Reconfiguration of the fire alarm system requirements, based on workgroup
381	56	907.9 . 907.20	907.9 . 907.20	F122-06/07	Reconfiguration of the fire alarm system requirements, based on workgroup
382	56	907.4 907.11	907.4 907.11	F122-06/07	Reconfiguration of the fire alarm system requirements, based on workgroup
383	56	907.7 (New)	907.7 (New)	F122-06/07	Reconfiguration of the fire alarm system requirements, based on workgroup
384	56	907 (Reorganization)	907 (Reorganization)	F122-06/07	Reconfiguration of the fire alarm system requirements, based on workgroup
385	68	908.7.1 (New)	908.7.1 (New)	F133-09/10	Requirements for CO alarms
386	68	908.7 (New)	908.7 (New)	F133-09/10	Requirements for CO alarms
387	---	909.5	909.5	E5-09/10, Part II	Clarifies interior stairway and ramp references
388	---	909.8.1	909.8.1	F123-06/07	Updates terms related to smoke layer measurements in for smoke management system design
389	---	909.11	909.11	FS37-06/07, F189-07/08	Editorial changes regarding fire barriers
390	---	909.13.1	909.13.1	F140-09/10	References the Mechanical Code for control air tubing in smoke management systems
391	63	909.19	909.19	F141-09/10	Requirement for a maintenance manual for smoke management systems
392	40	910.2.3 Deleted .	910.2.3 Deleted .	E114-07/08	Elimination of tradeoffs regarding smoke and heat vents
393	---	910.2	910.2	F239-09/10	Requires mechanical ventilation when smoke and heat vents would be required and the space is not the top story
394	---	910.3.4	910.3.4	FS37-06/07, F198-07/08	Editorial changes regarding fire barriers
395	---	910.3.5	910.3.5	F193-07/08, F199-07/08	Addresses where draft curtains should be installed
396	---	910.4.4	910.4.4	FS37-06/07	Editorial changes regarding fire barriers
397	---	910.3 Table	910.3 Table	F194-07/08, F195-07/08	Removes a do-loop regarding smoke and heat vents
398	64	910.5 (New)	910.5 (New)	F146-09/10	Requirement for smoke and heat vent maintenance
399	---	912.2.1	912.2.1	F201-07/08	Changes the approval of fire department connections to the fire chief
400	---	912.2	912.2	F132-06/07	Editorial
401	---	912.3.2 (New)	912.3.2 (New)	F133-06/07	Requirements regarding access and protection of fire department connections
402	---	912.3.3 (New)	912.3.3 (New)	F133-06/07	Requirements regarding access and protection of fire department connections
403	---	912.3	912.3	F133-06/07	Requirements regarding access and protection of fire department connections
404	---	912.4	912.4	F202-07/08	Updated sign requirements for fire department connections
405	---	913.2.1 (New)	913.2.1 (New)	F203-07/08	Requirements pertaining the the protection of fire pump rooms
406	---	914.2.1	914.2.1	G31-09/10	Addresses open-type mall buildings
407	---	914.2.2	914.2.2	G31-09/10	Addresses open-type mall buildings
408	---	914.2.3	914.2.3	G31-09/10	Addresses open-type mall buildings
409	---	914.2	914.2	G31-09/10	Addresses open-type mall buildings
410	---	914.3.1.1.1	914.3.1.1.1	E5-09/10, Part II	Clarifies interior stairway and ramp references
411	---	914.3.1.1.1 (New)	914.3.1.1.1 (New)	G46-07/08	Provides additional requirements for standpipe installations in high rise buildings
412	---	914.3.1.1 (New)	914.3.1.1 (New)	G46-07/08	Provides additional requirements for standpipe installations in high rise buildings
413	---	914.3.1.2 (New)	914.3.1.2 (New)	G46-07/08	Provides additional requirements for standpipe installations in high rise buildings
414	---	914.3.1	914.3.1	FS37-06/07	Editorial changes regarding fire barriers
415	---	914.4.1	914.4.1	FS37-06/07	Editorial changes regarding fire barriers
416	---	914.6.1	914.6.1	G70-09/10; CCC-IBC3-09	Update to sprinkler requirements for stage areas
417	---	914.8.2.2	914.8.2.2	G71-09/10	Update to fire area separation within aircraft servicing and storage areas
418	---	914.8.2.1 (New)	914.8.2.1 (New)	G25-07/08	Updates to classifications of aircraft related occupancies
419	---	914.8.2.2 (New)	914.8.2.2 (New)	G25-07/08	Updates to classifications of aircraft related occupancies
420	---	914.8.2	914.8.2	G25-07/08	Updates to classifications of aircraft related occupancies
421	---	914.8.2 Table (New)	914.8.2 Table (New)	G25-07/08	Updates to classifications of aircraft related occupancies

422	80	914.11 through 914.11.3	914.11 through 914.11.3	G15-09/10	Requirements regarding ambulatory care facilities
423	---	1002.1	1002.1	E5-06/07, E6-06/07, E111-06/07, E5-07/08, E7-07/08, E95-07/08, E110-07/08, E144-07/08	
424	---	1027.5.1	1027.5.1	E18-06/07	Clarifies door opening requirements
425	---	1027.1 1024.1	1027.1 1024.1	E150-06/07, E10-07/08, E138-07/08, E140-07/08	Clarification on the use of horizontal exits
426	---	1027.2 1022.2	1027.2 1022.2	FS37-06/07	Editorial changes regarding fire barriers
427	---	1027 1024	1027 1024	E111-06/07	Clarification on the term 'aisle'
428	---	1028.1.1 1025.1.1	1028.1.1 1025.1.1	E141-07/08	Updated requirements concerning fixed bleachers
429	---	1028.5.1 1025.5.1	1028.5.1 1025.5.1	E155-06/07	Clarification on press boxes
430	32	1028.10. 1025.10	1028.10. 1025.10	E158-06/07	Clarification on when a Group A is accessory to a Group E
431	---	1028.13. 1025.13	1028.13. 1025.13		
432	---	1028.14.2 . 1025.14.2	1028.14.2 . 1025.14.2	E160-06/07	Addition of ICC 300 for guard heights
433	32	1028.1 1025.1	1028.1 1025.1	E152-06/07	Clarification on when a Group A is accessory to a Group E
434	32	1028.2 1025.2	1028.2 1025.2	E152-06/07	Clarification on when a Group A is accessory to a Group E
435	32	1028.3 1025.3	1028.3 1025.3	E152-06/07	Clarification on when a Group A is accessory to a Group E
436	---	1028.4 1025.4	1028.4 1025.4	E153-06/07	Clarification on waiting areas in Group A-1
437	---	1028.5 1025.5	1028.5 1025.5	E155-06/07	Clarification on press boxes
438	32	1028.9 1025.9	1028.9 1025.9	E152-06/07	Clarification on when a Group A is accessory to a Group E
439	---	1028 1025	1028 1025	E111-06/07	Clarification on the term 'aisle'
440	---	1029 1026	1029 1026	E111-06/07	Clarification on the term 'aisle'
441	---	1030.2.1 (New)	1030.2.1 (New)	F151-09/10	Addresses special locking and acces-control on existing doorways.
442	---	1030.2	1030.2	F149-09/10, F151-09/10	Adds exit discharge to the requirements for reliability of the means of egress. Also limits exits and exit passageways from being used for other purposes.
443	---	1030.6	1030.6	F151-09/10	Addresses means of egress doors not being disguised and recognizable.
444	58	1030.2 (New)	1030.2 (New)	E19-07/08	Removal of sprinkler tradeoff regarding width of egress components
445	58	1030.2 Table (New)	1030.2 Table (New)	E19-07/08	Removal of sprinkler tradeoff regarding width of egress components
446	---	1030.9 (New)	1030.9 (New)	F151-09/10	Requirements for maintenance of floor identificaion signs.
447	---	1103.5	2003.5	F225-07/08	Recognizes aircraft fueling facilities within Chapter 22
448	---	1106.1	2006.1	F225-07/08	Recognizes aircraft fueling facilities within Chapter 22
449	---	1106.5.1	2006.5.1	F140-06/07	Updates to aircraft fueling vehicle operations, including the allowance for vehicles under aircraft wings during refueling of turbine-craft
450	---	1206.2	2106.2	F152-09/10	Further defines the limitation of Class 1 solvents in dry cleaning to 1 gallon and a specific use.
451	---	1206.3	2106.3	F152-09/10	Changes the terms from 'Types' to 'Classes' of dry cleaning solvents
452	---	1206.4	2106.4	F152-09/10	Allows for non-metal dispenser cans of Type IV dry cleaning solvents
453	---	1208.2	2108.2	F153-09/10	Allowances for Type IIIA dry cleaning plants to have certain exemptions for sprinklers
454	---	1411.1	3311.1	G48-07/08	Editorial
455	---	1413.1	3313.1	F141-06/07	Corrilates standpipe requirements for buildings under construction with that of Section 905
456	---	1417.1	3317.1	F142-06/07	Corrilates roofing operations in Chapter 14 with hot work requirements in Chapter 26
457	---	1501.2 (New)	2401.2	F217-07/08	Adds clarification to scope of flammable finishes regulated by Chapter 15
458	---	1506.2	2406.2	F144-06/07	Requirements regarding powder coating operations
459	---	1506.3	2406.3	F144-06/07	Requirements regarding powder coating operations
460	10	1507.2	2407.2	F145-06/07	Adds allowances for portable electrostatic paint-spraying apparatus
461	10	1507.3.1	2407.3.1	F145-06/07	Adds allowances for portable electrostatic paint-spraying apparatus
462	10	1507.3	2407.3	F145-06/07	Adds allowances for portable electrostatic paint-spraying apparatus
463	10	1507.5.1	2407.5.1	F145-06/07	Adds allowances for portable electrostatic paint-spraying apparatus
464	---	1701.1	2601.1	F158-09/10, F159-09/10	Redefines insecticidal fogging to not include heat as a qualifier
465	---	1703.1	2603.1	F158-09/10, F159-09/10	Redefines insecticidal fogging to not include heat as a qualifier
466	---	1703.2.1	2603.2.1	F159-09/10	Adds additional safety features for insecticidal fogging
467	---	1703.2.2	2603.2.2 (New)	F159-09/10	Adds additional safety features for insecticidal fogging
468	---	1703.2.3	2603.2.3 (New)	F159-09/10	Adds additional safety features for insecticidal fogging
469	---	1703.2	2603.2	F158-09/10	Redefines insecticidal fogging to not include heat as a qualifier
470	---	1703.3.1	2603.3.1	F159-09/10	Adds additional safety features for insecticidal fogging

471	---	1703.3.2	2603.3.2	F158-09/10	Redefines insecticidal fogging to not include heat as a qualifier
472	---	1703.3.4	2603.3.4 (New)	F159-09/10	Adds additional safety features for insecticidal fogging
473	---	1703.3.5	2603.3.5 (New)	F159-09/10	Adds additional safety features for insecticidal fogging
474	---	1703.3	2603.3	F158-09/10, F159-09/10	Redefines insecticidal fogging to not include heat as a qualifier
475	---	1703.5.1	2603.5.1 (New)	F159-09/10	Adds additional safety features for insecticidal fogging
476	---	1703.5	2603.5	F159-09/10	Adds additional safety features for insecticidal fogging
477	---	1802.1	2702.1	F219-07/08	Clarifies the requirements for HPM handling in rehabilitated semiconductor facilities
478	---	1803.10.1.2	2703.10.1.2	F160-09/10	Adds a UL standard regarding semi-conductor tool construction
479	---	1803.12.1.2	2703.12.1.2	E5-09/10, Part II	Clarifies interior stairway and ramp references
480	---	1803.13.2	2703.13.2	F147-06/07	Sets thresholds for gas detection monitoring in semiconductor facilities
481	---	1803.16	2703.16 (New)	F164-09/10	Adds an NFPA standrd regarding SAGS in semi-conductor facilities
482	---	1804.2.2.1 Table	2704.2.2.1 Table	F165-09/10	Further defines the amount of pyrophoric materials that can be in a semi-conductor fab or workstation
483	---	1805.2.3.4	2705.2.3.4	F166-09/10	Modifies the monitoring of cabinet exhaust in semi-conductor facilities
484	---	1805.2.3.4 Deleted .	2705.2.3.4 Deleted	F223-07/08	Removes workstation clearances within semiconductor facilities
485	---	1805.2.2 Table	2705.2.2 Table	F151-06/07, F152-06/07	Removes the limitation of 5.3 gallon DOT containers in workstations in semiconductor facilities, removes cylinder limitations and replaces with aggregate quantities
486	---	1805.2.2 Table	2705.2.2 Table	F165-09/10	Further defines the amount of pyrophoric materials that can be in a semi-conductor fab or workstation
487	---	1805.3.1	2705.3.1	F167-09/10, CCC10-IFC1	Addresses HPM transportation in semi-conductor facilities
488	---	1805.3.2.1	2705.3.2.1 (New)	F167-09/10	Addresses HPM transportation in semi-conductor facilities
489	---	1805.3.2.2	2705.3.2.2 (New)	F167-09/10	Addresses HPM transportation in semi-conductor facilities
490	---	1805.3.2	2705.3.2	F167-09/10	Addresses HPM transportation in semi-conductor facilities
491	---	2106.2.1	2106.2.1 (New)	F152-09/10	Further defines the limitation of Class 1 solvents in dry cleaning to 1 gallon and a specific use.
492	---	2201.1	2301.1	F225-07/08	Recognizes aircraft fueling facilities within Chapter 22
493	---	2202.1	2302.1	F225-07/08, F230-07/08	Recognizes aircraft fueling facilities within Chapter 22, New requirements addressing alcohol blended fuel-dispensing systems
494	43	2204.4.1	2304.4.1	F226-07/08	Limits the dispensing into portable container of not more than 5 gallons
495	47	2205.1	2305.1	F168-09/10	Modifies the motor-fuel distribution facility requirements for Biodiesel
496	---	2205.2.2	2305.2.2	F169-09/10	Removes a laundry list of requirements for fuel-dispensing equipment inspection
497	---	2205.2.1 (New)	2305.2.1	F228-07/08	Provides requirements for the inspection of fuel dispensing equipment
498	---	2205.2.2 (New)	2305.2.2	F228-07/08	Provides requirements for the inspection of fuel dispensing equipment
499	---	2206.2.2	2306.2.2	F171-09/10	Requires aboveground tanks to meet UL 2085
500	47	2206.2.3	2306.2.3	F168-09/10, F171-09/10	Modifies the motor-fuel distribution facility requirements for Biodiesel
501	47	2206.2.5	2306.2.5	F168-09/10	Modifies the motor-fuel distribution facility requirements for Biodiesel
502	47	2206.2.3 Tbl	2306.2.3 Table	F168-09/10, CCC-IBC50-09	Modifies the motor-fuel distribution facility requirements for Biodiesel
503	47	2206.2	2306.2	F168-09/10	Modifies the motor-fuel distribution facility requirements for Biodiesel
504	47	2206.6.2	2306.6.2	F168-09/10, CCC-F21-09	Modifies the motor-fuel distribution facility requirements for Biodiesel
505	47	2206.7.6.1	2306.7.6.1	F168-09/10	Modifies the motor-fuel distribution facility requirements for Biodiesel
506	47	2206.7.6	2306.7.6	F168-09/10	Modifies the motor-fuel distribution facility requirements for Biodiesel
507	50	2206.7	2306.7	F230-07/08	New requirements addressing alcohol blended fuel-dispensing systems
508	---	2206.8.1	2306.8.1	F173-09/10	Requires fuel dispensing equipment to be compatible to alcohol blended products prior to use
509	50	2206.8 through 2206.8.5 (New)	2306.8 through 2306.8.5 (new)	F230-07/08	New requirements addressing alcohol blended fuel-dispensing systems
510	---	2209.2.1	2309.2.1	F174-09/10	Removed language on hydrogen fuel stations and references NFPA 55.
511	---	2209.2.2	2309.2.2	F175-09/10	Allows for the term approved for hydrogen motor fuel dispensing equipment
512	---	2209.3.1.1	2309.3 Deleted	F174-09/10	Removed language on hydrogen fuel stations and references NFPA 55.
513	---	2209.3.1.2	2309.3 Deleted	F174-09/10	Removed language on hydrogen fuel stations and references NFPA 55.
514	---	2209.3.1	2309.3 Deleted	F174-09/10	Removed language on hydrogen fuel stations and references NFPA 55.
515	---	2209.3.2.1	2309.3.1.1	F174-09/10	Removed language on hydrogen fuel stations and references NFPA 55.
516	---	2209.3.2.2	2309.3.2 Deleted	F174-09/10	Removed language on hydrogen fuel stations and references NFPA 55.
517	---	2209.3.2.5.1 through 2209.3.2.5.1.2	2309.3.2 Deleted	F174-09/10	Removed language on hydrogen fuel stations and references NFPA 55.
518	---	2209.3.2.5.1 through 2209.3.2.5.1.2	2309.3.2 Deleted	F174-09/10	Removed language on hydrogen fuel stations and references NFPA 55.
519	---	2209.3.2.5	2309.3.2.5	F191-06/07	Expands Chapter 35 to include Flammable Cryogenic Liquids, Adds requirements for hydrogen storage tanks
520	---	2209.3.2	2309.3.1	F174-09/10	Removed language on hydrogen fuel stations and references NFPA 55.
521	---	2209.3.1 Table	2309.3 Deleted	F174-09/10	Removed language on hydrogen fuel stations and references NFPA 55.

522	---	2209.3	2309.3	F174-09/10	Removed language on hydrogen fuel stations and references NFPA 55.
523	---	2209.4.1 (New)	2309.4.1	F154-06/07	Adds overpressure protection devices for hydrogen refueling stations
524	---	2209.5.1.1 (New)	2309.5.1.1	F156-06/07, F233-07/08	Addresses vehicle fueling ground pads for hydrogen refueling
525	---	2209.5.4 through Table 2209.5.4.3.6 (2)	2309.3.2 Deleted	F174-09/10	Removed language on hydrogen fuel stations and references NFPA 55.
526	43	2210.3.4	2310.3.4	F226-07/08	Limits the dispensing into portable container of not more than 5 gallons
527	---	2211.7.2.1.1	2311.7.2.1.1 (New)	F178-09/10	Updates requirements for gas detection equipment for hydrogen fueling stations
528	---	2211.7.2.1	2311.7.2.1	F178-09/10	Updates requirements for gas detection equipment for hydrogen fueling stations
529	---	2211.7.2.1	2311.7.2.1	F157-06/07, F235-07/08	Requires listed gas detection equipment in service stations that repair gaseous vapor fuel vehicles
530	---	2211.7.2	2311.7.2	F157-06/07	Requires listed gas detection equipment in service stations that repair gaseous vapor fuel vehicles
531	---	2301.1	3201.1	F237-07/08	Updates of reference standards regarding sprinkler protection
532	72	2302.1	3202.1	F240-07/08	Requirements for first responder safeguards in buildings with automatic rack storage
533	65	2305.6 (New)	3205.6	F238-07/08	Requirement for visual designation of storage height in high-rack storage occupancies
534	---	2306.6.1.1	3206.6.1.1	F90-06/07	Sets spacing requirements between openings used to meet the windowless opening requirements
535	---	2308.4	3208.4	F237-07/08	Updates of reference standards regarding sprinkler protection
536	72	2309.4 (New)	3209.4	F240-07/08	Requirements for first responder safeguards in buildings with automatic rack storage
537	---	2310.1	3210.1	F237-07/08	Updates of reference standards regarding sprinkler protection
538	20	2401.1	3101.1	F161-06/07, F243-07/08	Adds tents and canopies to the limitations for fireworks, Aligns the terms 'tent' and 'canopy'
539	20	2402.1	3102.1	F243-07/08	Aligns the terms 'tent' and 'canopy'
540	20	2403.1	3103.1	F243-07/08	Aligns the terms 'tent' and 'canopy'
541	20	2403.2	3103.2	F243-07/08	Aligns the terms 'tent' and 'canopy'
542	20	2403.5	3103.5	F243-07/08	Aligns the terms 'tent' and 'canopy'
543	20	2403.6	3103.6	F243-07/08	Aligns the terms 'tent' and 'canopy'
544	20	2403.8.2	3103.8.2	F243-07/08	Aligns the terms 'tent' and 'canopy'
545	---	2403.8.4 (New)	3103.8.4	F241-07/08	Clarifies that tents, canopies, and membrane structures erected on buildings shall not be regulated as temporary.
546	20	2403.8.6 2403.8.5	3103.8.6 3103.8.5	F243-07/08	Aligns the terms 'tent' and 'canopy'
547	20	2403.8	3103.8	F243-07/08	Aligns the terms 'tent' and 'canopy'
548	20	2403.9	3103.9	F243-07/08	Aligns the terms 'tent' and 'canopy'
549	20	2403.11	3103.11	F243-07/08	Aligns the terms 'tent' and 'canopy'
550	---	2403.12.6.1	3103.12.6.1	F160-06/07, F242-07/08	Requires self-luminous signs to be labeled
551	20	2403.12.2 Table	3103.12.2	F243-07/08	Aligns the terms 'tent' and 'canopy'
552	20	2403.12	3103.12	F243-07/08	Aligns the terms 'tent' and 'canopy'
553	---	2404.1	3104.1	F161-07/08, F243-07/08	More prescriptive requirements for fire alarm shop drawings, Aligns the terms 'tent' and 'canopy'
554	20	2404.1	3104.1	F243-07/08	Aligns the terms 'tent' and 'canopy'
555	20	2404.2	3104.2	F243-07/08, CCC	Aligns the terms 'tent' and 'canopy'
556	20	2404.5	3104.5	F162-06/07, F243-07/08	Adds tents and canopies to the limitations for fireworks, Aligns the terms 'tent' and 'canopy'
557	---	2404.11	3104.11	F164-06/07	Editorial
558	20	2404.15.2	3104.15.2	F243-07/08	Aligns the terms 'tent' and 'canopy'
559	20	2404.15.5	3104.15.5	F243-07/08	Aligns the terms 'tent' and 'canopy'
560	20	2404.16.2	3104.16.2	F243-07/08	Aligns the terms 'tent' and 'canopy'
561	20	2404.16.3	3104.16.3	F243-07/08	Aligns the terms 'tent' and 'canopy'
562	20	2404.17.2	3104.17.2	F243-07/08	Aligns the terms 'tent' and 'canopy'
563	20	2404.17.3	3104.17.3	F243-07/08	Aligns the terms 'tent' and 'canopy'
564	20	2404.18.2	3104.18.2	F243-07/08	Aligns the terms 'tent' and 'canopy'
565	20	2404.18.5	3104.18.5	F243-07/08	Aligns the terms 'tent' and 'canopy'
566	20	2404.18	3104.18	F243-07/08	Aligns the terms 'tent' and 'canopy'
567	20	2404.19	3104.19	F243-07/08	Aligns the terms 'tent' and 'canopy'
568	20	2404.21	3104.21	F162-06/07, F243-07/08	Adds tents and canopies to the limitations for fireworks, Aligns the terms 'tent' and 'canopy'
569	20	2404.22	3104.22	F162-06/07, F243-07/08	Adds tents and canopies to the limitations for fireworks, Aligns the terms 'tent' and 'canopy'
570	20	2404.2 through 2404.4	3104.2 through 3104.4	F243-07/08	Aligns the terms 'tent' and 'canopy'
571	20	2404 (Section title)	3104	F243-07/08	Aligns the terms 'tent' and 'canopy'
572	20	2405.15.6	3105.15.6	F243-07/08	Aligns the terms 'tent' and 'canopy'
573	---	2501.1	3401.1	F237-07/08	Updates of reference standards regarding sprinkler protection
574	---	2502.2	3402.2	F244-07/08	Clarifies tire storage pile separation requirements
575	48	2506.1	3406.1	F294-07/08	Movement of all retroactive construction requirements to a new chapter

576	---	2605.2.1.1 (New)	3505.2.1.1	F165-06/07	Addresses welding carts using oxygen tanks
577	---	2605.2.1 (New)	3505.2.1	F165-06/07	Addresses welding carts using oxygen tanks
578	---	2605.4	3505.4	F208-06/07	Updates Referenced Standards
579	---	2701.2.2.1	5001.2.2.1	F245-07/08	Adds compressed gas to the physical hazard list
580	---	2701.5.1	5001.5.1	F246-07/08	Updates to the contents of the Hazardous Materials Management Plan
581	---	2701.5.2	5001.5.2	F246-07/08	Updates to the contents of the Hazardous Materials Management Plan
582	---	2702.1	5002.1	F245-07/08	Adds compressed gas to the physical hazard list
583	35	2703.1.1(1) Table	5003.1.1(1) Table	F46-06/07, F169-06/07, F247-07/08 (p. 492), CCC	Clarifies that fuel oil storage for building systems over 660 gallons is a Group H-3
584	---	2703.1.1(1) Tbl	5003.1.1(1) Table	F187-09/10, CCC-F23-09	Modifies the Haz-Mat table regarding combustible dust
585	---	2703.1.1(2) Table	5003.1.1(2) Table	F168-06/07, F169-06/07,	Requires haz-mat storage cabinets to be listed, allows for safety cans to count towards quantity increases, Changes the measurement of flammable gases in a liquid storage state to pounds
586	---	2703.1.1(3) Table	5003.1.1(3) Table	F169-06/07, F247-07/08	Changes the measurement of flammable gases in a liquid storage state to pounds
587	---	2703.1.1(4) Table	5003.1.1(4) Table	F169-06/07	Changes the measurement of flammable gases in a liquid storage state to pounds
588	---	2703.1	5003.1	E5-09/10, Part II, CCC10-IFC1	Clarifies interior stairway and ramp references
589	44	2703.2.1	5003.2.1	F249-07/08	Limits the installation of pressure vessels to ASME only; not DOT
590	---	2703.2.2.1	5003.2.2.1	F219-07/08	Clarifies the requirements for HPM handling in rehabilitated semiconductor facilities
591	---	2703.2.2	5003.2.2	F188-09/10	Adds a referenced standard for haz-mat fittings piping, tubing, and valves
592	---	2703.2.9	5003.2.9	F252-07/08	Adds the requirement that Haz-Mat safety systems are tested at the time of installation
593	---	2703.8.3.4	5003.8.3.4	F73-07/08, FS20-07/08	Editorial
594	---	2703.8.5.2	5003.8.5.2	F191-09/10	Requires gas cabinets to be provided with an exhaust ventilation system
595	---	2703.8.6.2	5003.8.6.2	F191-09/10	Requires gas cabinets to be provided with an exhaust ventilation system
596	---	2703.9.10 (New)	5003.9.10	F168-06/07, CCC	Requires haz-mat storage cabinets to be listed, allows for safety cans to count towards quantity increases
597	---	2703.10.2	5003.10.2	E5-09/10, Part II, CCC10-IFC1	Clarifies interior stairway and ramp references
598	---	2703.12	5003.12	F192-09/10	Barrier requirements for outdoor control areas
599	---	2704.1	5004.1	F193-09/10, Part I	Requirements for electrically supervised alarms, emergency alarms, and AFSS
600	---	2704.7	5004.7	F171-06/07, F254-07/08	Adds requirements for standby power or emergency power for storage areas of asphyxiants, irritants, and radioactive gases
601	---	2705.1.6	5005.1.6	F193-09/10, Part I	Requirements for electrically supervised alarms, emergency alarms, and AFSS
602	---	2705.1.11 . 2705.2.2.1	5005.1.11 5005.2.2.1	F231-06/07, F257-07/08	Expands requirements for design of hazardous material systems
603	---	2705.4.4	5005.4.4	E5-09/10, Part II	Clarifies interior stairway and ramp references
604	18	3001.1	5301.1	F205-06/07	Adds requirements for Liquid oxygen storage and use in home care
605	---	3002.1	5302.1	F260-07/08	Provides new requirements regarding the location and connection of 'tube trailers'
606	---	3003.2	5303.2	F208-06/07	Updates Referenced Standards
607	---	3003.7.11 through 3003.7.11.2 (New)	5303.7.11 through 5303.7.11.2 (new)	F260-07/08	Provides new requirements regarding the location and connection of 'tube trailers'
608	---	3006.2	5306.2	F173-06/07	Clarifies the need to consider high-hard occupancy classification for oxygen use areas
609	---	3201.1	5501.1	F191-06/07,	Expands Chapter 35 to include Flammable Cryogenic Liquids, Adds requirements for hydrogen storage tanks
610	---	3203.4.3	5503.4.3	F208-06/07	Updates Referenced Standards
611	---	3203.8	5503.8	F208-06/07	Updates Referenced Standards
612	---	3204.3.1.1.1 3203.6.1.1	5504.3.1.1.1	F262-07/08	Updates requirements regarding the location of cryogenic liquid storage
613	---	3204.3.1.1.2 3203.6.1.2	5504.3.1.1.2	F262-07/08	Updates requirements regarding the location of cryogenic liquid storage
614	---	3204.3.1.1.3 3204.3.1.1	5504.3.1.1.3	F191-06/07, F262-07/08	Expands Chapter 35 to include Flammable Cryogenic Liquids, Adds requirements for hydrogen storage tanks
615	---	3204.3.1.1.4 32304.3.1.2	5504.3.1.1.4	F262-07/08	Updates requirements regarding the location of cryogenic liquid storage
616	---	3204.3.1.1.5 3204.3.1.3	5504.3.1.1.5	F262-07/08	Updates requirements regarding the location of cryogenic liquid storage
617	---	3204.3.1.2.1 3203.6.2	5504.3.1.2.1	F262-07/08	Updates requirements regarding the location of cryogenic liquid storage
618	---	3204.3.1.2.1 Table 3203.6.2 Table	5504.3.1.2.1 Table	F262-07/08	Updates requirements regarding the location of cryogenic liquid storage
619	---	3204.3.1.2.2 3203.6.2.1	5504.3.1.2.2	F262-07/08	Updates requirements regarding the location of cryogenic liquid storage
620	---	3204.3.1.2.3 3204.3.2.2	5504.3.1.2.3	F262-07/08	Updates requirements regarding the location of cryogenic liquid storage
621	---	3204.3.1.1 3203.6.1	5504.3.1.1 5503.6.1	F262-07/08	Updates requirements regarding the location of cryogenic liquid storage
622	---	3204.3.1.1 Table 3203.6.1 Table	5504.3.1.1	F262-07/08	Updates requirements regarding the location of cryogenic liquid storage
623	---	3204.3.1.2 3204.3.2	5504.3.1.2	F262-07/08	Updates requirements regarding the location of cryogenic liquid storage

624	---	3204.3.2.1 Deleted .	5504.3.2.1	F262-07/08	Updates requirements regarding the location of cryogenic liquid storage
625	---	3204.3.1 3203.6	5504.3.1 5503.6	F262-07/08	Updates requirements regarding the location of cryogenic liquid storage
626	---	3204.3.1 Deleted .	5504.3.1	F262-07/08	Updates requirements regarding the location of cryogenic liquid storage
627	---	3204.3	5504.3	F262-07/08	Updates requirements regarding the location of cryogenic liquid storage
628	---	3205.3.1	5505.3.1	F262-07/08	Updates requirements regarding the location of cryogenic liquid storage
629	---	3205.4.6 3204.4.6	5505.4.6	F191-06/07	Expands Chapter 35 to include Flammable Cryogenic Liquids, Adds requirements for hydrogen storage tanks
630	---	3208.3.1 (New)	3208.3.1 (New)	F184-09/10	Requirements for the protection of flue spaces in high-rack applications
631	---	3301.1.3	5601.1.3	F176-06/07, F208-06/07	Adds the term displays in regarding the use of fireworks, Update to DOT 49CFR requirements
632	---	3301.1	5601.1	F208-06/07	Updates Referenced Standards
633	---	3301.3	5601.3	F208-06/07	Updates Referenced Standards
634	---	3301.8.1(3) Table	5601.8.1(3) Table	F265-07/08	Updates the separation table regarding consumer fireworks
635	---	3302.1	5602.1	F180-06/07, F208-06/07	Editorial change to add the term pyrotechnics to Chapter 33, Update to DOT 49CFR requirements
636	---	3304.5.2(2) Tbl	5604.5.2(2) Table	F199-09/10	Requirements for magazines containing fireworks
637	---	3304.5.2(3) Table	5604.5.2(3) Table	F267-07/08	Updates the separation table regarding consumer fireworks
638	---	3304.5.2(3) Tbl	5604.5.2(3) Table	F199-09/10	Requirements for magazines containing fireworks
639	---	3304.3 Table	5604.3 Table	F266-07/08	Updates the separation table regarding consumer fireworks
640	---	3307.4	5607.4	F179-06/07	Clarifies that daylight hours is between sunrise and sunset
641	---	3308.5.3	5608.8.3	F180-06/07	Editorial change to add the term pyrotechnics to Chapter 33
642	---	3308.5.4	5608.5.4	F180-06/07	Editorial change to add the term pyrotechnics to Chapter 33
643	---	3308.5.5	5608.5.5	F180-06/07	Editorial change to add the term pyrotechnics to Chapter 33
644	---	3308.8	5608.8	F180-06/07	Editorial change to add the term pyrotechnics to Chapter 33
645	---	3308.9	5608.9	F180-06/07	Editorial change to add the term pyrotechnics to Chapter 33
646	---	3308.1 through 3308.4	5608.1 through 5608.4	F180-06/07	Editorial change to add the term pyrotechnics to Chapter 33
647	---	3308.11 Deleted .	5608.11	F181-06/07	Removes the requirements of retail display and sale areas for fireworks
648	---	3309 (New)	5609	F268-07/08	Updates the separation table regarding consumer fireworks
649	---	3403.1.1 Table	5703.1.1 Table	F201-09/10	Reorganizes the Class I electrical equipment table
650	---	3403.6.2.1	5703.6.2.1	F270-07/08	Updated piping referenced standards for flammable and combustible liquids
651	---	3403.6.2	5703.6.2	F270-07/08	Updated piping referenced standards for flammable and combustible liquids
652	---	3403.6.2 Table (New)	5703.6.2 Table	F270-07/08	Updated piping referenced standards for flammable and combustible liquids
653	84	3404.2.3.2	5704.2.3.2	F271-07/08	Requires venting for Class IIIB liquid tanks
654	---	3404.2.7.3.2	5704.2.7.3.2	F203-09/10	Addresses pressure vacuum vents on vent line arresters
655	84	3404.2.7.3.3	5704.2.7.3.3	F271-07/08	Requires venting for Class IIIB liquid tanks
656	24	3404.2.7.4	5704.2.7.4	F204-09/10	Allows for emergency vents on UL 2085 tanks containing Class II or IIIA liquids to discharge inside the building
657	84	3404.2.7.5.2	5704.2.7.5.2	F271-07/08, F273-07/08	Requires venting for Class IIIB liquid tanks
658	---	3404.2.7.5.6	5704.2.7.5.6	F273-07/08	Prescriptive requirements regarding location of fill pipes of liquids
659	84	3404.2.7.5.8	5704.2.7.5.8	F271-07/08	Requires venting for Class IIIB liquid tanks
660	---	3404.2.8.12	5704.2.8.12	F187-06/07	Updates electrical classifications for flammable liquid areas
661	---	3404.2.8.17	5704.2.8.17	F187-06/07	Updates electrical classifications for flammable liquid areas
662	---	3404.2.9.5	5704.2.9.5	F205-09/10	Addresses above-ground tanks overflow protection and fill connections
663	---	3404.2.9.5	5704.2.9.5.1	F205-09/10	Addresses above-ground tanks overflow protection and fill connections
664	---	3404.2.9.5	5704.2.9.5.2	F205-09/10	Addresses above-ground tanks overflow protection and fill connections
665	---	3404.2.9.1 (New)	2704.2.9.1	F188-06/07	Clarifies the fire officials authority for tanks installed in noncompliance with existing requirements
666	84	3404.2.9.5 3404.2.9.4	5704.2.9.5	F271-07/08	Requires venting for Class IIIB liquid tanks
667	60	3404.2.13.1.4	5704.2.13.1.4	F274-07/08	Removes the exception for oil tanks under 1,000 gallons to be abandoned in place without fill
668	---	3404.2.15 (New)	5704.2.15	F275-07/08	Adds requirements for maintenance of aboveground tanks and piping systems
669	---	3404.3.3.9	5704.3.3.9	F237-07/08	Updates of reference standards regarding sprinkler protection
670	---	3404.3.6.1	5704.3.6.1	F211-09/10	Provides a referenced standard for the listing requirements of parts washer
671	---	3404.3.6.3(1) Table	5704.3.6.3(1)	F276-07/08	Updates reference to NFPA 30 regarding protection of rack storage
672	---	3404.3.6.3(2) Table	5704.3.6.3(2)	F276-07/08	Updates reference to NFPA 30 regarding protection of rack storage
673	---	3404.3.6.3(3) Table	5704.3.6.3(3)	F276-07/08	Updates reference to NFPA 30 regarding protection of rack storage
674	---	3404.3.6.3(4) through 3404.3.6.3(8) Tables	5704.3.6.3(4) through (8)	F276-07/08	Updates reference to NFPA 30 regarding protection of rack storage
675	---	3404.3.6.3(5) Tbl	5704.3.6.3(5) Table	F207-09/10	Lowers the height limit from 30 ft. to 14 feet for rack storage of liquids in metal containers requiring sprinkler protection
676	---	3404.3.6	5704.3.6	F206-09/10	Updates references to NFPA 30 regarding sprinkler coverage design parameters
677	---	3404.3.8.4	5704.3.8.4	F206-09/10	Updates references to NFPA 30 regarding sprinkler coverage design parameters

678	---	3405.2.4	5705.2.4	F208-09/10, F210-09/10	Clarification of how to handle heated class I liquids, limits the exemption from 5.3 to 1.3 gallons
679	---	3405.2.4	5705.2.4	F277-07/08	Better defines that Class II and III liquids that are heated are treated similar to Class I liquids
680	---	3405.2.5	5705.2.5	F278-07/08	Better defines that Class II and III liquids that are heated are treated similar to Class I liquids
681	---	3405.4.1	5705.4.1	F212-09/10	Removes solvent distillation units as an exempt from listing requirements for dry cleaning facilities
682	25	3405.5.1	5705.5.1	F190-06/07,	Allows for the use of certain aerosol based hand rubs
683	67	3405.5	5705.5	F213-09/10	Requirements for alcohol based hand rubs
684	---	3406.5.1.15	5706.5.1.15	F208-06/07	Updates Referenced Standards
685	---	3406.5.4.5	5706.5.4.5	F281-07/08	Adds separation requirements for storm drains
686	---	3501.1	5801.1	F214-09/10, F215-09/10	Updated requirements for hydrogen storage tanks
687	---	3501.1	5801.1	F191-06/07, F282-07/08	Expands Chapter 35 to include Flammable Cryogenic Liquids, Adds requirements for hydrogen storage tanks
688	---	3502.1	5802.1	F191-06/07, F194-06/07	Expands Chapter 35 to include Flammable Cryogenic Liquids, Adds requirements for hydrogen storage tanks, Adds requirements for metal hydraide storage systems
689	---	3503.1.1	5803.1.1	F283-07/08, F284-07/08	Prohibits the storage and use of oxidizing and flammable gases in offices, sets additional prohibitions to the exception regarding storage and use
690	---	3504.2.1.1	5802 Deleted	F215-09/10	Updated requirements for hydrogen storage tanks
691	---	3504.2.1.1 (New)	5804.2.1.1	F287-07/08	Creates new requirements for weather protection of flammable gases
692	---	3504.2.1	5802 Deleted	F215-09/10	Updated requirements for hydrogen storage tanks
693	---	3504.2.1 Table	5802 Deleted	F215-09/10	Updated requirements for hydrogen storage tanks
694	---	3506.4.8.1 3204.5.1	5806.4.8.1	F191-06/07	Expands Chapter 35 to include Flammable Cryogenic Liquids, Adds requirements for hydrogen storage tanks
695	---	3506.4.8.2 3204.5.2	5806.4.8.2	F191-06/07	Expands Chapter 35 to include Flammable Cryogenic Liquids, Adds requirements for hydrogen storage tanks
696	---	3506.4.8.3 3204.5.3	5806.4.8.3	F191-06/07	Expands Chapter 35 to include Flammable Cryogenic Liquids, Adds requirements for hydrogen storage tanks
697	---	3506.4.1 3204.4.1	5806.4.1	F191-06/07	Expands Chapter 35 to include Flammable Cryogenic Liquids, Adds requirements for hydrogen storage tanks
698	---	3506.4.2 3204.4.2	5806.4.2	F191-06/07	Expands Chapter 35 to include Flammable Cryogenic Liquids, Adds requirements for hydrogen storage tanks
699	---	3506.4.3 3204.4.3	5806.4.3	F191-06/07	Expands Chapter 35 to include Flammable Cryogenic Liquids, Adds requirements for hydrogen storage tanks
700	---	3506.4.4 3204.4.4	5806.4.4	F191-06/07	Expands Chapter 35 to include Flammable Cryogenic Liquids, Adds requirements for hydrogen storage tanks
701	---	3506.4.5 3204.4.5	5806.4.5	F191-06/07	Expands Chapter 35 to include Flammable Cryogenic Liquids, Adds requirements for hydrogen storage tanks
702	---	3506.4.7 3204.4.7	5806.4.7	F191-06/07	Expands Chapter 35 to include Flammable Cryogenic Liquids, Adds requirements for hydrogen storage tanks
703	---	3506.4.8 3204.5	5806.4.8	F191-06/07	Expands Chapter 35 to include Flammable Cryogenic Liquids, Adds requirements for hydrogen storage tanks
704	---	3506.1 through 3506.3.2.1 (New)	5806.1 through 5806.3.2.1	F191-06/07	Expands Chapter 35 to include Flammable Cryogenic Liquids, Adds requirements for hydrogen storage tanks
705	---	3506.4 3204.4	5806.4	F191-06/07	Expands Chapter 35 to include Flammable Cryogenic Liquids, Adds requirements for hydrogen storage tanks
706	---	3506 (New)	5806	F191-06/07	Expands Chapter 35 to include Flammable Cryogenic Liquids, Adds requirements for hydrogen storage tanks
707	---	3507 (New)	5807	F194-06/07	Adds requirements for metal hydraide storage systems
708	---	3704.2.2.7	6004.2.2.7	F198-06/07	Removes the exemption for small toxic gas systems for exhaust ventilation requirements
709	---	3704.2.2.10.1	6004.2.2.10.1	F178-09/10	Updates requirements for gas detection equipment for hydrogen fueling stations
710	---	3704.3.4.1 3704.3.2.5	6004.3.4.1	F289-07/08	Rearranges the compressed gas section regarding outdoor storage
711	---	3704.3.4.2 3704.3.2.6	6004.3.4.2	F289-07/08	Rearranges the compressed gas section regarding outdoor storage
712	---	3704.3.4.3 3704.3.2.7	6004.3.4.3	F289-07/08	Rearranges the compressed gas section regarding outdoor storage
713	---	3704.3.4	6004.3.4	F289-07/08	Rearranges the compressed gas section regarding outdoor storage
714	---	3705.1	6005.1	F200-06/07	Updates requirements for ozone generators in semiconductor facilities
715	---	3801.3	6101.3	F201-06/07	Specifies the term LP-gas container throughout the code
716	---	3802.1	6102.1	F201-06/07	Specifies the term LP-gas container throughout the code
717	---	3803.2.1.2	6103.2.1.2	F201-06/07	Specifies the term LP-gas container throughout the code
718	---	3803.2.2	6103.2.2	F201-06/07	Specifies the term LP-gas container throughout the code
719	---	3804.2	6104.2	F201-06/07	Specifies the term LP-gas container throughout the code
720	51	3804.3.1	6104.3.1 (New)	F216-09/10	Prohibits storage of propane on roofs
721	51	3804.3.1	6104.3.2	F216-09/10	Prohibits storage of propane on roofs
722	---	3804.3.1	6104.3.1	F201-06/07	Specifies the term LP-gas container throughout the code
723	---	3804.3	6104.3	F201-06/07	Specifies the term LP-gas container throughout the code
724	---	3804.4	6104.4	F201-06/07	Specifies the term LP-gas container throughout the code
725	---	3804 Title	6104	F201-06/07	Specifies the term LP-gas container throughout the code
726	---	3806.2	6106.2	F201-06/07	Specifies the term LP-gas container throughout the code
727	---	3806.3	6106.3	F201-06/07	Specifies the term LP-gas container throughout the code
728	---	3807.2	6107.2	F201-06/07	Specifies the term LP-gas container throughout the code
729	---	3808.1	6108.1	F201-06/07	Specifies the term LP-gas container throughout the code
730	---	3809.8	6109.8	F201-06/07	Specifies the term LP-gas container throughout the code
731	---	3809.10.1	6109.10.1	F201-06/07	Specifies the term LP-gas container throughout the code

732	---	3809.12	6109.12	F201-06/07	Specifies the term LP-gas container throughout the code
733	---	3809.13	6109.13	F201-06/07	Specifies the term LP-gas container throughout the code
734	---	3809.15.1	6109.15.1 (New)	F218-09/10	Provides requirements for automated LPG exchange racks
735	---	3809.15	6109.15 (New)	F218-09/10	Provides requirements for automated LPG exchange racks
736	---	3809.1 through 3809.6	6109.1 through 6109.6	F201-06/07	Specifies the term LP-gas container throughout the code
737	---	3809.12 Table	6109.12 Table	F201-06/07	Specifies the term LP-gas container throughout the code
738	---	3810.1	6110.1	F201-06/07	Specifies the term LP-gas container throughout the code
739	---	3810.2	6110.2	F201-06/07	Specifies the term LP-gas container throughout the code
740	---	3904.1.2	6204.1.2	G73-09/10, Part II	Updated reference for buildings containing organic peroxides
741	---	4001.1	6301.1	F203-06/07, F290-07/08	Changes the term oxidizer to oxidizing materials
742	---	4003.1.1.3	6303.1.1.3	F283-07/08, F284-07/08	Prohibits the storage and use of oxidizing and flammable gases in offices, sets additional prohibitions to the exception regarding storage and use
743	---	4003.1.1	6303.1.1	F203-06/07	Changes the term oxidizer to oxidizing materials
744	---	4003.1	6303.1	F203-06/07	Changes the term oxidizer to oxidizing materials
745	---	4003.2	6303.2	F203-06/07	Changes the term oxidizer to oxidizing materials
746	---	4004.1	6304.1	F203-06/07	Changes the term oxidizer to oxidizing materials
747	---	4004.2.2.1 (New)	6304.2.2.1 (New)	F203-06/07	Changes the term oxidizer to oxidizing materials
748	---	4004.2.2	6304.2.2	F203-06/07	Changes the term oxidizer to oxidizing materials
749	---	4004.2.4	6304.2.4	F203-06/07	Changes the term oxidizer to oxidizing materials
750	---	4004.2.2 Table	6304.2.2 Table	F203-06/07	Changes the term oxidizer to oxidizing materials
751	---	4004.2	6304.2	F203-06/07	Changes the term oxidizer to oxidizing materials
752	18	4006 (New)	6306	F205-06/07, F290-07/08	Adds requirements for Liquid oxygen storage and use in home care
753	---	4104.1	6404.1	F206-06/07	Removes language in IFC regarding Silane Gas, references CGA referenced standard
754	---	4104.2	6404.2	F206-06/07	Removes language in IFC regarding Silane Gas, references CGA referenced standard
755	---	4105.3	6405.3	F206-06/07	Removes language in IFC regarding Silane Gas, references CGA referenced standard
756	---	4106 Deleted.	6406 Deleted	F206-06/07	Removes language in IFC regarding Silane Gas, references CGA referenced standard
757	14	Chapter 45 (New)	4500	F210-06/07	Adds new chapter regarding marinas
758	---	4503.7 (New)	3603.7	F292-07/08	Updated requirements concerning marinas
759	---	4504.1	3604.1	F292-07/08	Updated requirements concerning marinas
760	---	4504.2.1 (New)	3604.2.1	F292-07/08	Updated requirements concerning marinas
761	---	4504.2	3604.2	F292-07/08	Updated requirements concerning marinas
762	---	4504.6 (New)	3604.6	F292-07/08	Updated requirements concerning marinas
763	---	Chapter 46	1100 Chapter 11	F1-09/10	Automatic detection requirements for college buildings, similar to the NYS requirements.
764	97	4601.2	1101.2	F219-09/10	Updates to triggers, administrative provisions, and building code requirements relative to retroactive construction requirements
765	97	4601.3	1101.3	F219-09/10	Updates to triggers, administrative provisions, and building code requirements relative to retroactive construction requirements
766	97	4601.4	1101.4	F219-09/10	Updates to triggers, administrative provisions, and building code requirements relative to retroactive construction requirements
767	---	4603.4.2	1103.6.2 (New)	F221-09/10	Adds retroactive construction requirements for standpipes
768	---	4603.5	1103.6	F221-09/10	Adds retroactive construction requirements for standpipes
769	---	4603.6.1	1103.6.1 (New)	F221-09/10	Adds retroactive construction requirements for standpipes
770	---	4603.6.6	1103.7.6	F223-09/10	Updates fire alarm requirements for exiting Group R-2 occupancies
771	---	4603.6.7	1103.7.7	F224-09/10	Updates fire alarm requirements for existing Group R-4 occupancies
772	57	4603.6.1 through 4603.7.3 907.3.1 through 907.3.4.3	1103.6.1 through 1103.7.3	F122-06/07, F167-07/08, F175-07/08, F176-07/08, F177-07/08, F178-07/08, F294-07/08	Reconfiguration of the fire alarm system requirements, based on workgroup, updates fire alarms for R-4 occupancies
773	---	4603.7.1	1103.8.1	F114-09/10, Part I; F225-09/10	Removes IRC language
774	---	4603.7.2	1103.8.2	F115-09/10, Part I	Allows for wireless interconnection.
775	12	4603.7	1103.8	F114-09/10, Part I	Adds Group I-1 to smoke alarm requirements.
776	76	4603.9	1103.9 (New)	F133-09/10	Requirements for retroactive CO alarms
777	76	4603.1 Table	1103.1 Table	F133-09/10, F219-09/10, F221-09/10, CCC10-IFC-18	Requirements for retroactive CO alarms, retroactive travel distance requirements, and retroactive standpipes
778	97	4604.1.2	1101.4.2	F219-09/10	Updates to triggers, administrative provisions, and building code requirements relative to retroactive construction requirements

779	97	4604.1	1104.1	F219-09/10	Updates to triggers, administrative provisions, and building code requirements relative to retroactive construction requirements
780	97	4604.4.1	1101.4.1	F219-09/10	Updates to triggers, administrative provisions, and building code requirements relative to retroactive construction requirements
781	---	4604.7	1104.7 Deleted	E21-09/10, Part II	Removes a table regarding egress reductions due to sprinklered existing buildings
782	96	4604.16.5.1	1104.16.5.1 (New)	F227-09/10	Updates requirements and sets an inspection schedule for fire escapes
783	96	4604.17.5	1106.16.5	F227-09/10	Updates requirements and sets an inspection schedule for fire escapes
784	97	4604.18.2 Table	1104.17.2 Table	F219-09/10,	Updates to triggers, administrative provisions, and building code requirements relative to retroactive construction requirements
785	---	4604.18.2 Table 1027.17.2 Table	1104.18.2	F209-07/08, CCC	Update to the dead-end requirements for existing buildings
786	---	4604.19. 1027.18	1104.19	E10-07/08	Editorial
787	---	4604.19	1104.2	E5-09/10, Part II, CCC10-IFC1	Clarifies interior stairway and ramp references
788	---	4604.20. 1027.19	1104.2	E10-07/08	Editorial
789	---	4604.5 1027.5	1104.5	E10-07/08, CCC	Editorial
790	---	4604.7 Table	1104.7 Table Deleted	E21-09/10, Part II	Removes a table regarding egress reductions due to sprinklered existing buildings
791	48	4604 1027	1104	F294-07/08	Movement of all retroactive construction requirements to a new chapter
792	---	ASTM	ASTM	F8-09/10, F51-09/10, ADM39-09/10	Updated ASTM standards
793	---	NFPA	NFPA	F56-09/10, F58-09/10, F63-09/10, F133-09/10, F146-09/10, F164-09/10; ADM39-09/10	Reference standard update
794	---	UL	UL	F8-09/10, F19-09/10, F44-09/10, F133-09/10, F160-09/10, F178-09/10; ADM39-09/10; E56-09/10	Updated UL standards
795	---	D103.1	D103.1	F67-07/08	Specifies that shoulders of roads are not permitted to be part of the fire apparatus access road requirements
796	---	D103.5	D103.5	F70-07/08	Adds a referenced standard for electric gate openers and design criteria for automatic gate operation.
797	---	D103.6.1	D103.6.1	F230-09/10	Adds more prescriptive requirements for fire lane signs
798	---	D103.6.2	D103.6.2	F230-09/10	Adds more prescriptive requirements for fire lane signs
799	54	D105.1	D105.1	F231-09/10	Provides more prescriptive requirements for aerial apparatus access roads
800	---	D105.1	D105.1	F67-07/08	Specifies that shoulders of roads are not permitted to be part of the fire apparatus access road requirements
801	54	D105.2	D105.2	F231-09/10	Provides more prescriptive requirements for aerial apparatus access roads
802	54	D105.3	D105.3	F231-09/10	Provides more prescriptive requirements for aerial apparatus access roads
803	54	D105.4 (New)	D105.4 (New)	F231-09/10	Provides more prescriptive requirements for aerial apparatus access roads
804	---	D107.1	D107.1	F233-09/10	Specifies two separate entrances are needed for developments over 30 dwelling units
805	38	J Appendix J (New)	J Appendix J (New)	F236-09/10	Creates the building information sign in an Appendix
806	1	J103.1.1	510.4.2.1	F27-09/10	Addition of emergency responder radio coverage
807	1	J103.1.2	510.4.2.2	F27-09/10	Addition of emergency responder radio coverage
808	1	J103.1.3	510.4.2.3	F27-09/10	Addition of emergency responder radio coverage
809	1	J103.1.4	510.4.2.4	F27-09/10	Addition of emergency responder radio coverage
810	1	J103.1.5	510.4.2.5	F27-09/10	Addition of emergency responder radio coverage
811	1	J103.1	510.4.2	F27-09/10	Addition of emergency responder radio coverage
812	1	J103.2.1	510.5.1	F27-09/10	Addition of emergency responder radio coverage
813	1	J103.2.3	510.5.3	F27-09/10	Addition of emergency responder radio coverage
814	1	J103.2.4	510.5.4	F27-09/10	Addition of emergency responder radio coverage
815	1	J103.2.5	510.5.5	F27-09/10	Addition of emergency responder radio coverage
816	1	J103.3.3	510.6.1	F27-09/10	Addition of emergency responder radio coverage
817	1	J103.3.4	510.6.2	F27-09/10	Addition of emergency responder radio coverage
818	1	J103.3.5	510.6.3	F27-09/10	Addition of emergency responder radio coverage

## 2012 International Fire Code Changes

2012 IFC Code Section	2009 Code Section	Code Change Proposal	Brief Description
304.3.2	304.3.2	F3-09/10	Allowances for wastebaskets to be utilized that are non-metallic and meet the requirements of Section 808.4
307.1.1	307.1.1	F4-09/10, F5-09/10	Modifies the language regarding open burning
307.3	307.3	F5-09/10	Modifies the requirements for prescribed burns, as well as capabilities on extinguishment
315	315	F6-09/10	Modification to the general storage section
315.1	315.1	F6-09/10	Modification to the general storage section
315.2	315.1 (part)	F6-09/10	Modification to the general storage section
315.3 (All)	315.3 (All)	F6-09/10	Modification to the general storage section
315.3.2	315.3.2	E5-09/10	Clarifies interior stairway and ramp references
316.4 (New)	316.4 (New)	F7-09/10	Addresses obstructions on roofs
317 (All; New)	317 (All; New)	F8-09/10, F9-09/10	Addresses design and maintenance of rooftop gardens
403.2.1	403.2.1	F11-09/10	Adds requirements for emergency egress and escape routes in a public safety plan.
503.4.1 (New)	503.4.1 (New)	F17-09/10	Prohibits the installation of traffic calming devices without approval
505.1	505.1	F18-09/10	Allows for code official to require additional premises identification
506.1	506.1	F19-09/10	Requirements for a key box for non-standardized key boxes
506.1.2 (New)	506.1.2 (New)	F19-09/10	Requirements for a key box for non-standardized key boxes
507.5.1.1 (New)	507.5.1.1 (New)	F21-09/10	Requires a hydrant within 100 feet of a standpipe FDC, per NFPA 14
508.1.5	508.1.5	F25-09/10	Requires a building information card in the fire command center
509.1.1 (New)	509.1.1 (New)	F26-09/10	Requires utility controls be identified similar to fire protection equipment locations
510.1	510.1	F27-09/10, F29-09/10	Addition of emergency responder radio coverage
510.2 (New)	510.2 (New)	F27-09/10	Addition of emergency responder radio coverage
510.3	510.3	F27-09/10	Addition of emergency responder radio coverage
510.4 (New)	510.4 (New)	F27-09/10	Addition of emergency responder radio coverage
510.4.1	510.2	F27-09/10	Addition of emergency responder radio coverage
510.4.1.1	510.2.1	F27-09/10	Addition of emergency responder radio coverage
510.4.1.2	510.2.2	F27-09/10	Addition of emergency responder radio coverage
510.4.2	J103.1	F27-09/10	Addition of emergency responder radio coverage
510.4.2.1	J103.1.1	F27-09/10	Addition of emergency responder radio coverage
510.4.2.2	J103.1.2	F27-09/10	Addition of emergency responder radio coverage
510.4.2.3	J103.1.3	F27-09/10	Addition of emergency responder radio coverage
510.4.2.4	J103.1.4	F27-09/10	Addition of emergency responder radio coverage
510.4.2.5	J103.1.5	F27-09/10	Addition of emergency responder radio coverage
510.5	510.5	F27-09/10	Addition of emergency responder radio coverage
510.5.1	J103.2.1	F27-09/10	Addition of emergency responder radio coverage
510.5.3	J103.2.3	F27-09/10	Addition of emergency responder radio coverage
510.5.4	J103.2.4	F27-09/10	Addition of emergency responder radio coverage
510.5.5	J103.2.5	F27-09/10	Addition of emergency responder radio coverage
510.6	510.6	F27-09/10	Addition of emergency responder radio coverage
510.6.1	J103.3.3	F27-09/10	Addition of emergency responder radio coverage
510.6.2	J103.3.4	F27-09/10	Addition of emergency responder radio coverage
510.6.3	J103.3.5	F27-09/10	Addition of emergency responder radio coverage
601.1	601.1	F44-09/10	Creates requirements for cooking oil storage tank systems
604.2.13	604.2.13	G31-09/10, CCC10-G10	Addresses open-type mall buildings
604.5 through 604.5.2.1 (New)	604.5 through 604.5.2.1 (New)	F35-09/10	Requirements for the inspection of unit-type emergency lighting
605.11-605.11.4 (New)	605.11-605.11.4 (New)	F30-09/10	Addition of requirements for PV (solar) panel installations
606.9	606.9	F39-09/10	Update to the requirements of refrigeration controls and emergency shutoffs
606.9.1	606.9.1	F39-09/10	Update to the requirements of refrigeration controls and emergency shutoffs
607.5 thru 607.5.4 (New)	607.5 thru 607.5.4 (New)	F20-09/10, CCC10-IFC2	Requirements for upgrade of elevator keys when equipped as Phase 1, Phase 2, or fire service access elevator
608.5.2	608.5.2	F41-09/10	Increases the recombinant battery requirements to include non-sealed units
608.6.1	608.6.1	F42-09/10	Coordinates battery room ventilation requirements with the IMC

610 (New)	610 (New)	F44-09/10	Creates requirements for cooking oil storage tank systems
703.2	703.2	F46-09/10	Sets requirements regarding the application of labels to show compliance with opening protective inspections
803.3 Table	803.3 Table	E5-09/10	Clarifies interior stairway and ramp references
803.5.1	803.5.1	F48-09/10, CCC-F6-09	Addresses textile ceiling coverings
803.5.2 (New)	803.5.2 (New)	F49-09/10	Addresses textile ceiling coverings
803.6	803.6	F50-09/10	Addresses vinyl wall or ceiling coverings
803.6.1 Deleted	803.6.1 Deleted	F50-09/10	Addresses vinyl wall or ceiling coverings
803.6.2 Deleted	803.6.2 Deleted	F50-09/10	Addresses vinyl wall or ceiling coverings
803.8	803.8	F5136-09/10, Part II	Addresses polypropylene use as an interior finish
804.3 through 804.3.3.1 (New)	804.3 through 804.3.3.1 (New)	F51-09/10	Rewrite of the section regarding interior floor finishes
804.3.3.2 (New)	804.3.3.2 (New)	F51-09/10, E5-09/10	Rewrite of the section regarding interior floor finishes
805.4	805.4	F53-09/10	Extension of upholstered furniture limitations to decks, balconies, and porches for Group R-2 student housing
806.2	806.2	F56-09/10	Alternative test requirements for artificial decorative vegetation
807.4.2.1	807.4.2.1	F58-09/10, Part I	Addition of NFPA 289 as an alternative for fire testing of foam plastic interior products
808.1	808.1	F59-09/10	Addition of Group I-1 to the wastebasket and linen container fire safety requirements
808.2 (New)	808.2 (New)	F60-09/10	Addition of regulation on of waste containers in student housing
808.3	808.3	F58-09/10, Part I, F60-09/10	Addition of NFPA 289 as an alternative for fire testing of foam plastic interior products
808.4 (New)	808.4 (New)	F61-09/10	Address combustible lockers
901.4.3	901.4.3	F529-09/10, Part II	Defines how fire area separation should be regulated
901.4.6 (New)	901.4.6 (New)	F62-09/10	Requirements for fire pump rooms
901.6	901.6	F63-09/10	Requirements that mechanical smoke exhaust and smoke and heat vents are maintained per NFPA 204
901.6.1 Table	901.6.1 Table	F63-09/10	Requirements that mechanical smoke exhaust and smoke and heat vents are maintained per NFPA 204
901.9 (New)	901.9 (New)	F64-09/10	Requirements for code official notification on changes or termination of fire alarm monitoring
903.2.2	903.2.2	F68-09/10, G15-09/10	Requirements for sprinkler protection coverage area for ambulatory healthcare facilities
903.2.4	903.2.4	F69-09/10	Requirements for sprinklers in buildings that store, sell, display, or manufacture upholstered furniture or mattresses
903.2.6	903.2.6	F70-09/10, G16-09/10, G20-09/10	Sets limitations on the use of NFPA 13D in Group I-1 occupancies
903.2.7	903.2.7	F69-09/10	Requirements for sprinklers in buildings that store, sell, display, or manufacture upholstered furniture or mattresses
903.2.8.1 (New)	903.2.8.1 (New)	G20-09/10, CCC10-IFC-4	Updates regarding assisted living and group homes
903.2.8.2 (New)	903.2.8.2 (New)	G20-09/10, CCC10-IFC-4	Updates regarding assisted living and group homes
903.2.9	903.2.9	F69-09/10	Requirements for sprinklers in buildings that store, sell, display, or manufacture upholstered furniture or mattresses
903.2.11	903.2.11	F74-09/10	Removes Group R-3 from the exemption list for sprinklers in specific hazard areas
903.2.11.1	903.2.11.1	F75-09/10	Sets a sill height for openings allowed to used in determining windowless stories
903.2.11.1.3	903.2.11.1.3	F76-09/10	Sets additional parameters for basement sprinkler requirements; pertaining to partition installation
903.2.11.2	903.2.11.2	F77-09/10	Additional requirements for sprinkler and standpipe systems for rubbish and linen chutes
903.3.1	903.3.1	F78-09/10	Addresses the sprinkler design requirements in Chapters 23 and 34
903.3.1.1.1	903.3.1.1.1	F80-09/10	Addresses sprinkler design criteria regarding occupant evacuation elevators
903.3.1.3	903.3.1.3	G20-09/10, CCC-F11-09	Updates regarding assisted living and group homes
903.3.2	903.3.2	G15-09/10, G20-09/10	Requirements regarding ambulatory care facilities
903.3.5.2	903.3.5.2	F83-09/10	Clarifies that a required secondary water supply for sprinkler systems needs to be automatic
903.4.2	903.4.2	F85-09/10	Updates the language regarding exterior audible alarms for sprinkler activation
904.1.1 (New)	904.1.1 (New)	F87-09/10	Requirements for the certification of fire extinguishing systems inspectors
904.3.2	904.3.2	F88-09/10	Regarding the installation of multiple AFSS systems and simultaneous hazards
905.3	905.3	F243-09/10	Specifies that combination sprinkler/standpipes are permitted
905.3.3	905.3.3	G31-09/10	Addresses open-type mall buildings
905.3.6	905.3.6	F92-09/10	Clarifies the standpipe requirements for helistops and heliports
905.3.8 (New)	905.3.8 (New)	F8-09/10	Standpipe requirements for rooftop gardens

905.4	905.4	F93-09/10, G31-09/10; CCC10-G10	Clarifies rooftop standpipe connection requirements
906.1	906.1	F94-09/10, F95-09/10	Removes the fire extinguisher exemption for QR sprinklered buildings
906.2.1 (New)	906.2.1 (New)	F96-09/10	Certification requirements for fire extinguisher service technicians
907.2.1	907.2.1	F100-09/10	Addresses dealing with fire alarms in multiple Group A occupancies
907.2.1.2 (New)	907.2.1.2 (New)	F105-09/10	Requirements for emergency voice/alarm communication captions in stadiums and arenas.
907.2.2	907.2.2	G15-09/10	Requirements regarding ambulatory care facilities
907.2.2.1	907.2.2.1	G15-09/10	Requirements regarding ambulatory care facilities
907.2.3	907.2.3	F107-09/10	In Group E occupancies, removes the allowance for manual pull boxes to be removed because of two-way communications to classrooms. Also requires a voice/alarm communication system.
907.2.6	907.2.6	G20-09/10, CCC-F14-09	Updates regarding assisted living and group homes
907.2.6.2	907.2.6.2	G20-09/10	Updates regarding assisted living and group homes
907.2.9.3 (New)	907.2.9.3 (New)	F109-09/10	Addresses dealing with fire alarms in multiple Group A occupancies
907.2.11.3	907.2.11.3	F114-09/10, Part I; F115-09/10, Part I	Adds Group I-1 to smoke alarm requirements. Allows for wireless alarms.
907.2.12.1	907.2.12.1	F118-09/10	Clarification of the term 'activate' rather than 'sound'
907.2.13.1.1	907.2.13.1.1	F119-09/10, CCC-F17-09	Clarification of smoke detector requirements in all buildings that have a fire alarm system.
907.2.20	907.2.20	G31-09/10, CCC10-G10	Addresses open-type mall buildings
907.4.2.6 (New)	907.4.2.6 (New)	F123-09/10	Prescriptively requires manual fire alarm boxes to be unobstructed and unobscured.
907.5.1	907.5.1	F122-09/10	Removal of the allowance for sprinklers to be able to be used in place of the fire detector above a fire alarm control panel
907.5.2.1	907.5.2.1	F124-09/10	Sets requirements for fire alarm notification in occupant evacuation elevator lobbies
907.5.2.1.1	907.5.2.1.1	F125-09/10	Reverts sound levels for audible fire alarm components to that found in NFPA 72
907.5.2.2.4 (New)	907.5.2.2.4 (New)	F105-09/10	Requirements for emergency voice/alarm communication captions in stadiums and arenas.
907.5.2.3.4	907.5.2.3.4	F128-09/10, E151-09/10, Pt II	Requirements for fire alarm control units to be able to handle expansion for visual devices in R-2 occupancies
907.6.5.2 (New)	907.6.5.2 (New)	F64-09/10 (Editorial)	Requirements for code official notification on changes or termination of fire alarm monitoring
908.7 (New)	908.7 (New)	F133-09/10	Requirements for CO alarms
908.7.1 (New)	908.7.1 (New)	F133-09/10	Requirements for CO alarms
909.5	909.5	E5-09/10, Part II	Clarifies interior stairway and ramp references
909.13.1	909.13.1	F140-09/10	References the Mechanical Code for control air tubing in smoke management systems
909.19	909.19	F141-09/10	Requirement for a maintenance manual for smoke management systems
910.2	910.2	F239-09/10	Requires mechanical ventilation when smoke and heat vents would be required and the space is not the top story
910.5 (New)	910.5 (New)	F146-09/10	Requirement for smoke and heat vent maintenance
914.2	914.2	G31-09/10	Addresses open-type mall buildings
914.2.1	914.2.1	G31-09/10	Addresses open-type mall buildings
914.2.2	914.2.2	G31-09/10	Addresses open-type mall buildings
914.2.3	914.2.3	G31-09/10	Addresses open-type mall buildings
914.3.1.1.1	914.3.1.1.1	E5-09/10, Part II	Clarifies interior stairway and ramp references
914.6.1	914.6.1	G70-09/10; CCC-IBC3-09	Update to sprinkler requirements for stage areas
914.8.2.2	914.8.2.2	G71-09/10	Update to fire area separation within aircraft servicing and storage areas
914.11 through 914.11.3	914.11 through 914.11.3	G15-09/10	Requirements regarding ambulatory care facilities
1030.2	1030.2	F149-09/10, F151-09/10	Adds exit discharge to the requirements for reliability of the means of egress. Also limits exits and exit passageways from being used for other purposes.
1030.2.1 (New)	1030.2.1 (New)	F151-09/10	Addresses special locking and access-control on existing doorways.
1030.6	1030.6	F151-09/10	Addresses means of egress doors not being disguised and recognizable.
1030.9 (New)	1030.9 (New)	F151-09/10	Requirements for maintenance of floor identification signs.
1100 Chapter 11	Chapter 46	F1-09/10	Automatic detection requirements for college buildings, similar to the NYS requirements.
1101.2	4601.2	F219-09/10	Updates to triggers, administrative provisions, and building code requirements relative to retroactive construction requirements
1101.3	4601.3	F219-09/10	Updates to triggers, administrative provisions, and building code requirements relative to retroactive construction requirements

1101.4	4601.4	F219-09/10	Updates to triggers, administrative provisions, and building code requirements relative to retroactive construction requirements
1101.4.1	4604.4.1	F219-09/10	Updates to triggers, administrative provisions, and building code requirements relative to retroactive construction requirements
1101.4.2	4604.1.2	F219-09/10	Updates to triggers, administrative provisions, and building code requirements relative to retroactive construction requirements
1103.1 Table	Table 4603.1	F133-09/10, F219-09/10, F221-09/10, CCC10-IFC-18	Requirements for retroactive CO alarms, retroactive travel distance requirements, and retroactive standpipes
1103.6	4603.5	F221-09/10	Adds retroactive construction requirements for standpipes
1103.6.1 (New)	4603.6.1	F221-09/10	Adds retroactive construction requirements for standpipes
1103.6.2 (New)	4603.4.2	F221-09/10	Adds retroactive construction requirements for standpipes
1103.7.6	4603.6.6	F223-09/10	Updates fire alarm requirements for existing Group R-2 occupancies
1103.7.7	4603.6.7	F224-09/10	Updates fire alarm requirements for existing Group R-4 occupancies
1103.8	4603.7	F114-09/10, Part I	Adds Group I-1 to smoke alarm requirements.
1103.8.1	4603.7.1	F114-09/10, Part I; F225-09/10	Removes IRC language
1103.8.2	4603.7.2	F115-09/10, Part I	Allows for wireless interconnection.
1103.9 (New)	4603.9	F133-09/10	Requirements for retroactive CO alarms
1104.1	4604.1	F219-09/10	Updates to triggers, administrative provisions, and building code requirements relative to retroactive construction requirements
1104.7 Deleted	4604.7	E21-09/10, Part II	Removes a table regarding egress reductions due to sprinklered existing buildings
1104.7 Table Deleted	Table 4604.7	E21-09/10, Part II	Removes a table regarding egress reductions due to sprinklered existing buildings
1106.16.5	4604.17.5	F227-09/10	Updates requirements and sets an inspection schedule for fire escapes
1104.16.5.1 (New)	4604.16.5.1	F227-09/10	Updates requirements and sets an inspection schedule for fire escapes
1104.17.2 Table	Table 4604.18.2	F219-09/10,	Updates to triggers, administrative provisions, and building code requirements relative to retroactive construction requirements
		F228-09/10, CCC10-IFC-19	Correlates common path of egress travel requirements with the IBC for existing applications
1104.2	4604.19	E5-09/10, Part II, CCC10-IFC1	Clarifies interior stairway and ramp references
2007.5	905.5	F92-09/10	Clarifies the standpipe requirements for helistops and heliports
2106.2	1206.2	F152-09/10	Further defines the limitation of Class 1 solvents in dry cleaning to 1 gallon and a specific use.
2106.2.1 (New)	2106.2.1	F152-09/10	Further defines the limitation of Class 1 solvents in dry cleaning to 1 gallon and a specific use.
2106.3	1206.3	F152-09/10	Changes the terms from 'Types' to 'Classes' of dry cleaning solvents
2106.4	1206.4	F152-09/10	Allows for non-metal dispenser cans of Type IV dry cleaning solvents
2108.2	1208.2	F153-09/10	Allowances for Type IIIA dry cleaning plants to have certain exemptions for sprinklers
2305.1	2205.1	F168-09/10	Modifies the motor-fuel distribution facility requirements for Biodiesel
2305.2.2	2205.2.2	F169-09/10	Removes a laundry list of requirements for fuel-dispensing equipment inspection
2306.2	2206.2	F168-09/10	Modifies the motor-fuel distribution facility requirements for Biodiesel
2306.2.2	2206.2.2	F171-09/10	Requires aboveground tanks to meet UL 2085
2306.2.3	2206.2.3	F168-09/10, F171-09/10	Modifies the motor-fuel distribution facility requirements for Biodiesel
2306.2.3 Table	Tbl 2206.2.3	F168-09/10, CCC-IBC50-09	Modifies the motor-fuel distribution facility requirements for Biodiesel
2306.2.5	2206.2.5	F168-09/10	Modifies the motor-fuel distribution facility requirements for Biodiesel
2306.6.2	2206.6.2	F168-09/10, CCC-F21-09	Modifies the motor-fuel distribution facility requirements for Biodiesel
2306.7.6	2206.7.6	F168-09/10	Modifies the motor-fuel distribution facility requirements for Biodiesel
2306.7.6.1	2206.7.6.1	F168-09/10	Modifies the motor-fuel distribution facility requirements for Biodiesel
2306.8.1	2206.8.1	F173-09/10	Requires fuel dispensing equipment to be compatible to alcohol blended products prior to use
2309.2.1	2209.2.1	F174-09/10	Removed language on hydrogen fuel stations and references NFPA 55.
2309.2.2	2209.2.2	F175-09/10	Allows for the term approved for hydrogen motor fuel dispensing equipment
2309.3	2209.3	F174-09/10	Removed language on hydrogen fuel stations and references NFPA 55.
2309.3 Deleted	2209.3.1	F174-09/10	Removed language on hydrogen fuel stations and references NFPA 55.
2309.3 Deleted	Table 2209.3.1	F174-09/10	Removed language on hydrogen fuel stations and references NFPA 55.
2309.3 Deleted	2209.3.1.1	F174-09/10	Removed language on hydrogen fuel stations and references NFPA 55.
2309.3 Deleted	2209.3.1.2	F174-09/10	Removed language on hydrogen fuel stations and references NFPA 55.
2309.3.1	2209.3.2	F174-09/10	Removed language on hydrogen fuel stations and references NFPA 55.

2309.3.1.1	2209.3.2.1	F174-09/10	Removed language on hydrogen fuel stations and references NFPA 55.
2309.3.2 Deleted	2209.3.2.2	F174-09/10	Removed language on hydrogen fuel stations and references NFPA 55.
2309.3.2 Deleted	2209.3.2.5.1 through 2209.3.2.5.1.2	F174-09/10	Removed language on hydrogen fuel stations and references NFPA 55.
2309.3.2 Deleted	2209.3.2.5.1 through 2209.3.2.5.1.2	F174-09/10	Removed language on hydrogen fuel stations and references NFPA 55.
2309.3.2 Deleted	2209.5.4 through Table 2209.5.4.3.6 (2)	F174-09/10	Removed language on hydrogen fuel stations and references NFPA 55.
2311.7.2.1	2211.7.2.1	F178-09/10	Updates requirements for gas detection equipment for hydrogen fueling stations
2311.7.2.1.1 (New)	2211.7.2.1.1	F178-09/10	Updates requirements for gas detection equipment for hydrogen fueling stations
2601.1	1701.1	F158-09/10, F159-09/10	Redefines insecticidal fogging to not include heat as a qualifier
2603.1	1703.1	F158-09/10, F159-09/10	Redefines insecticidal fogging to not include heat as a qualifier
2603.2	1703.2	F158-09/10	Redefines insecticidal fogging to not include heat as a qualifier
2603.2.1	1703.2.1	F159-09/10	Adds additional safety features for insecticidal fogging
2603.2.2 (New)	1703.2.2	F159-09/10	Adds additional safety features for insecticidal fogging
2603.2.3 (New)	1703.2.3	F159-09/10	Adds additional safety features for insecticidal fogging
2603.3	1703.3	F158-09/10, F159-09/10	Redefines insecticidal fogging to not include heat as a qualifier
2603.3.1	1703.3.1	F159-09/10	Adds additional safety features for insecticidal fogging
2603.3.2	1703.3.2	F158-09/10	Redefines insecticidal fogging to not include heat as a qualifier
2603.3.4 (New)	1703.3.4	F159-09/10	Adds additional safety features for insecticidal fogging
2603.3.5 (New)	1703.3.5	F159-09/10	Adds additional safety features for insecticidal fogging
2603.5	1703.5	F159-09/10	Adds additional safety features for insecticidal fogging
2603.5.1 (New)	1703.5.1	F159-09/10	Adds additional safety features for insecticidal fogging
2703.10.1.2	1803.10.1.2	F160-09/10	Adds a UL standard regarding semi-conductor tool construction
2703.12.1.2	1803.12.1.2	E5-09/10, Part II	Clarifies interior stairway and ramp references
2703.16 (New)	1803.16	F164-09/10	Adds an NFPA standard regarding SAGS in semi-conductor facilities
2704.2.2.1 Table	Table 1804.2.2.1	F165-09/10	Further defines the amount of pyrophoric materials that can be in a semi-conductor fab or workstation
2705.2.2 Table	Table 1805.2.2	F165-09/10	Further defines the amount of pyrophoric materials that can be in a semi-conductor fab or workstation
2705.2.3.4	1805.2.3.4	F166-09/10	Modifies the monitoring of cabinet exhaust in semi-conductor facilities
2705.3.1	1805.3.1	F167-09/10, CCC10-IFC1	Addresses HPM transportation in semi-conductor facilities
2705.3.2	1805.3.2	F167-09/10	Addresses HPM transportation in semi-conductor facilities
2705.3.2.1 (New)	1805.3.2.1	F167-09/10	Addresses HPM transportation in semi-conductor facilities
2705.3.2.2 (New)	1805.3.2.2	F167-09/10	Addresses HPM transportation in semi-conductor facilities
3208.3.1 (New)	3208.3.1 (New)	F184-09/10	Requirements for the protection of flue spaces in high-rack applications
5003.1.1(1) Table	Tbl 2703.1.1(1)	F187-09/10, CCC-F23-09	Modifies the Haz-Mat table regarding combustible dust
5003.2.2	2703.2.2	F188-09/10	Adds a referenced standard for haz-mat fittings piping, tubing, and valves
5003.8.5.2	2703.8.5.2	F191-09/10	Requires gas cabinets to be provided with an exhaust ventilation system
5003.8.6.2	2703.8.6.2	F191-09/10	Requires gas cabinets to be provided with an exhaust ventilation system
5003.1	2703.1	E5-09/10, Part II, CCC10-IFC1	Clarifies interior stairway and ramp references
5003.10.2	2703.10.2	E5-09/10, Part II, CCC10-IFC1	Clarifies interior stairway and ramp references
5003.12	2703.12	F192-09/10	Barrier requirements for outdoor control areas
5004.1	2704.1	F193-09/10, Part I	Requirements for electrically supervised alarms, emergency alarms, and AFSS
5005.1.6	2705.1.6	F193-09/10, Part I	Requirements for electrically supervised alarms, emergency alarms, and AFSS
5005.4.4	2705.4.4	E5-09/10, Part II	Clarifies interior stairway and ramp references
5604.5.2(2) Table	Tbl 3304.5.2(2)	F199-09/10	Requirements for magazines containing fireworks
5604.5.2(3) Table	Tbl 3304.5.2(3)	F199-09/10	Requirements for magazines containing fireworks
5703.1.1 Table	Table 3403.1.1	F201-09/10	Reorganizes the Class I electrical equipment table
5704.2.7.3.2	3404.2.7.3.2	F203-09/10	Addresses pressure vacuum vents on vent line arresters
5704.2.7.4	3404.2.7.4	F204-09/10	Allows for emergency vents on UL 2085 tanks containing Class II or IIIA liquids to discharge inside the building
5704.2.9.5	3404.2.9.5	F205-09/10	Addresses above-ground tanks overflow protection and fill connections
5704.2.9.5.1	3404.2.9.5	F205-09/10	Addresses above-ground tanks overflow protection and fill connections
5704.2.9.5.2	3404.2.9.5	F205-09/10	Addresses above-ground tanks overflow protection and fill connections
5704.3.6	3404.3.6	F206-09/10	Updates references to NFPA 30 regarding sprinkler coverage design parameters

5704.3.6.3(5) Table	Tbl 3404.3.6.3(5)	F207-09/10	Lowers the height limit from 30 ft. to 14 feet for rack storage of liquids in metal containers requiring sprinkler protection
5704.3.8.4	3404.3.8.4	F206-09/10	Updates references to NFPA 30 regarding sprinkler coverage design parameters
5705.2.4	3405.2.4	F208-09/10, F210-09/10	Clarification of how to handle heated class I liquids, limits the exemption from 5.3 to 1.3 gallons
5704.3.6.1	3404.3.6.1	F211-09/10	Provides a referenced standard for the listing requirements of parts washer
5705.4.1	3405.4.1	F212-09/10	Removes solvent distillation units as an exempt from listing requirements for dry cleaning facilities
5705.5	3405.5	F213-09/10	Requirements for alcohol based hand rubs
5801.1	3501.1	F214-09/10, F215-09/10	Updated requirements for hydrogen storage tanks
5802 Deleted	3504.2.1	F215-09/10	Updated requirements for hydrogen storage tanks
5802 Deleted	Table 3504.2.1	F215-09/10	Updated requirements for hydrogen storage tanks
5802 Deleted	3504.2.1.1	F215-09/10	Updated requirements for hydrogen storage tanks
6004.2.2.10.1	3704.2.2.10.1	F178-09/10	Updates requirements for gas detection equipment for hydrogen fueling stations
6104.3.1 (New)	3804.3.1	F216-09/10	Prohibits storage of propane on roofs
6104.3.2	3804.3.1	F216-09/10	Prohibits storage of propane on roofs
6109.15 (New)	3809.15	F218-09/10	Provides requirements for automated LPG exchange racks
6109.15.1 (New)	3809.15.1	F218-09/10	Provides requirements for automated LPG exchange racks
6204.1.2	3904.1.2	G73-09/10, Part II	Updated reference for buildings containing organic peroxides
ASTM	ASTM	F8-09/10, F51-09/10, ADM39-09/10	Updated ASTM standards
NFPA	NFPA	F56-09/10, F58-09/10, F63-09/10, F133-09/10, F146-09/10, F164-09/10; ADM39-09/10	Reference standard update
UL	UL	F8-09/10, F19-09/10, F44-09/10, F133-09/10, F160-09/10, F178-09/10; ADM39-09/10; E56-09/10	Updated UL standards
D103.6.1	D103.6.1	F230-09/10	Adds more prescriptive requirements for fire lane signs
D103.6.2	D103.6.2	F230-09/10	Adds more prescriptive requirements for fire lane signs
D105.1	D105.1	F231-09/10	Provides more prescriptive requirements for aerial apparatus access roads
D105.2	D105.2	F231-09/10	Provides more prescriptive requirements for aerial apparatus access roads
D105.3	D105.3	F231-09/10	Provides more prescriptive requirements for aerial apparatus access roads
D105.4 (New)	D105.4 (New)	F231-09/10	Provides more prescriptive requirements for aerial apparatus access roads
D107.1	D107.1	F233-09/10	Specifies two separate entrances are needed for developments over 30 dwelling units
J Appendix J (New)	J Appendix J (New)	F236-09/10	Creates the building information sign in an Appendix

## 2009 International Fire Code Changes

2009 Code Section	Code Change Proposal	Brief Description
301.1	F40-07/08	Retitle of Chapter 3, Movement of hazards to firefighters to Chapter 3
302.1	F44-07/08	Requirements for portable outdoor fireplaces
304.3	F42-07/08	Provides requirements for combustible dumpsters
304.3.2	F41-07/08	Adds test requirements for approvable combustible wastebaskets
304.3.4 (New)	F42-07/08, CCC	Provides requirements for combustible dumpsters
307 Title	F44-07/08	Requirements for portable outdoor fireplaces
307.1.1	F43-07/08	Update of open burning requirements
307.4.3 (New)	F44-07/08	Requirements for portable outdoor fireplaces
307.5	F44-07/08	Requirements for portable outdoor fireplaces
308.1	F51-07/08	Realigns the open flame requirements
308.1.1 . 308.2	F51-07/08	Realigns the open flame requirements
308.1.2 . 308.2.1	F51-07/08	Realigns the open flame requirements
308.1.3 . 308.4	F51-07/08	Realigns the open flame requirements
308.1.4 . 308.3.1	F51-07/08, F28-06/07, F48-07/08	Moves requirement regarding LP-gas cooking appliances under the general cooking appliance section, Realigns the open flame requirements
308.1.4 Exception 3 . 308.3.1.1	F28-06/07, F48-07/08	Movement of requirements concerning cooking devices
308.1.5 308.3.3	F51-07/08	Realigns the open flame requirements
308.1.6 308.5	F10-06/07, F51-07/08	Adds the term 'wildfire risk area' for open burning and signal fuse, realigns the open flame requirements
308.1.6.1 308.5.1	F10-06/07, F51-07/08	Adds the term 'wildfire risk area' for open burning and signal fuse use, realigns the open flame requirements
308.1.6.2 308.5.2	F51-07/08	Realigns the open flame requirements
308.1.7 308.3.5	F51-07/08	Realigns the open flame requirements
308.1.7.1 308.3.4	F51-07/08	Realigns the open flame requirements
308.1.8 308.6	F51-07/08	Realigns the open flame requirements
308.1.8.1 308.6.1	F51-07/08	Realigns the open flame requirements
308.1.8.2 308.6.2	F51-07/08	Realigns the open flame requirements
308.1.8.3 308.6.3	F51-07/08	Realigns the open flame requirements
308.1.8.4 308.6.4	F51-07/08	Realigns the open flame requirements
308.1.8.5 308.6.5	F51-07/08	Realigns the open flame requirements
308.2 (New)	F51-07/08	Realigns the open flame requirements
308.3 308.3.7	F51-07/08	Realigns the open flame requirements
308.3.1 308.3.2	F51-07/08	Realigns the open flame requirements
308.3.2 308.3.6	F51-07/08	Realigns the open flame requirements
308.4 (New)	F51-07/08	Realigns the open flame requirements
308.4.1 308.3.8	F51-07/08	Realigns the open flame requirements
311.2.1	F29-06/07	Additional requirements for the code official to post signs and barriertape regarding vacant buildings
311.2.2	F53-07/08	Adds requirements for lithium metal polymer batteries
311.5	F30-06/07	Clarifies the triggers for placards; including vacant or abandoned buildings that have structural or interior hazards
311.5.2	F31-06/07	Clarifies placard sign sizes are minimum dimensions
311.5.4	F54-07/08	Update of the hazard placards
313.1	F55-07/08	Adds portable generators to the list of 'fueled equipment'
315.3.1	F56-07/08	Sets additional sprinkler requirements for storage, display, and handling of combustible materials under eaves and associated construction
315.4 (New)	F78-07/08	Requirements regarding storage and structures underneath high-voltage transmission lines
316 (New) 507	F40-07/08	Retitle of Chapter 3, Movement of hazards to firefighters to Chapter 3
316.1 507.1	F40-07/08	Retitle of Chapter 3, Movement of hazards to firefighters to Chapter 3
316.2 507.2	F40-07/08	Retitle of Chapter 3, Movement of hazards to firefighters to Chapter 3
316.2.1 507.2.1	F40-07/08	Retitle of Chapter 3, Movement of hazards to firefighters to Chapter 3
316.2.2 507.2.2	F40-07/08	Retitle of Chapter 3, Movement of hazards to firefighters to Chapter 3
316.3 507.3	F40-07/08	Retitle of Chapter 3, Movement of hazards to firefighters to Chapter 3
316.4 401.5	F40-07/08	Retitle of Chapter 3, Movement of hazards to firefighters to Chapter 3
316.5 (New)	F78-07/08	Requirements regarding storage and structures underneath high-voltage transmission lines
316.5.1 (New)	F78-07/08	Requirements regarding storage and structures underneath high-voltage transmission lines
316.5.2 (New)	F78-07/08	Requirements regarding storage and structures underneath high-voltage transmission lines
317 (New)	F58-07/08	Adds test standards for laundry carts
401.3	F34-06/07 (p. 14)	Clarifies the actions of occupants and employees during a fire event
401.3.1 401.3	F34-06/07 (p. 14)	Clarifies the actions of occupants and employees during a fire event

401.3.2	F34-06/07	Clarifies the actions of occupants and employees during a fire event
401.3.3 . 401.3.2	F34-06/07	Clarifies the actions of occupants and employees during a fire event
401.3.4 (New)	F35-06/07	Prohibits the use of a false alarm to be counted as a fire drill
401.4 (New)	F34-06/07	Clarifies the actions of occupants and employees during a fire event
401.5 . 401.3.1	F34-06/07	Clarifies the actions of occupants and employees during a fire event
401.6 . 401.3.3	F34-06/07	Clarifies the actions of occupants and employees during a fire event
402.1	F61-07/08	Addresses lockdown plans
403.3 (New) .	F59-07/08	Sets requirements for crowd managers
404.1	F61-07/08	Addresses lockdown plans
404.2	F60-07/08	Adds Group F into fire safety and evacuation plan/drill requirements
404.3.1	E38-06/07	Requirements for fire evacuation plans and fire safety plans for buildings with areas of assisted rescue
404.3.2	E38-06/07	Requirements for fire evacuation plans and fire safety plans for buildings with areas of assisted rescue
404.3.3 through 404.3.3 (New)	F61-07/08	Addresses lockdown plans
404.5.1 (New)	F36-06/07	Sets requirements for the distribution of the fire safety and evacuation plan in mixed use buildings
405.2 Table	F60-07/08	Adds Group F into fire safety and evacuation plan/drill requirements
406.3.3 (New)	F61-07/08	Addresses lockdown plans
407.2	F62-07/08	Allows for electronic access to MSDS sheets be approvable
408.11.1	F38-06/07	Adds the requirement for the elevator machine room to be identified on the covered mall building lease plan submission
501.3	F65-07/08	Adds security gates as part of the fire apparatus access submission requirements
503.2.1	F67-07/08	Specifies that shoulders of roads are not permitted to be part of the fire apparatus access road requirements
503.2.8 (New)	F68-07/08	Angle of approach and departure is added to fire apparatus access road specifications
503.3	F69-07/08	Adds more prescriptive requirements for signs along fire lanes
503.5	F70-07/08	Adds a referenced standard for electric gate openers and design criteria for automatic gate operation.
503.6	F70-07/08	Adds a referenced standard for electric gate openers and design criteria for automatic gate operation.
504.3	F73-07/08	Editorial
505.1	F40-06/07	Modification to the address numbering requirements
507.5.4 . 508.5.4	F133-06/07	Requirements regarding access and protection of fire department connections
508 . 509	F43-06/07, F84-07/08, F85-07/08, CCC	Adds additional requirements for elevator controls and functional indicators in the fire command center
509.2 (New)	F44-06/07 (p. 20)	Requirements for keeping clear fire protection system controls
510 (New)	F87-07/08 (p. 373)	Adds requirements for emergency responder radio coverage
603.3.1	F46-06/07	Clarifies that fuel oil storage for building systems over 660 gallons is a Group H-3
603.3.2 Deleted .	F46-06/07	Clarifies that fuel oil storage for building systems over 660 gallons is a Group H-3
603.3.2 thru 603.3.2.5 (New)	F46-06/07	Clarifies that fuel oil storage for building systems over 660 gallons is a Group H-3
603.4	F47-06/07	Requirements for portable outdoor gas heaters
603.4.2 thru 603.4.2.3.4 (New)	F47-06/07, CCC	Requirements for portable outdoor gas heaters
604.2.13 Deleted .	F206-06/07	Removes language in IFC regarding Silane Gas, references CGA referenced standard
604.2.14.1.3 604.2.15.1.3	F89-07/08	Changes fire pump power from standby power to emergency power
604.2.14.3 604.2.15.3	F89-07/08	Changes fire pump power from standby power to emergency power
605.1	F91-07/08	Updates to the electric space heater requirements
606.8	F51-06/07	Sets requirements for the location of the signal sent by a refrigeration leak detector
606.9.1	F52-06/07	Additional requirements for refrigeration system emergency shutoffs
606.10.1.1	F93-07/08	Updates requirements to relief valve settings for refrigeration systems
606.10.2.2	F93-07/08	Updates requirements to relief valve settings for refrigeration systems
606.13	F94-07/08	Exempts ammonia from the discharge location requirements in refrigeration machinery rooms
607.1	F294-07/08	Movement of all retroactive construction requirements to a new chapter
607.3 (New)	F95-07/08	Clearance of combustibles from fire service access elevator lobbies
608.1	F53-06/07	Adds requirements for lithium metal polymer batteries
608.1 Table	F53-06/07	Adds requirements for lithium metal polymer batteries
608.3	F53-06/07	Adds requirements for lithium metal polymer batteries
608.5	F53-06/07	Adds requirements for lithium metal polymer batteries
608.5.1	F98-07/08	Updates the parameters of battery neutralization
608.5.2	F53-06/07, F98-07/08	Adds requirements for lithium metal polymer batteries
608.6.1	F53-06/07	Adds requirements for lithium metal polymer batteries
608.6.3 (New)	F54-06/07, F100-07/08	Requires supervision of ventilation systems where battery charging occurs
609.3 (New)	F55-06/07	Moves the maintenance of kitchen hoods to Chapter 6
609.3.1 904.11.6.1	F55-06/07	Moves the maintenance of kitchen hoods to Chapter 6
609.3.2 904.11.6.2	F55-06/07	Moves the maintenance of kitchen hoods to Chapter 6
609.3.3 904.11.6.3	F55-06/07, F102-06/07	Moves the maintenance of kitchen hoods to Chapter 6, Adds hood cleaning requirements to Chapter 6 of the Fire Code
609.3.3.1 (New)	F102-06/07	Adds hood cleaning requirements to Chapter 6 of the Fire Code

609.3.3.1 Table (New)	F102-06/07	Adds hood cleaning requirements to Chapter 6 of the Fire Code
609.3.3.2 (New)	F102-06/07	Adds hood cleaning requirements to Chapter 6 of the Fire Code
609.3.3.3 (New)	F102-06/07	Adds hood cleaning requirements to Chapter 6 of the Fire Code
609.3.4 (New)	F55-06/07	Moves the maintenance of kitchen hoods to Chapter 6
701.1	F103-07/08, F294-07/08	Specifies how to deal with new floor openings in existing buildings,
701.2 (New)	F104-07/08	Recognizes unsafe conditions can exist due to unmaintained fire resistance construction
703.1	F105-07/08	Sets annual inspection requirements for passive fire protection systems
703.1.2	F59-06/07, F106-07/08	Adds smoke partitions to the maintenance requirements. Adds NFPA 80 for opening protective maintenance and inspection requirements.
703.1.3 (New)	F59-06/07, F107-07/08	Adds smoke partitions to the maintenance requirements. Adds NFPA 80 for opening protective maintenance and inspection requirements.
704.1	F294-07/08	Movement of all retroactive construction requirements to a new chapter
704.1 Table Deleted	F294-07/08	Movement of all retroactive construction requirements to a new chapter
801.1	F114-07/08	Clarifies new vs. existing requirements pertaining to interior finishes
802.1	F65-06/07, F119-07/08	Sets requirements for floor-wall base materials
803.1.2	F61-06/07	Editorial change regarding textile wall and ceiling finishes
803.5.1	F511-06/07	Addition of UL standards
803.6.2	F118-07/08	Specifies the referenced standard regarding the preparation of interior finish test samples
803.7.3	F62-06/07	Editorial change regarding foam plastic trim
803.8 (New)	FS165-07/08	Recognizes HDPE as an interior finish
803.9 (New)	F119-07/08	Defines and sets requirements for site-fabricated 'stretch systems', a type of interior panel
804.1	F63-06/07, F120-07/08, CCC	Clarification on the measurement of 10% as it applies to walls and ceilings
804.1.1 (New)	F64-06/07	Allowance for a room fire test to satisfy the interior finish requirements of interior trim
804.2.3	F63-06/07, F121-07/08	Clarification on the measurement of 10% as it applies to walls and ceilings
804.2.4	F64-06/07, FS11-06/07, CCC	Allowance for a room fire test to satisfy the interior finish requirements of interior trim
804.3 (New)	F65-06/07	Sets requirements for floor-wall base materials
805.1.1.1	F66-06/07, F67-06/07	Allows for the use of the same fire test standards in Group I-2 and I-3 occupancies for Group I-1, relative to newly introduced upholstered furnishings, Removes the exception that allowed newly introduced furniture in sprinklered buildings to be exempt for fire testing
805.1.2.1	F68-06/07	Removes the exception that allowed newly introduced mattresses in sprinklered buildings to be exempt for fire testing
805.2.1.1	F69-06/07	Removes the exception that allowed newly introduced furniture in sprinklered buildings to be exempt for fire testing (Group I-2)
805.3.1.1	F70-06/07	Removes the exception that allowed newly introduced furniture in sprinklered buildings to be exempt for fire testing
805.3.1.2	F71-06/07, F125-07/08	Removes the exception that allowed newly introduced furniture and mattresses in sprinklered buildings to be exempt for fire testing
805.3.2.1	F72-06/07	Removes the exception that allowed newly introduced mattresses in sprinklered buildings to be exempt for fire testing
805.3.2.2	F71-06/07	Removes the exception that allowed newly introduced furniture and mattresses in sprinklered buildings to be exempt for fire testing
805.4 through 805.4.2.3 (New)	F75-06/07, F126-07/08	Sets furnishing and mattress fire test standards for student housing
807.1	F127-07/08	Provides allowances for decorative materials in student housing
807.1.2	F128-07/08	Clarifies that 10% application of combustible decorative materials is calculated on a per surface basis
807.4.2.1	F78-06/07	Editorial, removing extra wording regarding cellular and foam plastic trim
808.1	F129-07/08	Expands the requirements for waste and linen containers to Group I-2 occupancies. Requires containers over 32 gallons to be stored in waste or linen collection rooms.
903.2	FS37-06/07, CCC	Editorial changes regarding fire barriers
903.2.1	F85-06/07, E8-07/08	Changes the requirements of assembly occupancy sprinkler requirements; between the Group A and the 'highest' level of exit discharge.
903.2.1.1	E10-07/08	Editorial
903.2.1.2	E10-07/08	Editorial
903.2.1.3	F132-07/08, E10-07/08	Removes the 'areas used for participant sports' exemption for sprinkler systems
903.2.1.4	F132-07/08, E10-07/08	Removes the 'areas used for participant sports' exemption for sprinkler systems
903.2.2 (New)	G23-07/08	Sets requirements for ambulatory health care facilities
903.2.2.1	G23-07/08	Sets requirements for ambulatory health care facilities
903.2.3 903.2.2	F85-06/07, F133-07/08, E10-07/08	Changes the requirements of assembly occupancy sprinkler requirements; between the Group A and the 'highest' level of exit discharge.
903.2.7 903.2.6	F135-07/08	Requirements regarding sprinklers for furniture stores
903.2.9 903.2.8	F136-07/08	Aligns requirements for sprinkler systems in parking garages with repair garages, relative to commercial trucks
903.2.9.1 903.2.8.1	G8-06/07, F136-07/08, G13-07/08	Requirements for shop drawings of passive fire protection requirements

903.2.10 903.2.9	F89-06/07	Provides a trigger for sprinkler protection in enclosed parking structures
903.2.11 903.2.10	F138-07/08, CCC	Editorial rewrite of section regarding special sprinkler requirements
903.2.11.1 903.2.10.1	F90-06/07, G8-06/07	Sets spacing requirements between openings used to meet the windowless opening requirements
903.2.11.4 903.2.12.1	F138-07/08	Editorial rewrite of section regarding special sprinkler requirements
903.2.11.5 903.2.12.2	F138-07/08	Editorial rewrite of section regarding special sprinkler requirements
903.2.11.6 903.2.13	F138-07/08	Editorial rewrite of section regarding special sprinkler requirements
903.2.11.6 Table 903.2.13 Table	F206-06/07, G131-06/07	Removes language in IFC regarding Silane Gas, references CGA referenced standard
903.2.13 Deleted .	F206-06/07, CCC	Removes language in IFC regarding Silane Gas, references CGA referenced standard
903.3.1	F140-07/08	Clarification of the use of 13R sprinkler systems
903.3.1.2.1	F96-06/07	Sets requirements for sprinklers to be installed on decks of Type 5 Group R construction only if there is a deck or roof above
903.3.1.3	F144-07/08	Adds townhouses to the allowance use of 13D under the IBC
903.3.5.2	G14-07/08	Attaches requirements for the IBC regarding high rises
903.4	F99-06/07	Clean up of terms regarding monitoring and supervision of sprinkler systems
903.4.1	F99-06/07, F147-07/08	Clean up of terms regarding monitoring and supervision of sprinkler systems
903.4.3	G14-07/08	Attaches requirements for the IBC regarding high rises
903.6.1	F294-07/08	Movement of all retroactive construction requirements to a new chapter
903.6.2 (New)	F154-07/08	Retroactive requirements for sprinklers in Group I-2 occupancies
904.11.6	F55-06/07	Moves the maintenance of kitchen hoods to Chapter 6
904.11.6.1 (New)	F156-07/08	Addresses vehicle fueling ground pads for hydrogen refueling
905.3.1	G81-06/07	Defines locking arrangements that are permitted in a Group I-1 occupancy
905.3.3	F104-06/07, F157-07/08	Updates the hydraulic requirements for standpipe connections in covered mall buildings
905.3.7	F158-07/08	Removal of a contradiction in the standpipe section regarding marinas
905.4	F159-07/08	Allowance for not installing a standpipe connection within exit passageways when a connection already exists in a closeby stairway
905.11	F294-07/08	Movement of all retroactive construction requirements to a new chapter
906.1 Table	F243-07/08	Aligns the terms 'tent' and 'canopy'
905.6.2	F105-06/07	Updates requirements regarding interconnection of standpipe risers
906.2	F160-07/08, CCC	Allows for alternative locations for fire extinguishers in Group I-3 occupancies
907 (Reorganization)	F122-06/07	Reconfiguration of the fire alarm system requirements, based on workgroup
907.1.1	F122-06/07, F161-07/08	Reconfiguration of the fire alarm system requirements, based on workgroup
907.1.2 (New)	F161-07/08	More prescriptive requirements for fire alarm shop drawings
907.2	F122-06/07, F162-07/08, F163-07/08	Reconfiguration of the fire alarm system requirements, based on workgroup
907.2.1	F122-06/07	Reconfiguration of the fire alarm system requirements, based on workgroup
907.2.1.1	F122-06/07	Reconfiguration of the fire alarm system requirements, based on workgroup
907.2.2	F122-06/07, G23-07/08	Reconfiguration of the fire alarm system requirements, based on workgroup
907.2.2.1 (New)	G23-07/08	Sets requirements for ambulatory health care facilities
907.2.3	F122-06/07, CCC	Reconfiguration of the fire alarm system requirements, based on workgroup
907.2.4	F122-06/07	Reconfiguration of the fire alarm system requirements, based on workgroup
907.2.5	F164-07/08	Updates to notification and communication systems for fire alarms
907.2.6	F122-06/07, F164-07/08, F165-07/08	Reconfiguration of the fire alarm system requirements, based on workgroup, clarifies notification and communication systems, addresses private mode signaling
907.2.6.1	F122-06/07	Reconfiguration of the fire alarm system requirements, based on workgroup
907.2.6.1.1 (New)	F122-06/07	Reconfiguration of the fire alarm system requirements, based on workgroup
907.2.6.2	F122-06/07	Reconfiguration of the fire alarm system requirements, based on workgroup
907.2.6.3	F163-07/08	Clarifies where fire alarm systems and smoke detection systems are specifically required
907.2.6.3.1	F122-06/07	Reconfiguration of the fire alarm system requirements, based on workgroup
907.2.6.3.2	F122-06/07	Reconfiguration of the fire alarm system requirements, based on workgroup
907.2.6.3.3	F122-06/07, F164-07/08	Reconfiguration of the fire alarm system requirements, based on workgroup, clarifies notification and communication systems
907.2.7	F122-06/07	Reconfiguration of the fire alarm system requirements, based on workgroup
907.2.7.1	F122-06/07, F164-07/08	Reconfiguration of the fire alarm system requirements, based on workgroup, clarifies notification and communication systems
907.2.8	F122-06/07	Reconfiguration of the fire alarm system requirements, based on workgroup
907.2.8.1	F122-06/07	Reconfiguration of the fire alarm system requirements, based on workgroup
907.2.8.2	F122-06/07, F163-07/08	Reconfiguration of the fire alarm system requirements, based on workgroup, specifies visual alarms not required in elevator cars, Clarifies where fire alarm systems and smoke detection systems are specifically required
907.2.8.3	F122-06/07	Reconfiguration of the fire alarm system requirements, based on workgroup
907.2.9	F122-06/07	Reconfiguration of the fire alarm system requirements, based on workgroup

907.2.9.1 (New)	F122-06/07, F166-07/08	Reconfiguration of the fire alarm system requirements, based on workgroup, clarifies needs for fire alarms in Group R-2 occupancies
907.2.9.2 (New)	F122-06/07	Reconfiguration of the fire alarm system requirements, based on workgroup
907.2.10 through 907.2.10.3 (New)	F167-07/08	Adds requirements for fire alarms and detection in Group R-4 occupancies
907.2.11 907.2.10	F122-06/07, F167-07/08	Reconfiguration of the fire alarm system requirements, based on workgroup, updates fire alarms for R-4 occupancies
907.2.11.1 907.2.10.1	F122-06/07, F167-07/08	Reconfiguration of the fire alarm system requirements, based on workgroup, updates fire alarms for R-4 occupancies
907.2.11.2 907.2.10.2	F122-06/07, F167-07/08	Reconfiguration of the fire alarm system requirements, based on workgroup
907.2.10.1.3	F167-07/08, CCC	Adds requirements for fire alarms and detection in Group R-4 occupancies
907.2.11.3 907.2.10.3	F122-06/07	Reconfiguration of the fire alarm system requirements, based on workgroup
907.2.11.4 907.2.10.4	F122-06/07	Reconfiguration of the fire alarm system requirements, based on workgroup
907.2.12 907.2.11	F122-06/07, F163-07/08	Reconfiguration of the fire alarm system requirements, based on workgroup, Clarifies where fire alarm systems and smoke detection systems are specifically required
907.2.12.2 907.2.11.2	F122-06/07, F167-07/08, CCC	Reconfiguration of the fire alarm system requirements, based on workgroup, updates fire alarms for R-4 occupancies
907.2.12.3 907.2.11.3	F122-06/07, F167-07/08	Reconfiguration of the fire alarm system requirements, based on workgroup, updates fire alarms for R-4 occupancies
907.2.13 907.2.12	F122-06/07, F163-07/08, F168-07/08, G14-07/08, CCC	Reconfiguration of the fire alarm system requirements, based on workgroup, Clarifies where fire alarm systems and smoke detection systems are specifically required
907.2.13.1 907.2.12.1	F122-06/07, F163-07/08, F169-07/08	Reconfiguration of the fire alarm system requirements, based on workgroup, Clarifies where fire alarm systems and smoke detection systems are specifically required
907.2.13.1.1 907.2.12.1.1	F122-06/07, F169-07/08	Reconfiguration of the fire alarm system requirements, based on workgroup
907.2.13.1.2 907.2.12.1.1	F169-07/08	Clarification of high-rise fire alarm and detection requirements
907.2.13.2 907.2.12.2	F87-07/08, F164-07/08	Adds requirements for emergency responder radio coverage
907.2.14 907.2.13	F122-06/07, F163-07/08	Reconfiguration of the fire alarm system requirements, based on workgroup, Clarifies where fire alarm systems and smoke detection systems are specifically required
907.2.15 907.2.14	F122-06/07, F163-07/08	Reconfiguration of the fire alarm system requirements, based on workgroup, Clarifies where fire alarm systems and smoke detection systems are specifically required
907.2.16 907.2.15	F122-06/07	Reconfiguration of the fire alarm system requirements, based on workgroup
907.2.18 907.2.17	F122-06/07, F163-07/08	Reconfiguration of the fire alarm system requirements, based on workgroup, Clarifies where fire alarm systems and smoke detection systems are specifically required
907.2.18.2 907.2.17.2	F122-06/07	Reconfiguration of the fire alarm system requirements, based on workgroup
907.2.19 907.2.18	F122-06/07, E8-07/08	Reconfiguration of the fire alarm system requirements, based on workgroup
907.4.1 907.12	F120-06/07	Specifies the requirements for duct detectors to be connected to required fire alarm systems
907.2.18.1 Deleted .	F172-07/08	Removal of PA system requirements. Conflicts with NFPA 72
907.2.20 907.2.19.1	F122-06/07	Reconfiguration of the fire alarm system requirements, based on workgroup
907.2.21 907.2.20	F122-06/07	Reconfiguration of the fire alarm system requirements, based on workgroup
907.2.22 907.2.21	F122-06/07, F173-07/08	Reconfiguration of the fire alarm system requirements, based on workgroup
907.2.23 907.2.22	F122-06/07, F174-07/08	Reconfiguration of the fire alarm system requirements, based on workgroup
907.3	F122-06/07, F175-07/08, F294-07/08	Reconfiguration of the fire alarm system requirements, based on workgroup
4603.6.1 through 4603.7.3 907.3.1 through 907.3.4.3	F122-06/07, F167-07/08, F175-07/08, F176-07/08, F17	Reconfiguration of the fire alarm system requirements, based on workgroup, updates fire alarms for R-4 occupancies
907.4 907.11	F122-06/07	Reconfiguration of the fire alarm system requirements, based on workgroup
907.4.1 907.12	F122-06/07, F179-07/08	Reconfiguration of the fire alarm system requirements, based on workgroup
907.4.2 907.2.15	F122-06/07	Reconfiguration of the fire alarm system requirements, based on workgroup
907.4.3 through 907.5.1 (New)	F122-06/07	Reconfiguration of the fire alarm system requirements, based on workgroup
907.5.2 907.4	F122-06/07	Reconfiguration of the fire alarm system requirements, based on workgroup
907.5.2.5 907.4.5	F122-06/07	Reconfiguration of the fire alarm system requirements, based on workgroup
907.5.3 (New)	F122-06/07, F180-07/08 (p. 438)	Reconfiguration of the fire alarm system requirements, based on workgroup
907.5.3.1 (New)	F180-07/08	Clarifies the allowance to use a sprinkler system in place of a heat detection system
907.6 . 907.7	F122-06/07, F164-07/08	Reconfiguration of the fire alarm system requirements, based on workgroup, clarifies notification and communication systems
907.6.1 . 907.8	F122-06/07	Reconfiguration of the fire alarm system requirements, based on workgroup
907.6.2.1.1 907.10.2	F122-06/07, F164-07/08	Reconfiguration of the fire alarm system requirements, based on workgroup, clarifies notification and communication systems
907.6.2.1.2 907.10.2	F122-06/07, F164-07/08	Reconfiguration of the fire alarm system requirements, based on workgroup, clarifies notification and communication systems
907.6.2.2 907.2.12.2.3	F122-06/07, F164-07/08	Reconfiguration of the fire alarm system requirements, based on workgroup, clarifies notification and communication systems
907.6.2.2.3 (New)	F164-07/08	Updates to notification and communication systems for fire alarms
907.6.2.2.4 907.2.1.2	F122-06/07	Reconfiguration of the fire alarm system requirements, based on workgroup

907.6.2.3 907.10.1	F122-06/07, F118-06/07	Reconfiguration of the fire alarm system requirements, based on workgroup, specifies visual alarms not required in elevator cars
907.6.2.3.3 907.10.1.3	F122-06/07	Reconfiguration of the fire alarm system requirements, based on workgroup
907.6.2.3.3 . Table 907.10.1.3 Table	F122-06/07	Reconfiguration of the fire alarm system requirements, based on workgroup
907.6.2.3.4 907.10.1.4	F122-06/07	Reconfiguration of the fire alarm system requirements, based on workgroup
907.7 (New)	F122-06/07	Reconfiguration of the fire alarm system requirements, based on workgroup
907.7.1 . 907.6	F122-06/07	Reconfiguration of the fire alarm system requirements, based on workgroup
907.7.2 . 907.5	F122-06/07	Reconfiguration of the fire alarm system requirements, based on workgroup
907.7.3.2 907.9.2	F164-07/08	Updates to notification and communication systems for fire alarms
907.7.4 . 907.13	F164-07/08	Updates to notification and communication systems for fire alarms
907.7.5 . 907.15	F122-06/07	Reconfiguration of the fire alarm system requirements, based on workgroup
907.8 . 907.17	F122-06/07	Reconfiguration of the fire alarm system requirements, based on workgroup
907.8.1 . 907.2.10.4	F122-06/07	Reconfiguration of the fire alarm system requirements, based on workgroup
907.8.2 . 907.18	F122-06/07	Reconfiguration of the fire alarm system requirements, based on workgroup
907.9 . 907.20	F122-06/07	Reconfiguration of the fire alarm system requirements, based on workgroup
907.9.1 . 907.20.1	F122-06/07	Reconfiguration of the fire alarm system requirements, based on workgroup
907.9.2 . 907.20.2	F122-06/07	Reconfiguration of the fire alarm system requirements, based on workgroup
907.9.3 . 907.20.3	F122-06/07	Reconfiguration of the fire alarm system requirements, based on workgroup
907.9.4 . 907.20.4	F122-06/07	Reconfiguration of the fire alarm system requirements, based on workgroup
907.9.4.1 907.20.4.1	F122-06/07	Reconfiguration of the fire alarm system requirements, based on workgroup
907.9.5 . 907.20.5	F122-06/07	Reconfiguration of the fire alarm system requirements, based on workgroup
909.8.1	F123-06/07	Updates terms related to smoke layer measurements in for smoke management system design
909.11	FS37-06/07, F189-07/08	Editorial changes regarding fire barriers
910.2.3 Deleted .	E114-07/08	Elimination of tradeoffs regarding smoke and heat vents
910.3 Table	F194-07/08, F195-07/08	Removes a do-loop regarding smoke and heat vents
910.3.4	FS37-06/07, F198-07/08	Editorial changes regarding fire barriers
910.3.5	F193-07/08, F199-07/08	Addresses where draft curtains should be installed
910.4.4	FS37-06/07	Editorial changes regarding fire barriers
912.2	F132-06/07	Editorial
912.2.1	F201-07/08	Changes the approval of fire department connections to the fire chief
912.3	F133-06/07	Requirements regarding access and protection of fire department connections
912.3.2 (New)	F133-06/07	Requirements regarding access and protection of fire department connections
912.3.3 (New)	F133-06/07	Requirements regarding access and protection of fire department connections
912.4	F202-07/08	Updated sign requirements for fire department connections
913.2.1 (New)	F203-07/08	Requirements pertaining the the protection of fire pump rooms
914.3.1	FS37-06/07	Editorial changes regarding fire barriers
914.3.1.1 (New)	G46-07/08	Provides additional requirements for standpipe installations in high rise buildings
914.3.1.1.1 (New)	G46-07/08	Provides additional requirements for standpipe installations in high rise buildings
914.3.1.2 (New)	G46-07/08	Provides additional requirements for standpipe installations in high rise buildings
914.4.1	FS37-06/07	Editorial changes regarding fire barriers
914.8.2	G25-07/08	Updates to classifications of aircraft related occupancies
914.8.2 Table (New)	G25-07/08	Updates to classifications of aircraft related occupancies
914.8.2.1 (New)	G25-07/08	Updates to classifications of aircraft related occupancies
914.8.2.2 (New)	G25-07/08	Updates to classifications of aircraft related occupancies
1002.1	E5-06/07, E6-06/07, E111-06/07, E5-07/08, E7-07/08, E95-07/08, E110-07/08, E144-07/08	
1027 1024	E111-06/07	Clarification on the term 'aisle'
1027.1 1024.1	E150-06/07, E10-07/08, E138-07/08, E140-07/08	Clarification on the use of horizontal exits
1027.2 1022.2	FS37-06/07	Editorial changes regarding fire barriers
1027.5.1	E18-06/07	Clarifies door opening requirements
1028 1025	E111-06/07	Clarification on the term 'aisle'
1028.1 1025.1	E152-06/07	Clarification on when a Group A is accessory to a Group E
1028.1.1 1025.1.1	E141-07/08	Updated requirements concerning fixed bleachers
1028.2 1025.2	E152-06/07	Clarification on when a Group A is accessory to a Group E
1028.3 1025.3	E152-06/07	Clarification on when a Group A is accessory to a Group E
1028.4 1025.4	E153-06/07	Clarification on waiting areas in Group A-1
1028.5 1025.5	E155-06/07	Clarification on press boxes
1028.5.1 1025.5.1	E155-06/07	Clarification on press boxes
1028.9 1025.9	E152-06/07	Clarification on when a Group A is accessory to a Group E
1028.10. 1025.10	E158-06/07	Clarification on when a Group A is accessory to a Group E

1028.13. 1025.13		
1028.14.2 . 1025.14.2	E160-06/07	Addition of ICC 300 for guard heights
1029 1026	E111-06/07	Clarification on the term 'aisle'
1030.2 (New)	E19-07/08	Removal of sprinkler tradeoff regarding width of egress components
1030.2 Table (New)	E19-07/08	Removal of sprinkler tradeoff regarding width of egress components
4604 1027	F294-07/08	Movement of all retroactive construction requirements to a new chapter
4604.5 1027.5	E10-07/08, CCC	Editorial
4604.18.2 Table 1027.17.2 Table	F209-07/08, CCC	Update to the dead-end requirements for existing buildings
4604.19. 1027.18	E10-07/08	Editorial
4604.20. 1027.19	E10-07/08	Editorial
1103.5	F225-07/08	Recognizes aircraft fueling facilities within Chapter 22
1106.1	F225-07/08	Recognizes aircraft fueling facilities within Chapter 22
1106.5.1	F140-06/07	Updates to aircraft fueling vehicle operations, including the allowance for vehicles under aircraft wings during refueling of turbine-craft
1411.1	G48-07/08	Editorial
1413.1	F141-06/07	Corrilates standpipe requirements for buildings under construction with that of Section 905
1417.1	F142-06/07	Corrilates roofing operations in Chapter 14 with hot work requirements in Chapter 26
1501.2 (New)	F217-07/08	Adds clarification to scope of flammable finishes regulated by Chapter 15
1506.2	F144-06/07	Requirements regarding powder coating operations
1506.3	F144-06/07	Requirements regarding powder coating operations
1507.2	F145-06/07	Adds allowances for portable electrostatic paint-spraying apparatus
1507.3	F145-06/07	Adds allowances for portable electrostatic paint-spraying apparatus
1507.3.1	F145-06/07	Adds allowances for portable electrostatic paint-spraying apparatus
1507.5.1	F145-06/07	Adds allowances for portable electrostatic paint-spraying apparatus
1802.1	F219-07/08	Clarifies the requirements for HPM handling in rehabilitated semiconductor facilities
1803.13.2	F147-06/07	Sets thresholds for gas detection monitoring in semiconductor facilities
1805.2.3.4 Deleted .	F223-07/08	Removes workstation clearances within semiconductor facilities
1805.2.2 Table	F151-06/07, F152-06/07	Removes the limitation of 5.3 gallon DOT containers in workstations in semiconductor facilities, removes cylinder limitations and replaces with aggregate quantities
2201.1	F225-07/08	Recognizes aircraft fueling facilities within Chapter 22
2202.1	F225-07/08, F230-07/08	Recognizes aircraft fueling facilities within Chapter 22, New requirements addressing alcohol blended fuel-dispensing systems
2204.4.1	F226-07/08	Limits the dispensing into portable container of not more than 5 gallons
2205.2.1 (New)	F228-07/08	Provides requirements for the inspection of fuel dispensing equipment
2205.2.2 (New)	F228-07/08	Provides requirements for the inspection of fuel dispensing equipment
2206.7	F230-07/08	New requirements addressing alcohol blended fuel-dispensing systems
2206.8 through 2206.8.5 (New)	F230-07/08	New requirements addressing alcohol blended fuel-dispensing systems
2209.3.2.5	F191-06/07	Expands Chapter 35 to include Flammable Cryogenic Liquids, Adds requirements for hydrogen storage tanks
2209.4.1 (New)	F154-06/07	Adds overpressure protection devices for hydrogen refueling stations
2209.5.1.1 (New)	F156-06/07, F233-07/08	Addresses vehicle fueling ground pads for hydrogen refueling
2210.3.4	F226-07/08	Limits the dispensing into portable container of not more than 5 gallons
2211.7.2	F157-06/07	Requires listed gas detection equipment in service stations that repair gaseous vapor fuel vehicles
2211.7.2.1	F157-06/07, F235-07/08	Requires listed gas detection equipment in service stations that repair gaseous vapor fuel vehicles
2301.1	F237-07/08	Updates of reference standards regarding sprinkler protection
2302.1	F240-07/08	Requirements for first responder safeguards in buildings with automatic rack storage
2305.6 (New)	F238-07/08	Requirement for visual designation of storage height in high-rack storage occupancies
2306.6.1.1	F90-06/07	Sets spacing requirements between openings used to meet the windowless opening requirements
2308.4	F237-07/08	Updates of reference standards regarding sprinkler protection
2309.4 (New)	F240-07/08	Requirements for first responder safeguards in buildings with automatic rack storage
2310.1	F237-07/08	Updates of reference standards regarding sprinkler protection
2401.1	F161-06/07, F243-07/08	Adds tents and canopies to the limitations for fireworks, Aligns the terms 'tent' and 'canopy'
2402.1	F243-07/08	Aligns the terms 'tent' and 'canopy'
2403.1	F243-07/08	Aligns the terms 'tent' and 'canopy'
2403.2	F243-07/08	Aligns the terms 'tent' and 'canopy'
2403.5	F243-07/08	Aligns the terms 'tent' and 'canopy'
2403.6	F243-07/08	Aligns the terms 'tent' and 'canopy'
2403.8	F243-07/08	Aligns the terms 'tent' and 'canopy'
2403.8.2	F243-07/08	Aligns the terms 'tent' and 'canopy'
2403.8.4 (New)	F241-07/08	Clarifies that tents, canopies, and membrane structures erected on buildings shall not be regulated as temporary.

2403.8.6 2403.8.5	F243-07/08	Aligns the terms 'tent' and 'canopy'
2403.9	F243-07/08	Aligns the terms 'tent' and 'canopy'
2403.11	F243-07/08	Aligns the terms 'tent' and 'canopy'
2403.12	F243-07/08	Aligns the terms 'tent' and 'canopy'
2403.12.2 Table	F243-07/08	Aligns the terms 'tent' and 'canopy'
2403.12.6.1	F160-06/07, F242-07/08	Requires self-luminous signs to be labeled
2404 (Section title)	F243-07/08	Aligns the terms 'tent' and 'canopy'
2404.1	F161-07/08, F243-07/08	More prescriptive requirements for fire alarm shop drawings, Aligns the terms 'tent' and 'canopy'
2404.2 through 2404.4	F243-07/08	Aligns the terms 'tent' and 'canopy'
2404.5	F162-06/07, F243-07/08	Adds tents and canopies to the limitations for fireworks, Aligns the terms 'tent' and 'canopy'
2403.8.4 (New)	F241-07/08	Clarifies that tents, canopies, and membrane structures erected on buildings shall not be regulated as temporary.
2404.1	F243-07/08	Aligns the terms 'tent' and 'canopy'
2404.11	F164-06/07	Editorial
2404.15.2	F243-07/08	Aligns the terms 'tent' and 'canopy'
2404.15.5	F243-07/08	Aligns the terms 'tent' and 'canopy'
2405.15.6	F243-07/08	Aligns the terms 'tent' and 'canopy'
2404.16.2	F243-07/08	Aligns the terms 'tent' and 'canopy'
2404.16.3	F243-07/08	Aligns the terms 'tent' and 'canopy'
2404.17.2	F243-07/08	Aligns the terms 'tent' and 'canopy'
2404.17.3	F243-07/08	Aligns the terms 'tent' and 'canopy'
2404.18	F243-07/08	Aligns the terms 'tent' and 'canopy'
2404.18.2	F243-07/08	Aligns the terms 'tent' and 'canopy'
2404.18.5	F243-07/08	Aligns the terms 'tent' and 'canopy'
2404.19	F243-07/08	Aligns the terms 'tent' and 'canopy'
2404.2	F243-07/08, CCC	Aligns the terms 'tent' and 'canopy'
2404.21	F162-06/07, F243-07/08	Adds tents and canopies to the limitations for fireworks, Aligns the terms 'tent' and 'canopy'
2404.22	F162-06/07, F243-07/08	Adds tents and canopies to the limitations for fireworks, Aligns the terms 'tent' and 'canopy'
2501.1	F237-07/08	Updates of reference standards regarding sprinkler protection
2502.2	F244-07/08	Clarifies tire storage pile separation requirements
2506.1	F294-07/08	Movement of all retroactive construction requirements to a new chapter
2605.2.1 (New)	F165-06/07	Addresses welding carts using oxygen tanks
2605.2.1.1 (New)	F165-06/07	Addresses welding carts using oxygen tanks
2605.4	F208-06/07	Updates Referenced Standards
2701.2.2.1	F245-07/08	Adds compressed gas to the physical hazard list
2701.5.1	F246-07/08	Updates to the contents of the Hazardous Materials Management Plan
2701.5.2	F246-07/08	Updates to the contents of the Hazardous Materials Management Plan
2702.1	F245-07/08	Adds compressed gas to the physical hazard list
2703.1.1(1) Table	F46-06/07, F169-06/07, F247-07/08 (p. 492), CCC	Clarifies that fuel oil storage for building systems over 660 gallons is a Group H-3
2703.1.1(2) Table	F168-06/07, F169-06/07,	Requires haz-mat storage cabinets to be listed, allows for safety cans to count towards quantity increases, Changes the measurement of flammable gases in a liquid storage state to pounds
2703.1.1(3) Table	F169-06/07, F247-07/08	Changes the measurement of flammable gases in a liquid storage state to pounds
2703.1.1(4) Table	F169-06/07	Changes the measurement of flammable gases in a liquid storage state to pounds
2703.2.1	F249-07/08	Limits the installation of pressure vessels to ASME only; not DOT
2703.2.2.1	F219-07/08	Clarifies the requirements for HPM handling in rehabilitated semiconductor facilities
2703.2.9	F252-07/08	Adds the requirement that Haz-Mat safety systems are tested at the time of installation
2703.8.3.4	F73-07/08, FS20-07/08	Editorial
2703.9.10 (New)	F168-06/07, CCC	Requires haz-mat storage cabinets to be listed, allows for safety cans to count towards quantity increases
2704.7	F171-06/07, F254-07/08	Adds requirements for standby power or emergency power for storage areas of asphyxiants, irritants, and radioactive gases
2705.1.11 . 2705.2.2.1	F231-06/07, F257-07/08	Expands requirements for design of hazardous material systems
3001.1	F205-06/07	Adds requirements for Liquid oxygen storage and use in home care
3002.1	F260-07/08	Provides new requirements regarding the location and connection of 'tube trailers'
3003.2	F208-06/07	Updates Referenced Standards
3003.7.11 through 3003.7.11.2 (New)	F260-07/08	Provides new requirements regarding the location and connection of 'tube trailers'
3006.2	F173-06/07	Clarifies the need to consider high-hard occupancy classification for oxygen use areas
3201.1	F191-06/07,	Expands Chapter 35 to include Flammable Cryogenic Liquids, Adds requirements for hydrogen storage tanks
3203.4.3	F208-06/07	Updates Referenced Standards
3203.8	F208-06/07	Updates Referenced Standards
3204.3	F262-07/08	Updates requirements regarding the location of cryogenic liquid storage
3204.3.1 Deleted .	F262-07/08	Updates requirements regarding the location of cryogenic liquid storage

3204.3.1 3203.6	F262-07/08	Updates requirements regarding the location of cryogenic liquid storage
3204.3.1.1 3203.6.1	F262-07/08	Updates requirements regarding the location of cryogenic liquid storage
3204.3.1.1 Table 3203.6.1 Table	F262-07/08	Updates requirements regarding the location of cryogenic liquid storage
3204.3.1.1.1 3203.6.1.1	F262-07/08	Updates requirements regarding the location of cryogenic liquid storage
3204.3.1.1.2 3203.6.1.2	F262-07/08	Updates requirements regarding the location of cryogenic liquid storage
3204.3.1.1.3 3204.3.1.1	F191-06/07, F262-07/08	Expands Chapter 35 to include Flammable Cryogenic Liquids, Adds requirements for hydrogen storage tanks
3204.3.1.1.4 32304.3.1.2	F262-07/08	Updates requirements regarding the location of cryogenic liquid storage
3204.3.1.1.5 3204.3.1.3	F262-07/08	Updates requirements regarding the location of cryogenic liquid storage
3204.3.1.2 3204.3.2	F262-07/08	Updates requirements regarding the location of cryogenic liquid storage
3204.3.2.1 Deleted .	F262-07/08	Updates requirements regarding the location of cryogenic liquid storage
3204.3.1.2.1 3203.6.2	F262-07/08	Updates requirements regarding the location of cryogenic liquid storage
3204.3.1.2.1 Table 3203.6.2 Table	F262-07/08	Updates requirements regarding the location of cryogenic liquid storage
3204.3.1.2.2 3203.6.2.1	F262-07/08	Updates requirements regarding the location of cryogenic liquid storage
3204.3.1.2.3 3204.3.2.2	F262-07/08	Updates requirements regarding the location of cryogenic liquid storage
3205.3.1	F262-07/08	Updates requirements regarding the location of cryogenic liquid storage
3301.1	F208-06/07	Updates Referenced Standards
3301.1.3	F176-06/07, F208-06/07	Adds the term displays in regarding the use of fireworks, Update to DOT 49CFR requirements
3301.3	F208-06/07	Updates Referenced Standards
3301.8.1(3) Table	F265-07/08	Updates the separation table regarding consumer fireworks
3302.1	F180-06/07, F208-06/07	Editorial change to add the term pyrotechnics to Chapter 33, Update to DOT 49CFR requirements
3304.3 Table	F266-07/08	Updates the separation table regarding consumer fireworks
3304.5.2(3) Table	F267-07/08	Updates the separation table regarding consumer fireworks
3307.4	F179-06/07	Clarifies that daylight hours is between sunrise and sunset
3308.1 through 3308.4	F180-06/07	Editorial change to add the term pyrotechnics to Chapter 33
3308.5.3	F180-06/07	Editorial change to add the term pyrotechnics to Chapter 33
3308.5.4	F180-06/07	Editorial change to add the term pyrotechnics to Chapter 33
3308.5.5	F180-06/07	Editorial change to add the term pyrotechnics to Chapter 33
3308.8	F180-06/07	Editorial change to add the term pyrotechnics to Chapter 33
3308.9	F180-06/07	Editorial change to add the term pyrotechnics to Chapter 33
3308.11 Deleted .	F181-06/07	Removes the requirements of retail display and sale areas for fireworks
3309 (New)	F268-07/08	Updates the separation table regarding consumer fireworks
3403.6.2	F270-07/08	Updated piping referenced standards for flammable and combustible liquids
3403.6.2 Table (New)	F270-07/08	Updated piping referenced standards for flammable and combustible liquids
3403.6.2.1	F270-07/08	Updated piping referenced standards for flammable and combustible liquids
3404.2.3.2	F271-07/08	Requires venting for Class IIIB liquid tanks
3404.2.7.3.3	F271-07/08	Requires venting for Class IIIB liquid tanks
3404.2.7.5.2	F271-07/08, F273-07/08	Requires venting for Class IIIB liquid tanks
3404.2.7.5.6	F273-07/08	Precriptive requirements regarding location of fill pipes of liquids
3404.2.7.5.8	F271-07/08	Requires venting for Class IIIB liquid tanks
3404.2.8.12	F187-06/07	Updates electrical classifications for flammable liquid areas
3404.2.8.17	F187-06/07	Updates electrical classifications for flammable liquid areas
3404.2.9.1 (New)	F188-06/07	Clarifies the fire officials authority for tanks installed in noncompliance with existing requirements
3404.2.9.5 3404.2.9.4	F271-07/08	Requires venting for Class IIIB liquid tanks
3404.2.13.1.4	F274-07/08	Removes the exception for oil tanks under 1,000 gallons to be abandoned in place without fill
3404.2.15 (New)	F275-07/08	Adds requirements for maintenance of aboveground tanks and piping systems
3404.3.3.9	F237-07/08	Updates of reference standards regarding sprinkler protection
3404.3.6.3(1) Table	F276-07/08	Updates reference to NFPA 30 regarding protection of rack storage
3404.3.6.3(2) Table	F276-07/08	Updates reference to NFPA 30 regarding protection of rack storage
3404.3.6.3(3) Table	F276-07/08	Updates reference to NFPA 30 regarding protection of rack storage
3404.3.6.3(4) through 3404.3.6.3(8) Tables	F276-07/08	Updates reference to NFPA 30 regarding protection of rack storage
3405.2.4	F277-07/08	Better defines that Class II and III liquids that are heated are treated similar to Class I liquids
3405.2.5	F278-07/08	Better defines that Class II and III liquids that are heated are treated similar to Class I liquids
3405.5.1	F190-06/07	Allows for the use of certain aerosol based hand rubs
3406.5.1.15	F208-06/07	Updates Referenced Standards
3406.5.4.5	F281-07/08	Adds separation requirements for storm drains
3501.1	F191-06/07, F282-07/08	Expands Chapter 35 to include Flammable Cryogenic Liquids, Adds requirements for hydrogen storage tanks
3502.1	F191-06/07, F194-06/07	Expands Chapter 35 to include Flammable Cryogenic Liquids, Adds requirements for hydrogen storage tanks, Adds requirements for metal hydride storage systems

3503.1.1	F283-07/08, F284-07/08	Prohibits the storage and use of oxidizing and flammable gases in offices, sets additional prohibitions to the exception regarding storage and use
3504.2.1.1 (New)	F287-07/08	Creates new requirements for weather protection of flammable gases
3506 (New)	F191-06/07	Expands Chapter 35 to include Flammable Cryogenic Liquids, Adds requirements for hydrogen storage tanks
3506.1 through 3506.3.2.1 (New)	F191-06/07	Expands Chapter 35 to include Flammable Cryogenic Liquids, Adds requirements for hydrogen storage tanks
3506.4 3204.4	F191-06/07	Expands Chapter 35 to include Flammable Cryogenic Liquids, Adds requirements for hydrogen storage tanks
3506.4.1 3204.4.1	F191-06/07	Expands Chapter 35 to include Flammable Cryogenic Liquids, Adds requirements for hydrogen storage tanks
3506.4.2 3204.4.2	F191-06/07	Expands Chapter 35 to include Flammable Cryogenic Liquids, Adds requirements for hydrogen storage tanks
3506.4.3 3204.4.3	F191-06/07	Expands Chapter 35 to include Flammable Cryogenic Liquids, Adds requirements for hydrogen storage tanks
3506.4.4 3204.4.4	F191-06/07	Expands Chapter 35 to include Flammable Cryogenic Liquids, Adds requirements for hydrogen storage tanks
3506.4.5 3204.4.5	F191-06/07	Expands Chapter 35 to include Flammable Cryogenic Liquids, Adds requirements for hydrogen storage tanks
3205.4.6 3204.4.6	F191-06/07	Expands Chapter 35 to include Flammable Cryogenic Liquids, Adds requirements for hydrogen storage tanks
3506.4.7 3204.4.7	F191-06/07	Expands Chapter 35 to include Flammable Cryogenic Liquids, Adds requirements for hydrogen storage tanks
3506.4.8 3204.5	F191-06/07	Expands Chapter 35 to include Flammable Cryogenic Liquids, Adds requirements for hydrogen storage tanks
3506.4.8.1 3204.5.1	F191-06/07	Expands Chapter 35 to include Flammable Cryogenic Liquids, Adds requirements for hydrogen storage tanks
3506.4.8.2 3204.5.2	F191-06/07	Expands Chapter 35 to include Flammable Cryogenic Liquids, Adds requirements for hydrogen storage tanks
3506.4.8.3 3204.5.3	F191-06/07	Expands Chapter 35 to include Flammable Cryogenic Liquids, Adds requirements for hydrogen storage tanks
3507 (New)	F194-06/07	Adds requirements for metal hydride storage systems
3704.2.2.7	F198-06/07	Removes the exemption for small toxic gas systems for exhaust ventilation requirements
3704.3.4	F289-07/08	Rearranges the compressed gas section regarding outdoor storage
3704.3.4.1 3704.3.2.5	F289-07/08	Rearranges the compressed gas section regarding outdoor storage
3704.3.4.2 3704.3.2.6	F289-07/08	Rearranges the compressed gas section regarding outdoor storage
3704.3.4.3 3704.3.2.7	F289-07/08	Rearranges the compressed gas section regarding outdoor storage
3705.1	F200-06/07	Updates requirements for ozone generators in semiconductor facilities
3801.3	F201-06/07	Specifies the term LP-gas container throughout the code
3802.1	F201-06/07	Specifies the term LP-gas container throughout the code
3803.2.1.2	F201-06/07	Specifies the term LP-gas container throughout the code
3803.2.2	F201-06/07	Specifies the term LP-gas container throughout the code
3804 Title	F201-06/07	Specifies the term LP-gas container throughout the code
3804.2	F201-06/07	Specifies the term LP-gas container throughout the code
3804.3	F201-06/07	Specifies the term LP-gas container throughout the code
3804.3.1	F201-06/07	Specifies the term LP-gas container throughout the code
3804.4	F201-06/07	Specifies the term LP-gas container throughout the code
3806.2	F201-06/07	Specifies the term LP-gas container throughout the code
3806.3	F201-06/07	Specifies the term LP-gas container throughout the code
3807.2	F201-06/07	Specifies the term LP-gas container throughout the code
3808.1	F201-06/07	Specifies the term LP-gas container throughout the code
3809.1 through 3809.6	F201-06/07	Specifies the term LP-gas container throughout the code
3809.8	F201-06/07	Specifies the term LP-gas container throughout the code
3809.10.1	F201-06/07	Specifies the term LP-gas container throughout the code
3809.12	F201-06/07	Specifies the term LP-gas container throughout the code
3809.12 Table	F201-06/07	Specifies the term LP-gas container throughout the code
3809.13	F201-06/07	Specifies the term LP-gas container throughout the code
3810.1	F201-06/07	Specifies the term LP-gas container throughout the code
3810.2	F201-06/07	Specifies the term LP-gas container throughout the code
4001.1	F203-06/07, F290-07/08	Changes the term oxidizer to oxidizing materials
4003.1	F203-06/07	Changes the term oxidizer to oxidizing materials
4003.1.1	F203-06/07	Changes the term oxidizer to oxidizing materials
4003.1.1.3	F283-07/08, F284-07/08	Prohibits the storage and use of oxidizing and flammable gases in offices, sets additional prohibitions to the exception regarding storage and use
4003.2	F203-06/07	Changes the term oxidizer to oxidizing materials
4004.1	F203-06/07	Changes the term oxidizer to oxidizing materials
4004.2	F203-06/07	Changes the term oxidizer to oxidizing materials
4004.2.2	F203-06/07	Changes the term oxidizer to oxidizing materials
4004.2.2.1 (New)	F203-06/07	Changes the term oxidizer to oxidizing materials
4004.2.4	F203-06/07	Changes the term oxidizer to oxidizing materials
4004.2.2 Table	F203-06/07	Changes the term oxidizer to oxidizing materials
4006 (New)	F205-06/07, F290-07/08	Adds requirements for Liquid oxygen storage and use in home care
4104.1	F206-06/07	Removes language in IFC regarding Silane Gas, references CGA referenced standard

4104.2	F206-06/07	Removes language in IFC regarding Silane Gas, references CGA referenced standard
4105.3	F206-06/07	Removes language in IFC regarding Silane Gas, references CGA referenced standard
4106 Deleted .	F206-06/07	Removes language in IFC regarding Silane Gas, references CGA referenced standard
Chapter 45 (New)	F210-06/07	Adds new chapter regarding marinas
4503.7 (New)	F292-07/08	Updated requirements concerning marinas
4504.1	F292-07/08	Updated requirements concerning marinas
4504.2	F292-07/08	Updated requirements concerning marinas
4504.2.1 (New)	F292-07/08	Updated requirements concerning marinas
4504.6 (New)	F292-07/08	Updated requirements concerning marinas
D103.1	F67-07/08	Specifies that shoulders of roads are not permitted to be part of the fire apparatus access road requirements
D103.5	F70-07/08	Adds a referenced standard for electric gate openers and design criteria for automatic gate operation.
D105.1	F67-07/08	Specifies that shoulders of roads are not permitted to be part of the fire apparatus access road requirements