



STATE FIRE PREVENTION AND BUILDING CODE TECHNICAL SUBCOMMITTEE MEETING

PLUMBING MECHANICAL AND FUEL GAS CODE TECHNICAL SUBCOMMITTEE MEETING

Minutes of the October 4, 2012 teleconference meeting of the technical subcommittee reviewing the **2009 & 2012 International Plumbing, Mechanical and Fuel gas Codes** for adoption by New York State.

PRESENT: John Addario
 Peter Campito
 Douglas Page
 Sal Pennelle
 Robert Cordell

Meeting Minutes:

- 1) The meeting was called to order at 1:30 PM with 4 of 7 members present. Members listed were present by teleconference. A quorum was not present.
- 2) The committee members present discussed some of the substantial changes indicated in the chart in regards to the Fuel Gas Code, Items discussed included; Section 308.1 which clarifies that gypsum board is considered combustible material, Section 410.4 Excess Flow Valves, Flashback Arrestors, overall change of the use of the terms "Equipment" and "Appliance", gas piping sentiment trap requirements and underground gas piping penetrations.
- 3) The committee members present were concerned that Flashback arrestors required for hot work using oxygen needs to be verified with the Hot Work Chapter of the Fire Code. John Addario agreed to verify the requirement in the Fire Code.
- 4) The meeting was adjourned at approximately 2:30pm.
- 5) The next meeting is scheduled for Thursday October 11, 2012 at 1:30PM.