



**New York State Thruway Authority**  
**New York State Canal Corporation**



200 Southern Boulevard, Post Office Box 189  
Albany, New York 12201-0189  
[www.thruway.ny.gov](http://www.thruway.ny.gov)  
(518) 436-2700

February 27, 2015

State of New York  
Department of State  
One Commerce Plaza  
99 Washington Avenue  
Albany, NY 12231-0001

Dear Director Piester/Gerard Hathaway:

Pursuant to your letter of February 4 (received in our office February 6) 2015, attached, I provide the following response and year-end report information for my Agency, as requested.

Included with this letter please find the following information in hard copy format, which I am also providing electronically in advance, in PDF format.

- 1) Copy of DBSC, February 4, 2015 letter
- 2) State Agency Annual Report, pages 1 thru 7 with responses
- 3) listing of certified code personnel, manager and coordinators, two pages, satisfies item 1 of report
- 4) list of all construction permits, code compliance certificates, temporary compliance certificates, six pages, defined as "all", CCC, and TCC respectively, satisfies item 2 of report.
- 5) listing of all fire safety inspections for Agency, year 2014, satisfies item 3, 4, and 5 of report.
- 6) listing of all Agency related complaints and disposition of same, satisfies item 6 of report
- 7) items 7, 8 of report addressed within the report itself.

The above listed items should provide sufficient information to satisfy the requirements of 2014 Year-end reporting for the New York State Thruway Authority and Canal Corporation. If additional information or clarification is needed however please do not hesitate to give me a call or send an email to the contact information listed below. Thank you.

Sincerely,

A handwritten signature in black ink that reads "Martin D. Harding".

Martin D. Harding  
Code Compliance Program Manager  
Bureau of Facilities and Code Compliance  
(518) 471-4217  
[Martin.harding@thruway.ny.gov](mailto:Martin.harding@thruway.ny.gov)



STATE OF NEW YORK  
**DEPARTMENT OF STATE**  
ONE COMMERCE PLAZA  
99 WASHINGTON AVENUE  
ALBANY, NY 12231-0001

ANDREW M. CUOMO  
GOVERNOR

CESAR A. PERALES  
SECRETARY OF STATE

February 4, 2015



NYS Thruway Authority and Canal Corporation  
*Attn: Martin Harding, Code Compliance Program Manager*  
Bureau of Facilities and Code Compliance  
200 Southern Blvd.  
Albany, NY 12209

Dear Mr. Harding:

You have been identified to us as the designated code coordinator, for your agency, with responsibility for overall compliance with 19 NYCRR Part 1204. Under these regulations, state agencies are to prepare annual reports of their code administration activities for the preceding calendar year on or before February 1 of each year. Specific requirements for this report are found in Part 1204.14. This letter is to remind you that the annual report on code enforcement activities for the calendar year 2014 for all nonexempt agencies is required to be prepared by February 1, 2015.

A joint New York City-New York State Task Force on building and fire safety in state-owned or leased buildings (The Task Force) was established by Chapter 283 of the Laws of 2010. In their 2012 report to the Governor, the Task Force recommended that the State require the filing of annual reports be posted on the Department of State's website. In accordance with this recommendation and Part 1204.14(f), please submit a PDF format copy of the full 2014 State Agency Annual Report of your agency to me by March 3, 2015. A copy of the 2014 form is available on the Department of State website at: <http://www.dos.ny.gov/DCEA/stateagencies.html>. This Annual Report Form is provided as a courtesy of the Secretary of State of the State of New York to assist State agencies in fulfilling their Annual Report obligations. Use of this Annual Report Form is optional; a State Agency may use this Annual Report Form or a form prepared by the State Agency and containing the information required by 19 NYCRR section 1204.14.)

The report may be submitted by email to [Gerard.Hathaway@dos.ny.gov](mailto:Gerard.Hathaway@dos.ny.gov) or by mail to his attention at the Department of State. If you are no longer your agency's code coordinator, I ask that you forward this request to the designated code coordinator.

If you have any questions, you may contact Gerard Hathaway, Assistant Director for Technical Services, at (518) 474-4073. Thank you for your prompt attention to this matter.

Sincerely,

Ronald Piester, AIA, Director  
Division of Building Standards and Codes

REP/gh

New York State Department of State  
**Division of Building Standards and Codes**  
99 Washington Avenue, Suite 1160  
Albany, NY 12231  
Ph:(518)-474-4073 FAX:(518)-486-4487  
www.dos.ny.us

Print Form

Page 1 of 7

Reporting Year: **2014**

**19 NYCRR PART 1204**  
**UNIFORM CODE: ADMINISTRATION AND ENFORCEMENT BY STATE AGENCIES**  
**STATE AGENCY ANNUAL REPORT**  
Uniform Code Administration and Enforcement

**GENERAL INFORMATION**

Name of State Agency: New York State Thruway Authority and Canal Corporation

Mailing Address 200 Southern Boulevard, Albany, NY 12209

This Report is being submitted by:

Entire Agency  Campus, Region or Division on behalf of the agency's primary code coordinator

If the form is being completed for anything other than the entire agency, please describe the Campus, Region or Division (be specific):

If form is being completed for anything other than the entire agency, has/will form be submitted to Central Agency:

Name of Primary Agency Code Coordinator: Martin D. Harding

Title of Primary Agency Code Coordinator: Code Compliance Program Manager (CCS 1)

Code Official NYDOS Certification #: NY0004356

Phone Number: (518) 471-4217

E-mail Address: martin.harding@thruway.ny.gov

**NUMBER OF BUILDINGS WITHIN CUSTODY OF THIS AGENCY**

1. Total number of buildings within the custody of this State Agency for reporting year **2014**:

2. Total number of buildings within the custody of this State Agency for reporting year **2013**:

**ADDITIONAL INFORMATION/COMMENTS**

Based upon information from four Divisions and Hq.  
-Martin Harding, #NY0004356, Headquarters  
-Paul Foody, #0898-7187B, NY Division  
-David J. Broughel, #0493-7130A, Albany Division  
-Richard Stagnitti, #0794-7181B, Syracuse Division  
-Frederick Harris, #1104-77313, Buffalo Division









**STATE AGENCY ANNUAL REPORT**

Uniform Code Administration and Enforcement

Reporting Year: **2014**

State Agency: Thruway Authority/Canal

8. List all *changes* during the calendar year covered by this Report in the list of the buildings or portions of buildings which the State Agency preparing this Report occupies, uses, maintains, or operates *and* which are within its custody:

- Check here if there were no changes
- Check here if this list is included or continued on attached sheet[s]

<u>Building or Portion of Building</u>	<u>Added to or removed from list</u>
Syracuse Division	
Hazardous Materials Shelters, 12'x12'	
Herkimer Section	Added to list
Verona Section	Added to list
Weedsport Section	Added to list
Manchester Section	Added to list
Electrical Buildings	
Indian Castle	Added to list
Chittenango	Added to list
Clifton Springs	Added to list
New York Division	
M1638, TZ Decon, demolished	Removed from list
M1639, Men's lockerroom, demolished	Removed from list
M1646, TZ welders shop, demolished	Removed from list
M1635, conc block bldg. dockside, demolished	Removed from list
M1644, Bridge painters. locker rm, office, demolished	Removed from list
M1340, Tarrytwn Police barracks, demolished	Removed from list



## UNIFORM CODE: ADMINISTRATION AND ENFORCEMENT BY STATE AGENCIES

**STATE AGENCY ANNUAL REPORT**

## Uniform Code Administration and Enforcement

Reporting Year: **2014****ABOUT THIS FORM**

Each State Agency that has not been granted an exemption under 19 NYCRR Section 1204.15 is required to prepare an annual report that includes the following information:

- (1) the name and address of the State Agency, the name and address of the State Agency's code coordinator, and the name(s) and address(es) of the State Agency's code compliance manager(s), if any;
- (2) a list of all construction permits, code compliance certificates, and temporary approvals for occupancy which were issued or received during the preceding year along with an indication of which permits, certificates and temporary approvals were still valid on the preceding December 31st;
- (3) a list of all fire safety inspections conducted within buildings or structures in the custody of the State Agency;
- (4) a list of all code violations within the State Agency's buildings or structures which were not corrected within 60 days of their discovery;
- (5) a statement of the current status of the violations noted in paragraph (4) and a plan to correct any such violations still uncorrected;
- (6) a list of all code related complaints and their disposition;
- (7) any changes in the list of the buildings or portions of buildings which the State Agency occupies, uses, maintains, or operates *and* which are within its custody; and
- (8) any changes in the list of the buildings or portions of buildings which the State Agency occupies, uses, maintains, or operates and which are (i) within the custody of another State Agency or (ii) subject to code enforcement by the authority responsible for enforcement in the particular municipality where the building is located.

The report must be completed by February 1 of each year, and must include the information pertaining to the preceding calendar year. Each State Agency must notify the Department of State of the Agency's completion of its annual report within 30 days after completion.

This form is provided as a courtesy of the Secretary of State of the State of New York, to assist State Agencies in fulfilling their Annual Report requirements pursuant to 19 NYCRR Part 1204. Use of this form is optional, but may be used to satisfy their Annual Report obligation. State Agencies may instead use other forms, where acceptable to the Secretary of State, to fulfill their Annual Report obligations.



**New York State Thruway Authority**  
**New York State Canal Corporation**



200 Southern Boulevard, Post Office Box 189  
Albany, New York 12201-0189  
[www.thruway.ny.gov](http://www.thruway.ny.gov)  
(518) 436-2700

**New York State Thruway Authority and Canal Corporation**

**200 Southern Boulevard, Albany, NY 12209**

**State Agency Annual Report form 2014**

**Item #1**

---

**Bureau of Facilities and Code Compliance**

**HEADQUARTERS**

Joe Stahl, Director, CEO

Martin Harding, Code Compliance Program Manager (CCS1), CEO, Code Manager

**DIVISIONS**

**New York**

Michael Naccarato, Division Facilities Engineer, CEO

Paul Foody, Code Coordinator, (CCS 1) CEO

Vacant, Building Maintenance Supervisor II, CEO

**Albany**

Dan Meier, Division Facilities Engineer, CEO

David Broughel, Code Coordinator, (CCS 1) CEO

Greg Hermance, Building Maintenance Supervisor II, CEO

**Syracuse**

Kevin Post, Division Facilities Engineer, CEO

Rick Stagnitti, Code Coordinator, (CCS 1) CEO

Barry Oaksford, Building Maintenance Supervisor II, CEO

Buffalo

Sean Carrington, Division Facilities Engineer, CEO

Fred Harris, Code Coordinator, (CCS 1) CEO

Victor Maisonet, Building Maintenance Supervisor II, CEO

\*Additional staff trained at the current Code Compliance Technician level as well.

New York State Thruway Authority and Canal Corporation-2014 Year End Reporting

Construction Permits- all (Question 2 requirement)

Permit No.	Description	Date	Status	Code	Div. Code	Division
CP2014-001	Exit 40 Weedsport	01/06/2014	CCC	CC-CONST	T03	Albany
CP2014-002	Guilberland SA Gas Station ML-152-8-E	01/07/2014	CCC	CC-CONST	T02	Albany
CP2014-003	Pembroke Travel Plaza Gift Shop	01/08/2014	CCC	CC-CONST	T04	Buffalo
CP2014-004	Port Byron Restaurant	01/10/2014	CCC	CC-CONST	T03	Syracuse
CP2014-005	Junius Ponds Restaurant	01/10/2014	CCC	CC-CONST	T03	Syracuse
CP2014-006	Seneca Service Area Restaurant.	01/10/2014	CCC	CC-CONST	T03	Syracuse
CP2014-007	Manchester Section Maintenance VSB	01/10/2014	CCC	CC-CONST	T03	Syracuse
CP2014-008	Clarence Travel Plaza Gift Shop	01/16/2014	CCC	CC-CONST	T04	Buffalo
CP2014-009	Scottsville Travel Plaza Gift Shop	01/16/2014	CCC	CC-CONST	T04	Buffalo
CP2014-010	Erie Canal	01/16/2014	ISSUED	CC-CONST	T03	Syracuse
CP2014-011	Weedsport VSB	01/16/2014	CCC	CC-CONST	T03	Syracuse
CP2014-012	Ardsley-BK fire repairs	01/17/2014	PENDING	CC-CONST	T01	New York
CP2014-013	Warners Service Area	01/21/2014	CCC	CC-CONST	T03	Syracuse
CP2014-014	Warner's Mobile Station	01/22/2014	CCC	CC-CONST	T03	Syracuse
CP2014-015	Tarbel Road, Bridge Offices at M3341	01/28/2014	CCC	CC-CONST	T03	Syracuse
CP2014-016	Pembroke Travel Plaza	02/07/2014	CCC	CC-CONST	T04	Buffalo
CP2014-017	Seneca Service Area Restaurant.	02/07/2014	CCC	CC-CONST	T03	Syracuse
CP2014-018	M1635 TZ/Generator relocation	02/11/2014	CCC	CC-CONST	T01	New York
CP2014-019	exit 10 site lighting / TZC	02/11/2014	ISSUED	CC-CONST	T01	New York
CP2014-020	TZC/bulkhead building(RPZ/meter)	02/11/2014	ISSUED	CC-CONST	T01	New York
CP2014-021	TZC/Temporary conex storage boxes	02/11/2014	ISSUED	CC-CONST	T01	New York
CP2014-022	Chittenango Service Area	02/24/2014	ISSUED	CC-CONST	T03	Syracuse
CP2014-023	Indian Castle Service Area	02/24/2014	ISSUED	CC-CONST	T03	Syracuse
CP2014-024	Clifton Springs Service Area	02/24/2014	ISSUED	CC-CONST	T03	Syracuse
CP2014-025	M2531 Catskill Section Maintenance	02/27/2014	CCC	CC-CONST	T02	Albany
CP2014-026	Mancester Section	02/28/2014	CCC	CC-CONST	T03	Syracuse
CP2014-027	AT&T upgrade at Plattkill tower	02/28/2014	CCC	CC-CONST	T05	New York
CP2014-028	Scottsville Travel Plaza Lehigh	03/03/2014	CCC	CC-CONST	T04	Buffalo
CP2014-029	Schuyler Service Area	03/05/2014	CCC	CC-CONST	T03	Syracuse
CP2014-030	MP 252 to 262	03/11/2014	CCC	CC-CONST	T03	Syracuse
CP2014-031	Interchange 42 Geneva	03/11/2014	CCC	CC-CONST	T03	Syracuse
CP2014-032	Modena/Faber gift shop	03/13/2014	ISSUED	CC-CONST	T05	New York
CP2014-033	Junius Ponds Travel Mart. Upgrades, Refrigeration and lighting.	03/14/2014	CCC	CC-CONST	T03	Syracuse
CP2014-034	MP 109.7 Cell Tower. Catskill.	03/19/2014	ISSUED	CC-CONST	T02	Albany
CP2014-035	Ontario Service Area	03/19/2014	CCC	CC-CONST	T04	Buffalo
CP2014-036	Oswego Canal	03/21/2014	CCC	CC-CONST	T03	Syracuse
CP2014-037	MP B 11 Berkshire Spur.	03/24/2014	ISSUED	CC-CONST	T02	Albany
CP2014-038	MP B 15 Berkshire Spur.	03/24/2014	ISSUED	CC-CONST	T02	Albany
CP2014-039	Ontario Service Area Restaurant	04/01/2014	CCC	CC-CONST	T04	Buffalo
CP2014-040	Erie Barge Canal	04/02/2014	ISSUED	CC-CONST	T02	Albany
CP2014-041	Erie Barge Canal	04/02/2014	ISSUED	CC-CONST	T02	Albany
CP2014-042	Chittenango SA - Fountain Equipment, plumbing, electrical	04/09/2014	CCC	CC-CONST	T03	Syracuse
CP2014-043	Waterloo Interchange Salt Shed Repairs.	04/09/2014	CCC	CC-CONST	T03	Syracuse

CP2014-044	Weedsport Section Salt Shed	04/09/2014	CCC	CC-CONST	Code-Construction Permit	T03	A	CNST	Syracuse
CP2014-045	Office Trailer for CP2013-055 RO Rehab.	04/18/2014	TCC	CC-CONST	Code-Construction Permit	T03	A	CNST	Syracuse
CP2014-046	S3130 Iroquois Blower Building (Installation of roof).	04/18/2014	CCC	CC-CONST	Code-Construction Permit	T03	A	CNST	Syracuse
CP2014-047	T3533 Verona Boiler Replacement.	04/18/2014	FILEONLY	CC-CONST	Code-Construction Permit	T03	A	CNST	Syracuse
CP2014-048	TUB Airconditioner Replacements, T3533 Verona.	04/18/2014	FILEONLY	CC-CONST	Code-Construction Permit	T03	A	CNST	Syracuse
CP2014-049	S3103 Schuyler Restaurant Pitched Roof Project.	04/18/2014	CCC	CC-CONST	Code-Construction Permit	T03	A	CNST	Syracuse
CP2014-050	S3106 Dewitt Restaurant Pitched Roof Replacement.	04/18/2014	CCC	CC-CONST	Code-Construction Permit	T03	A	CNST	Syracuse
CP2014-051	S3107 Warners Restaurant Pitched Roof Replacement.	04/18/2014	CCC	CC-CONST	Code-Construction Permit	T03	A	CNST	Syracuse
CP2014-052	S3108 Port Byron Pitched Roof Replacement.	04/18/2014	CCC	CC-CONST	Code-Construction Permit	T03	A	CNST	Syracuse
CP2014-053	Herkimer Haz Mat Shelter Flood Plain Construction Requirements	04/25/2014	CCC	CC-CONST	Code-Construction Permit	T03	A	CNST	Syracuse
CP2014-054	Syracuse Section Maintenance Tarbel Road Haz Mat Shelter	04/25/2014	FILEONLY	CC-CONST	Code-Construction Permit	T03	A	CNST	Syracuse
CP2014-055	Weedsport Section Haz Mat Shelter	04/25/2014	CCC	CC-CONST	Code-Construction Permit	T03	A	CNST	Syracuse
CP2014-056	Manchester Section Maintenance Haz Mat Shelter	04/25/2014	CCC	CC-CONST	Code-Construction Permit	T03	A	CNST	Syracuse
CP2014-057	HMS/Plattekill TMT storage	05/05/2014	PENDING	CC-CONST	Code-Construction Permit	T05	A	CNST	New York
CP2014-058	Ontario Service Area Garbage Corral	05/13/2014	CCC	CC-CONST	Code-Construction Permit	T04	A	CNST	Buffalo
CP2014-059	Herkimer Tolls canopy lighting & electrical.	05/15/2014	CCC	CC-CONST	Code-Construction Permit	T03	A	CNST	Syracuse
CP2014-060	Verona Tolls Asbestos Abatement by contractor, Mid Atlantic	05/15/2014	CCC	CC-CONST	Code-Construction Permit	T03	A	CNST	Syracuse
CP2014-061	Lock E -10 Flood damage repairs to lockhouse and shed replacement.	05/16/2014	ISSUED	CC-CONST	Code-Construction Permit	C02	A	CNST	Albany
CP2014-062	Geneva Tolls Boiler Replacement.	05/20/2014	CCC	CC-CONST	Code-Construction Permit	T03	A	CNST	Syracuse
CP2014-063	Geneva Tolls Generator Pad & LP Tank installation.	05/20/2014	CCC	CC-CONST	Code-Construction Permit	T03	A	CNST	Syracuse
CP2014-064	Tarrytown welders shop	05/28/2014	PENDING	CC-CONST	Code-Construction Permit	T01	A	CNST	New York
CP2014-065	Tarrytown decon trailer	05/28/2014	PENDING	CC-CONST	Code-Construction Permit	T01	A	CNST	New York
CP2014-066	Tarrytown supervisor/locker	05/28/2014	PENDING	CC-CONST	Code-Construction Permit	T01	A	CNST	New York
CP2014-067	Herkimer Section VSB Insulation, sheathing, electrical, storage racks.	06/04/2014	CCC	CC-CONST	Code-Construction Permit	T03	A	CNST	Syracuse
CP2014-068	Exit 37 Canopy Extension and Wiring.	06/06/2014	FILEONLY	CC-CONST	Code-Construction Permit	T03	A	CNST	Syracuse
CP2014-069	Exit 34 Canastota Sign Electrical Service.	06/06/2014	CCC	CC-CONST	Code-Construction Permit	T03	A	CNST	Syracuse
CP2014-070	Herkimer Section Rail Covered Storage Racks.	06/06/2014	APPROVED	CC-CONST	Code-Construction Permit	T05	A	CNST	New York
CP2014-071	Woodbury chair lift install	06/12/2014	CCC	CC-CONST	Code-Construction Permit	T03	A	CNST	Syracuse
CP2014-072	T3431 Utica Tolls. Lighting Up-grades.	06/16/2014	CCC	CC-CONST	Code-Construction Permit	T03	A	CNST	Syracuse
CP2014-073	T3635 Thomson Rd. Tolls Air Conditioner replacements & lighting	06/16/2014	FILEONLY	CC-CONST	Code-Construction Permit	T03	A	CNST	Syracuse
CP2014-074	T3741 Waterloo Tolls AC Replacements.	06/16/2014	FILEONLY	CC-CONST	Code-Construction Permit	T03	A	CNST	Syracuse
CP2014-075	T3843 Machester Tolls Lighting Up-grades.	06/16/2014	CCC	CC-CONST	Code-Construction Permit	T03	A	CNST	Syracuse
CP2014-076	T3429 Little Falls Generator transfer switch emergency replacement.	06/19/2014	CCC	CC-CONST	Code-Construction Permit	T03	A	CNST	Syracuse
CP2014-077	gas line repair / sloatsburg	06/25/2014	PENDING	CC-CONST	Code-Construction Permit	T05	A	CNST	New York
CP2014-078	Iroquois Restaurant Hershey Ice Cream Concept.	06/27/2014	CCC	CC-CONST	Code-Construction Permit	T03	A	CNST	Syracuse
CP2014-079	M3639 Chittenango Salt Shed Roof Replacement.	07/02/2014	CCC	CC-CONST	Code-Construction Permit	T03	A	CNST	Syracuse
CP2014-080	M3836 Manchester Salt Shed Roof Replacement	07/02/2014	ISSUED	CC-CONST	Code-Construction Permit	T03	A	CNST	Syracuse
CP2014-081	P3203 Junius Ponds State Police Roof Replacement	07/02/2014	FILEONLY	CC-CONST	Code-Construction Permit	T03	A	CNST	Syracuse
CP2014-082	T3739 State Fair Exit and Emergency Lighting.	07/02/2014	FILEONLY	CC-CONST	Code-Construction Permit	T03	A	CNST	Syracuse
CP2014-083	S3143 Oneida SA generator bldg Roof Replacement PO Contract	07/03/2014	CCC	CC-CONST	Code-Construction Permit	T03	A	CNST	Syracuse
CP2014-084	T3635 Exit 35 Roof Replacement by Al's Construction	07/03/2014	CCC	CC-CONST	Code-Construction Permit	T03	A	CNST	Syracuse
CP2014-085	T3636 Svr 1-81 Roof Replacement by PO Contract Al's Construction	07/03/2014	CCC	CC-CONST	Code-Construction Permit	T03	A	CNST	Syracuse
CP2014-086	T3637 Roof Replacement by PO Contract. Al's Construction Naples NY	07/03/2014	CCC	CC-CONST	Code-Construction Permit	T03	A	CNST	Syracuse
CP2014-087	Champlain Barge Canal	07/07/2014	CCC	CC-CONST	Code-Construction Permit	C02	A	CNST	Albany
CP2014-088	AT&T A/C units M1341	07/07/2014	APPROVED	CC-CONST	Code-Construction Permit	T01	A	CNST	New York
CP2014-089	M1632 alterations	07/10/2014	ISSUED	CC-CONST	Code-Construction Permit	T01	A	CNST	New York
CP2014-090	Walden Avenue Tower	07/24/2014	CCC	CC-CONST	Code-Construction Permit	T04	A	CNST	Buffalo

CP2014-091	S2105 Gunderland SA	07/29/2014	FILEONLY	CC-CONST	Code-Construction Permit	T02	A		CNST	Albany
CP2014-092	Roof Replacement Sloatsburgh	07/31/2014	PENDING	CC-CONST	Code-Construction Permit	T01	A		CNST	New York
CP2014-093	Roof Replacement Modena	07/31/2014	PENDING	CC-CONST	Code-Construction Permit	T05	A		CNST	New York
CP2014-094	DeWitt Service Area, McDonald's - AHR Mechanical & Action Crane.	08/07/2014	CCC	CC-CONST	Code-Construction Permit	T03	A		CNST	Syracuse
CP2014-095	T3843 Manchester LED lighting upgrades.	08/07/2014	CCC	CC-CONST	Code-Construction Permit	T03	A		CNST	Syracuse
CP2014-096	T3533 Verona Tolls Electrical Panels Upgrade.	08/14/2014	FILEONLY	CC-CONST	Code-Construction Permit	T03	A		CNST	Syracuse
CP2014-097	Haz-Mat shelter exit 10	08/28/2014	PENDING	CC-CONST	Code-Construction Permit	T01	A		CNST	New York
CP2014-098	M2534 Salt Shed - New Baltimore Service Area MP 127 SB	09/05/2014	CCC	CC-CONST	Code-Construction Permit	T02	A		CNST	Albany
CP2014-099	Port Byron Mc Donald's Renovations 2014. (interior).	09/17/2014	ISSUED	CC-CONST	Code-Construction Permit	T03	A		CNST	Syracuse
CP2014-100	MP 308 east Bound Project TAS 14-11 Parking Lot Site Lighting	09/24/2014	CCC	CC-CONST	Code-Construction Permit	T03	A		CNST	Syracuse
CP2014-101	S3107 Warners SA McDonald's Rehab 2014 McDonald's Corp.	09/25/2014	ISSUED	CC-CONST	Code-Construction Permit	T03	A		CNST	Syracuse
CP2014-102	Seneca SA, Lehigh Mobile Sale Sign Replacement	09/29/2014	ISSUED	CC-CONST	Code-Construction Permit	T03	A		CNST	Syracuse
CP2014-103	demolition / tarrytown HQ	10/01/2014	ISSUED	CC-CONST	Code-Construction Permit	T01	A		CNST	New York
CP2014-104	flood mitigation shelter building	10/01/2014	PENDING	CC-CONST	Code-Construction Permit	T01	A		CNST	New York
CP2014-105	Sloatsburgh Starbucks upgrade	10/02/2014	PENDING	CC-CONST	Code-Construction Permit	T05	A		CNST	New York
CP2014-106	S2103 New Baltimore SA Restaurant Bldg.	10/08/2014	CCC	CC-CONST	Code-Construction Permit	T02	A		CNST	Albany
CP2014-107	S2103 New Baltimore SA Restaurant Bldg.	10/09/2014	CCC	CC-CONST	Code-Construction Permit	T02	A		CNST	Albany
CP2014-108	S2106 Pattersonville SA Restaurant Bldg.	10/09/2014	CCC	CC-CONST	Code-Construction Permit	T02	A		CNST	Albany
CP2014-109	Erie Canal	10/09/2014	PENDING	CC-CONST	Code-Construction Permit	T02	A		CNST	Albany
CP2014-110	MP 212.7 (T-Mobile cabinet and electrical upgrades)	10/13/2014	ISSUED	CC-CONST	Code-Construction Permit	T03	A		CNST	Syracuse
CP2014-111	MP 243 Exit 32 T-Mobile Electrical, fiber cable and cabinet upgrades.	10/22/2014	ISSUED	CC-CONST	Code-Construction Permit	T03	A		CNST	Syracuse
CP2014-112	MP 310 Port Byron SA, T-Mobile upgrades	10/22/2014	ISSUED	CC-CONST	Code-Construction Permit	T03	A		CNST	Syracuse
CP2014-113	M2631 Albany Maintenance.	10/22/2014	FILEONLY	CC-CONST	Code-Construction Permit	T04	A		CNST	Syracuse
CP2014-114	M3736 Waterloo salt Shed electrical service upgrade.	10/31/2014	CCC	CC-CONST	Code-Construction Permit	T02	A		CNST	Albany
CP2014-115	Lock 23	12/03/2014	FILEONLY	CC-CONST	Code-Construction Permit	T03	A		CNST	Syracuse
CP2014-116	Eden Angola Toll Interchange 15197562	12/04/2014	FILEONLY	CC-CONST	Code-Construction Permit	T04	A		CNST	Buffalo
CP2014-117	Dunkirk Interchange (15197458)	12/04/2014	FILEONLY	CC-CONST	Code-Construction Permit	T04	A		CNST	Buffalo
CP2014-118	Ripley Interchange 15197564	12/04/2014	FILEONLY	CC-CONST	Code-Construction Permit	T04	A		CNST	Buffalo
CP2014-119	M3831 Manchester Section, Combustible liquid dispensing system.	12/11/2014	FILEONLY	CC-CONST	Code-Construction Permit	T03	A		CNST	Syracuse
CP2014-120	M3731 Weedsport Section Combustible liquid dispensing system.	12/12/2014	FILEONLY	CC-CONST	Code-Construction Permit	T03	A		CNST	Syracuse
CP2014-121	M3731 Weedsport Section Combustible liquid dispensing system.	12/12/2014	FILEONLY	CC-CONST	Code-Construction Permit	T03	A		CNST	Syracuse
CP2014-122	M3731 Weedsport Section Combustible liquid dispensing system.	12/12/2014	FILEONLY	CC-CONST	Code-Construction Permit	T03	A		CNST	Syracuse
CP2014-123	Ardasley / interior renovations	12/12/2014	PENDING	CC-CONST	Code-Construction Permit	T01	A		CNST	New York
CP2014-124	M3535 Verona Section Maintenance, Combustible oil dispensing system.	12/15/2014	FILEONLY	CC-CONST	Code-Construction Permit	T03	A		CNST	Syracuse
CP2014-125	M3432 Herkimer Section Combustible liquid dispensing system.	12/15/2014	FILEONLY	CC-CONST	Code-Construction Permit	T03	A		CNST	Syracuse
CP2014-126	Ontario Travel Plaza McDonald's	12/11/2014	ISSUED	CC-CONST	Code-Construction Permit	T04	A		CNST	Buffalo
CP2014-127	S3107 Warners Emergency Repair to the dry fire sprinkler system.	12/18/2014	ISSUED	CC-CONST	Code-Construction Permit	T03	A		CNST	Syracuse
CP2014-128	Int.23 Cell Tower Site	12/19/2014	PENDING	CC-CONST	Code-Construction Permit	T02	A		CNST	Albany
CP2014-129	Chittenango Service Area HMS Host cashroom door replacement by HI	12/31/2014	ISSUED	CC-CONST	Code-Construction Permit	T03	A		CNST	Syracuse

\*construction permits not in CCC or TCC status are still open/valid as of December 31.

New York State Thruway Authority and Canal Corporation-2014 Year End Reporting

Construction Permits-Code Compliance Certificates (CCC) (Question 2 requirement)

Permit No.	Description	Date	Status			Div. Code		Division
CP2014-001	Exit 40 Weedsport	01/06/2014	CCC	CC-CONST	Code-Construction Permit	T03	A	Syracuse
CP2014-002	Guilderland SA Gas Station ML-152-8-E	01/07/2014	CCC	CC-CONST	Code-Construction Permit	T02	A	Albany
CP2014-003	Pembroke Travel Plaza Gift Shop	01/08/2014	CCC	CC-CONST	Code-Construction Permit	T04	A	Buffalo
CP2014-004	Port Byron Restaurant	01/10/2014	CCC	CC-CONST	Code-Construction Permit	T03	A	Syracuse
CP2014-005	Junius Ponds Restaurant	01/10/2014	CCC	CC-CONST	Code-Construction Permit	T03	A	Syracuse
CP2014-006	Seneca Service Area Restaurant.	01/10/2014	CCC	CC-CONST	Code-Construction Permit	T03	A	Syracuse
CP2014-007	Manchester Section Maintenance VSB	01/10/2014	CCC	CC-CONST	Code-Construction Permit	T03	A	Syracuse
CP2014-008	Clarence Travel Plaza Gift Shop	01/16/2014	CCC	CC-CONST	Code-Construction Permit	T04	A	Buffalo
CP2014-009	Scottsville Travel Plaza Gift Shop	01/16/2014	CCC	CC-CONST	Code-Construction Permit	T04	A	Buffalo
CP2014-011	Weedsport VSB	01/16/2014	CCC	CC-CONST	Code-Construction Permit	T03	A	Syracuse
CP2014-013	Warners Service Area	01/21/2014	CCC	CC-CONST	Code-Construction Permit	T03	A	Syracuse
CP2014-014	Warner's Mobile Station	01/22/2014	CCC	CC-CONST	Code-Construction Permit	T03	A	Syracuse
CP2014-015	Tarbel Road, Bridge Offices at M3341	01/28/2014	CCC	CC-CONST	Code-Construction Permit	T03	A	Syracuse
CP2014-016	Pembroke Travel Plaza	02/03/2014	CCC	CC-CONST	Code-Construction Permit	T04	A	Buffalo
CP2014-017	Seneca Service Area Restaurant.	02/07/2014	CCC	CC-CONST	Code-Construction Permit	T03	A	Syracuse
CP2014-018	M1635 TZ/Generator relocation	02/11/2014	CCC	CC-CONST	Code-Construction Permit	T01	A	New York
CP2014-025	M2531 Catskill Section Maintenance	02/27/2014	CCC	CC-CONST	Code-Construction Permit	T02	A	Albany
CP2014-026	Manchester Section	02/28/2014	CCC	CC-CONST	Code-Construction Permit	T03	A	Syracuse
CP2014-027	AT&T upgrade at Plattekill tower	02/28/2014	CCC	CC-CONST	Code-Construction Permit	T05	A	New York
CP2014-028	Scottsville Travel Plaza Lehigh	03/03/2014	CCC	CC-CONST	Code-Construction Permit	T04	A	Buffalo
CP2014-029	Schuyler Service Area	03/05/2014	CCC	CC-CONST	Code-Construction Permit	T03	A	Syracuse
CP2014-030	MP 252 to 262	03/11/2014	CCC	CC-CONST	Code-Construction Permit	T03	A	Syracuse
CP2014-031	Interchange 42 Geneva	03/11/2014	CCC	CC-CONST	Code-Construction Permit	T03	A	Syracuse
CP2014-033	Junius Ponds Travel Mart Upgrades, Refrigeration and lighting.	03/14/2014	CCC	CC-CONST	Code-Construction Permit	T03	A	Syracuse
CP2014-035	Ontario Service Area	03/19/2014	CCC	CC-CONST	Code-Construction Permit	T04	A	Buffalo
CP2014-036	Oswego Canal	03/21/2014	CCC	CC-CONST	Code-Construction Permit	C03	A	Syracuse
CP2014-039	Ontario Service Area Restaurant	04/01/2014	CCC	CC-CONST	Code-Construction Permit	T04	A	Buffalo
CP2014-042	Chittenango SA - Fountain Equipment, plumbing, electrical	04/09/2014	CCC	CC-CONST	Code-Construction Permit	T03	A	Syracuse
CP2014-043	Waterloo Interchange Salt Shed Repairs.	04/09/2014	CCC	CC-CONST	Code-Construction Permit	T03	A	Syracuse
CP2014-044	Weedsport Section Salt Shed	04/09/2014	CCC	CC-CONST	Code-Construction Permit	T03	A	Syracuse
CP2014-046	S3130 Iroquois Blower Building (Installation of roof).	04/18/2014	CCC	CC-CONST	Code-Construction Permit	T03	A	Syracuse
CP2014-049	S3103 Schuyler Restaurant Pitched Roof Project.	04/18/2014	CCC	CC-CONST	Code-Construction Permit	T03	A	Syracuse
CP2014-050	S3106 Dewitt Restaurant Flat Roof Replacement.	04/18/2014	CCC	CC-CONST	Code-Construction Permit	T03	A	Syracuse
CP2014-051	S3107 Warners Restaurant Pitched Roof Replacement.	04/18/2014	CCC	CC-CONST	Code-Construction Permit	T03	A	Syracuse
CP2014-052	S3108 Port Byron Pitched Roof Replacement.	04/18/2014	CCC	CC-CONST	Code-Construction Permit	T03	A	Syracuse
CP2014-053	Herkimer Haz Mat Shelter Flood Plain Construction Requirements	04/25/2014	CCC	CC-CONST	Code-Construction Permit	T03	A	Syracuse
CP2014-055	Weedsport Section Haz Mat Shelter	04/25/2014	CCC	CC-CONST	Code-Construction Permit	T03	A	Syracuse
CP2014-056	Manchester Section Maintenance Haz Mat Shelter	04/25/2014	CCC	CC-CONST	Code-Construction Permit	T03	A	Syracuse
CP2014-058	Ontario Service Area Garbage Corral	05/13/2014	CCC	CC-CONST	Code-Construction Permit	T04	A	Buffalo
CP2014-059	Herkimer Tolls canopy lighting & electrical.	05/15/2014	CCC	CC-CONST	Code-Construction Permit	T03	A	Syracuse
CP2014-060	Verona Tolls Asbestos Abatement by contractor, Mid Atlantic	05/15/2014	CCC	CC-CONST	Code-Construction Permit	T03	A	Syracuse
CP2014-062	Geneva Tolls Boiler Replacement.	05/20/2014	CCC	CC-CONST	Code-Construction Permit	T03	A	Syracuse
CP2014-063	Geneva Tolls Generator Pad & LP Tank Installation.	05/20/2014	CCC	CC-CONST	Code-Construction Permit	T03	A	Syracuse

CP2014-067	Herkimer Section VSB Insulation, sheathing, electrical, storage racks.	06/04/2014	CCC	CC-CONST	Code-Construction Permit	T03	A	CNST	Syracuse
CP2014-069	Exit 34 Canastota Sign Electrical Service.	06/06/2014	CCC	CC-CONST	Code-Construction Permit	T03	A	CNST	Syracuse
CP2014-070	Herkimer Section Rail Covered Storage Racks.	06/06/2014	CCC	CC-CONST	Code-Construction Permit	T03	A	CNST	Syracuse
CP2014-072	T3431 Utica Tolls. Lighting Up-grades.	06/16/2014	CCC	CC-CONST	Code-Construction Permit	T03	A	CNST	Syracuse
CP2014-075	T3843 Madhester Tolls Lighting Up-grades.	06/16/2014	CCC	CC-CONST	Code-Construction Permit	T03	A	CNST	Syracuse
CP2014-076	T3429 Little Falls Generator transfer switch emergency replacement.	06/19/2014	CCC	CC-CONST	Code-Construction Permit	T03	A	CNST	Syracuse
CP2014-078	Iroquois Restaurant Hershey Ice Cream Concept.	06/27/2014	CCC	CC-CONST	Code-Construction Permit	T03	A	CNST	Syracuse
CP2014-079	M3639 Chittenango Salt Shed Roof Replacement.	07/02/2014	CCC	CC-CONST	Code-Construction Permit	T03	A	CNST	Syracuse
CP2014-080	M3836 Manchester Salt Shed Roof Replacement	07/02/2014	CCC	CC-CONST	Code-Construction Permit	T03	A	CNST	Syracuse
CP2014-083	S3143 Oneida SA generator bldg Roof Replacement PO Contract	07/03/2014	CCC	CC-CONST	Code-Construction Permit	T03	A	CNST	Syracuse
CP2014-084	T3635 Exit 35 Roof Replacement by Al's Construction	07/03/2014	CCC	CC-CONST	Code-Construction Permit	T03	A	CNST	Syracuse
CP2014-085	T3636 Syr I-81 Roof Replacement by PO Contract Al's Construction	07/03/2014	CCC	CC-CONST	Code-Construction Permit	T03	A	CNST	Syracuse
CP2014-086	T3637 Roof Replacement by PO Contract Al's Construction Napels NY	07/03/2014	CCC	CC-CONST	Code-Construction Permit	T03	A	CNST	Syracuse
CP2014-087	Champlain Barge Canal	07/07/2014	CCC	CC-CONST	Code-Construction Permit	T03	A	CNST	Albany
CP2014-090	Walden Avenue Tower	07/24/2014	CCC	CC-CONST	Code-Construction Permit	T04	A	CNST	Buffalo
CP2014-094	DeWitt Service Area, McDonald's - AHR Mechanical & Action Crane.	08/07/2014	CCC	CC-CONST	Code-Construction Permit	T03	A	CNST	Syracuse
CP2014-095	T3843 Manchester LED lighting upgrades.	08/07/2014	CCC	CC-CONST	Code-Construction Permit	T03	A	CNST	Syracuse
CP2014-098	M2534 Salt Shed - New Baltimore Service Area MP 127 SB	09/05/2014	CCC	CC-CONST	Code-Construction Permit	T02	A	CNST	Albany
CP2014-100	MP 308 east Bound Project TAS 14-11 Parking Lot Site Lighting	09/24/2014	CCC	CC-CONST	Code-Construction Permit	T03	A	CNST	Syracuse
CP2014-106	S2103 New Baltimore SA Restaurant Bldg.	10/08/2014	CCC	CC-CONST	Code-Construction Permit	T02	A	CNST	Albany
CP2014-107	S2103 New Baltimore SA Restaurant Bldg.	10/09/2014	CCC	CC-CONST	Code-Construction Permit	T02	A	CNST	Albany
CP2014-108	S2106 Pattersonville SA Restaurant Bldg.	10/09/2014	CCC	CC-CONST	Code-Construction Permit	T02	A	CNST	Albany
CP2014-115	M2631 Albany Maintenance.	10/31/2014	CCC	CC-CONST	Code-Construction Permit	T02	A	CNST	Albany

\*construction permits not in CCC or TCC status are still open/valid as of December 31.

**New York State Thruway Authority and Canal Corporation-2014 Year End Reporting**

Construction Permits-Code Compliance Certificates (CCC) (Question 2 requirement)

Permit No.	Description	Date	Status	CC-CONST	Code-Construction Permit	Div. Code	A	CNST	Division
CP2014-045	Office Trailer for CP2013-055 RC	04/18/2014	TCC			T03			Syracuse

\*construction permits not in CCC or TCC status are still open/valid as of December 31.

New York State Thruway Authority and Canal Corporation

2014 State Agency Annual Report form

Regarding page 5 of 7, Item #7, Record of Complaints

Division	Date	Building/ Building Number	Description	Disposition
NY	04/20/2014 05/28/2014 09/27/2014 11/08/2014 11/22/2014	S1102 S1105 S1105 M1340 S1102	Fire Alarm Fire Alarm Fire Alarm Fire Alarm Fire Alarm	Closed by Investigation Closed by Investigation Closed by Investigation Closed by Investigation Closed by Investigation
Albany		Port Byron SA Junius Ponds SA Seneca SA Schuyler SA Lock 24 furnace T3533, Verona Boiler T3637,Exit 37, Canopy	None reported	Repaired Repaired Repaired Replaced Replaced Replaced Replaced Repaired Replaced Replaced Replaced Under Review Repaired Repaired
Syracuse		T3429 Generator Transfer Switch Lock, C&S1, Cayuga Water Main S3107, Warners SA Fire Sprinklr. All Service Areas S3107, Warners SA Fire Alarm DeWitt SA	Fire Sprinkler System Fire Sprinkler System Fire Sprinkler System RPZ Replacement Furnace Problem Boiler Problem Canopy Damage Transfer Switch functionality Water Main failure Fire Sprinkler System Display Kiosks blocking egress, Executive Directive Fire Alarm System Fire Alarm System	Repaired Repaired Repaired Replaced Replaced Replaced Repaired Replaced Replaced Replaced Under Review Repaired Repaired
Buffalo			None reported	None reported
HQ			None reported	None reported

<b>New York State Thruway Authority and Canal Corporation</b>
<b>Report of Annual Fire Inspections and Violations-( 2014 )</b>
<b>Compliance Item #5 of report.</b>

Run Date:2/9/2015

<u>Division</u>	<u>Department</u>	<u>Description</u>	<u>Start Date</u>	<u>Number of Viols.</u>	<u>Number of Res. Viols.</u>	<u>Violations</u>
Canal - Albany	Ft Edward	Right Carpenters Storage Shed - Ft Edward	03/27/2014	1	0	1) PM304.2 Protective treatment. All exterior surfaces, including but not limited to, doors, door and w ...
Canal - Albany	Ft Edward	Whitehall Terminal Pavilion	07/02/2014	2	0	1) PM304.2 Protective treatment. All exterior surfaces, including but not limited to, doors, door and w ... 2) PM305.1 General. The interior of a structure and equipment therein shall be maintained in good repai ...
Canal - Albany	Ft Edward	Whitehall Terminal Visitor Center	07/02/2014	16	0	1) PM302.3 Sidewalks and driveways. All sidewalks, walkways, stairs, driveways, parking spaces and simi ... 2) PM304.2 Protective treatment. All exterior surfaces, including but not limited to, doors, door and w ... 3) PM304.2 Protective treatment. All exterior surfaces, including but not limited to, doors, door and w ... 4) F605.1 Abatement of electrical hazards. Identified electrical hazards shall be abated. Identified ha ... 5) PM304.1 General. The exterior of a structure shall be maintained in good repair, structurally sound ... 6) F1011.1 Where required. Exits and exit access doors shall be marked by an approved exit sign readily ... 7) F605.1 Abatement of electrical hazards. Identified electrical hazards shall be abated. Identified ha ... 8) PM504.1 General. All plumbing fixtures shall be properly installed and maintained in working order, ... 9) F605.1 Abatement of electrical hazards. Identified electrical hazards shall be abated. Identified ha ... 10) PM305.1 General. The interior of a structure and equipment therein shall be maintained in good repai ... 11) F605.1 Abatement of electrical hazards. Identified electrical hazards shall be abated. Identified ha ... 12) F3404.3.4.4 Liquids for maintenance and operation of equipment. In all occupancies, quantities of fl ... 13) F605.3.1 Labeling. Doors into electrical control panel rooms shall be marked with a plainly visible ... 14) F605.1 Abatement of electrical hazards. Identified electrical hazards shall be abated. Identified ha ... 15) PM106.1 Maintenance. Equipment, systems, devices and safeguards required by this code or a previous ... 16) F3809.7 Storage in basement, pit or similar location. LP-gas containers shall not be stored in a ba ...
Canal - Albany	Waterford	Boiler Shop Building 27 - Waterford	09/26/2014	1	0	1) PM304.2 Protective treatment. All exterior surfaces, including but not limited to, doors, door and w ...
Canal - Albany	Waterford	Crews Quarters - Waterford	09/26/2014	5	0	1) F1011.2 Illumination. Exit signs shall be internally or externally illuminated. Exception: Tactil ... 2) PM106.2 Existing nonrequired equipment and systems. Whenever or wherever any nonrequired device, equ ... 3) PM305.1 General. The interior of a structure and equipment therein shall be

						maintained in good repair ... 4) F605.6 Unapproved conditions. Open junction boxes and open-wiring splices shall be prohibited. App ... 5) F1011.2 Illumination. Exit signs shall be internally or externally illuminated. Exception: Tactil ...
Canal - Albany	Waterford	Electrical Shop - Waterford	09/26/2014	11	0	1) PM106.1 Maintenance. Equipment, systems, devices and safeguards required by this code or a previous ... 2) PM604.3 Electrical system hazards. Where it is found that the electrical system in a structure const ... 3) PM604.3 Electrical system hazards. Where it is found that the electrical system in a structure const ... 4) F605.6 Unapproved conditions. Open junction boxes and open-wiring splices shall be prohibited. App ... 5) F605.6 Unapproved conditions. Open junction boxes and open-wiring splices shall be prohibited. App ... 6) F605.6 Unapproved conditions. Open junction boxes and open-wiring splices shall be prohibited. Appro ... 7) F605.6 Unapproved conditions. Open junction boxes and open-wiring splices shall be prohibited. App ... 8) F605.6 Unapproved conditions. Open junction boxes and open-wiring splices shall be prohibited. App ... 9) F605.6 Unapproved conditions. Open junction boxes and open-wiring splices shall be prohibited. Appro ... 10) PM304.2 Protective treatment. All exterior surfaces, including but not limited to, doors, door and w ... 11) PM304.6 Exterior walls. All exterior walls shall be free from holes, breaks, and loose or rotting ma ...
Canal - Albany	Waterford	Engineers Office - Waterford	09/26/2014	1	0	1) F901.6 Inspection, testing and maintenance. Fire detection, alarm and extinguishing systems shall be ...
Canal - Albany	Waterford	Long Shed - Waterford Shop - Waterford	09/26/2014	2	0	1) PM304.2 Protective treatment. All exterior surfaces, including but not limited to, doors, door and w ... 2) PM106.1 Maintenance. Equipment, systems, devices and safeguards required by this code or a previous ...
Canal - Albany	Waterford	Lumber Shed - Waterford	09/26/2014	1	0	1) PM304.2 Protective treatment. All exterior surfaces, including but not limited to, doors, door and w ...
Canal - Albany	Waterford	MECHANICS BUILDING - WATERFORD	09/26/2014	3	0	1) PM604.3 Electrical system hazards. Where it is found that the electrical system in a structure const ... 2) PM106.1 Maintenance. Equipment, systems, devices and safeguards required by this code or a previous ... 3) F605.3 Working space and clearance. A working space of not less than 30 inches (762 mm) in width, 36 ...
Canal - Albany	Waterford	Main Building - Waterford	09/26/2014	6	0	1) F1011.2 Illumination. Exit signs shall be internally or externally illuminated. Exception: Tactil ... 2) F605.6 Unapproved conditions. Open junction boxes and open-wiring splices shall be prohibited. Appro ... 3) F1011.2 Illumination. Exit signs shall be internally or externally illuminated. Exception: Tactil ... 4) F1011.2 Illumination. Exit signs shall be internally or externally illuminated. Exception: Tactil ... 5) F1011.2 Illumination. Exit signs shall be internally or externally illuminated. Exception: Tactil ... 6) PM604.3 Electrical system hazards.

						Where it is found that the electrical system in a structure const ...
Canal - Albany	Waterford	Open Garage - Shed 17 - Waterford - Waterford	09/26/2014	2	0	1) PM604.3 Electrical system hazards. Where it is found that the electrical system in a structure const ... 2) F605.6 Unapproved conditions. Open junction boxes and open-wiring splices shall be prohibited. Appro ...
Canal - Albany	Waterford	Paint Shed - Waterford	09/26/2014	0	0	
Canal - Albany	Waterford	Shed - Storage 22 - Waterford - replaces demolished shed 20S075B	09/26/2014	0	0	
Canal - Albany	Waterford	Shed 14 - Waterford Shop - Waterford	09/26/2014	0	0	
Canal - Albany	Waterford	Sheds 1 - 2 - 3 - Waterford Shop - Waterford	09/26/2014	3	0	1) PM106.2 Existing nonrequired equipment and systems. Whenever or wherever any nonrequired device, equ ... 2) PM304.6 Exterior walls. All exterior walls shall be free from holes, breaks, and loose or rotting ma ... 3) PM304.2 Protective treatment. All exterior surfaces, including but not limited to, doors, door and w ...
Canal - Albany	Waterford	Sheds 11 - 12 - 13 - Waterford Shop - Waterford	09/26/2014	0	0	
Canal - Albany	Waterford	Sheds 4 - 5 - Waterford Shop - Waterford	09/26/2014	1	0	1) PM106.1 Maintenance. Equipment, systems, devices and safeguards required by this code or a previous ...
Canal - Albany	Waterford	Transformer Building - Waterford Shop - Waterford	03/07/2014	0	0	
Canal - Albany	Waterford	Transformer Building - Waterford Shop - Waterford	09/26/2014	0	0	
Canal - Albany	Waterford	Waste Shed - Waterford - Waterford	09/26/2014	0	0	
Canal - Albany	Waterford	Water Control Shed - Waterford Shop - Waterford	09/26/2014	0	0	
Canal - Buffalo	Albion	Bottled Gas Storage Building - Albion Shop	08/29/2014	0	0	
Canal - Buffalo	Albion	Bottled Gas Storage Building - Pittsford Shop	09/02/2014	0	0	
Canal - Buffalo	Albion	Carpenters Shop - Lockport	08/25/2014	0	0	
Canal - Buffalo	Albion	Cement & Oil Storage - Hulberton Shop. Murray	08/28/2014	0	0	
Canal - Buffalo	Albion	Fuel Pumps - Albion Shop	08/29/2014	0	0	
Canal - Buffalo	Albion	Garage - Lock E-32 - Pittsford	08/27/2014	1	0	1) F605.1 Abatement of electrical hazards. Identified electrical hazards shall be abated. Identified ha ...
Canal - Buffalo	Albion	Garage - Lock E-33 - Henrietta or Brighton	08/27/2014	0	0	
Canal - Buffalo	Albion	Gas Pumps - Lockport	08/25/2014	1	0	1) F3404.2.3 Labeling and signs. Labeling and signs for storage tanks and storage tank areas shall comp ...
Canal - Buffalo	Albion	Gas Pumps - Pittsford	09/02/2014	1	0	1) F3404.2.3 Labeling and signs. Labeling and signs for storage tanks and storage tank areas shall comp ...
Canal - Buffalo	Albion	Lock Office - Lock E-35 - Lockport	08/25/2014	0	0	
Canal - Buffalo	Albion	Lube House - Lower Terminal - Lockport	08/25/2014	0	0	
Canal - Buffalo	Albion	Machine Shop - Albion	08/29/2014	1	0	1) F605.1 Abatement of electrical hazards. Identified electrical hazards shall be abated. Identified ha ...
Canal - Buffalo	Albion	Maintenance Shop - Albion	08/29/2014	2	0	1) F605.1 Abatement of electrical hazards. Identified electrical hazards shall be abated. Identified ha ... 2) F605.5 Extension cords. Extension cords and flexible cords shall not be a substitute for permanent w ...
Canal - Buffalo	Albion	Maintenance Shop - Pittsford	09/02/2014	12	0	1) F605.3.1 Labeling. Doors into electrical control panel rooms shall be marked with a plainly visible ... 2) F605.6 Unapproved conditions. Open junction boxes and open-wiring splices shall be prohibited. App ...

						<p>3) F605.1 Abatement of electrical hazards. Identified electrical hazards shall be abated. Identified ha ...</p> <p>4) F605.6 Unapproved conditions. Open junction boxes and open-wiring splices shall be prohibited. App ...</p> <p>5) F605.1 Abatement of electrical hazards. Identified electrical hazards shall be abated. Identified ha ...</p> <p>6) F605.6 Unapproved conditions. Open junction boxes and open-wiring splices shall be prohibited. App ...</p> <p>7) F605.6 Unapproved conditions. Open junction boxes and open-wiring splices shall be prohibited. App ...</p> <p>8) F605.1 Abatement of electrical hazards. Identified electrical hazards shall be abated. Identified ha ...</p> <p>9) F605.3.1 Labeling. Doors into electrical control panel rooms shall be marked with a plainly visible ...</p> <p>10) F605.1 Abatement of electrical hazards. Identified electrical hazards shall be abated. Identified ha ...</p> <p>11) F605.6 Unapproved conditions. Open junction boxes and open-wiring splices shall be prohibited. App ...</p> <p>12) F605.1 Abatement of electrical hazards. Identified electrical hazards shall be abated. Identified ha ...</p>
Canal - Buffalo	Albion	Mechanics Building - Lockport	09/08/2014	0	0	
Canal - Buffalo	Albion	Mower Shed - Lockport	08/25/2014	0	0	
Canal - Buffalo	Albion	Office - Lock E-32 - Pittsford	08/27/2014	0	0	
Canal - Buffalo	Albion	Office - Lock E-33 - Henrietta	08/27/2014	2	0	<p>1) B.C.1106.1 PARKING AND PASSENGER LOADING FACILITIES Required. Where parking is provided, accessible ...</p> <p>2) F1011.2 Illumination. Exit signs shall be internally or externally illuminated. Exception: Tactil ...</p>
Canal - Buffalo	Albion	Operating House 1 - Court Street Dam - Rochester	08/28/2014	5	0	<p>1) F605.1 Abatement of electrical hazards. Identified electrical hazards shall be abated. Identified ha ...</p> <p>2) Confined space labeling. ...</p> <p>3) F610.6 Equipment. Carbon monoxide alarms shall be listed and labeled as complying with UL 2034 or C ...</p> <p>4) F907.20 Inspection, testing and maintenance. The maintenance and testing schedules and procedures fo ...</p> <p>5) F605.3 Working space and clearance. A working space of not less than 30 inches (762 mm) in width, 36 ...</p>
Canal - Buffalo	Albion	Operating House 2 - Court Street Dam - Rochester	08/28/2014	1	0	<p>1) F1003.6 Means of egress continuity. The path of egress travel along a means of egress shall not be i ...</p>
Canal - Buffalo	Albion	Orleans County Storehouse - Murray	08/28/2014	3	0	<p>1) F901.6 Inspection, testing and maintenance. Fire detection, alarm and extinguishing systems shall be ...</p> <p>2) F605.1 Abatement of electrical hazards. Identified electrical hazards shall be abated. Identified ha ...</p> <p>3) PM304.6 Exterior walls. All exterior walls shall be free from holes, breaks, and loose or rotting ma ...</p>
Canal - Buffalo	Albion	Powerhouse - Locks E-34 & E-35 - Lockport	08/25/2014	0	0	
Canal - Buffalo	Albion	Quonset Shed - Pittsford	09/02/2014	3	0	<p>1) F605.6 Unapproved conditions. Open junction boxes and open-wiring splices shall be prohibited. App ...</p> <p>2) F605.3.1 Labeling. Doors into electrical control panel rooms shall be marked with a plainly visible ...</p> <p>3) F605.3 Working space and clearance. A working space of not less than 30 inches (762 mm) in width, 36 ...</p>

Canal - Buffalo	Albion	Sandblasting Building - Lockport	08/25/2014	0	0	
Canal - Buffalo	Albion	Section Office - Albion	08/29/2014	1	0	1) PM304.4 Structural members. All structural members shall be maintained free from deterioration, and ...
Canal - Buffalo	Albion	Shed - Hulberton Shop - Murray	08/28/2014	0	0	
Canal - Buffalo	Albion	Shop & Office - Locks E-34 & E-35 - Lockport	08/25/2014	1	0	1) F1008.1.8.4 Bolt locks. Manually operated flush bolts or surface bolts are not permitted. Except ...
Canal - Buffalo	Albion	Shop - Lockport	08/25/2014	2	0	1) 605.5.2 Ampacity. The ampacity of the extension cords shall not be less than the rated capacity of ... 2) F605.5 Extension cords. Extension cords and flexible cords shall not be a substitute for permanent w ...
Canal - Buffalo	Albion	Steel Bar Shed - Lockport	08/25/2014	0	0	
Canal - Buffalo	Albion	Steel Storage Building - Albion	08/29/2014	0	0	
Canal - Buffalo	Albion	Storage Shed - Pittsford Shop	09/02/2014	1	0	1) F605.3 Working space and clearance. A working space of not less than 30 inches (762 mm) in width, 36 ...
Canal - Buffalo	Albion	Store House - Lockport	08/25/2014	0	0	
Canal - Buffalo	Albion	Store House - Locks E-34 & E-35 - Lockport	08/25/2014	0	0	
Canal - Buffalo	Albion	Tower - Park Avenue Lift Bridge - Brockport	08/28/2014	2	0	1) PM304.7 Roofs and drainage. The roof and flashing shall be sound, tight and not have defects that ad ... 2) F605.1 Abatement of electrical hazards. Identified electrical hazards shall be abated. Identified ha ...
Canal - Buffalo	Albion	Tower - Adams Basin Lift Bridge - Ogden	08/28/2014	1	0	1) Confined space not labeled. ...
Canal - Buffalo	Albion	Tower - Bridge E-230 - Lockport	08/26/2014	1	1	1) Confined space not labeled. ...
Canal - Buffalo	Albion	Tower - Eagle Harbor Lift Bridge - Albion	08/26/2014	3	0	1) PM304.2 Protective treatment. All exterior surfaces, including but not limited to, doors, door and w ... 2) PM304.1 General. The exterior of a structure shall be maintained in good repair, structurally sound ... 3) Confined space not labeled. ...
Canal - Buffalo	Albion	Tower - Fairport Lift Bridge - Fairport	08/27/2014	1	0	1) F901.6 Inspection, testing and maintenance. Fire detection, alarm and extinguishing systems shall be ...
Canal - Buffalo	Albion	Tower - Ingersoll Street Lift Bridge - Albion	08/26/2014	1	0	1) Confined spaces not labeled. ...
Canal - Buffalo	Albion	Tower - Knowlesville Lift Bridge - Ridgeway	08/26/2014	2	0	1) Confined space not labeled. ... 2) F605.4.3 Installation. Relocatable power tap cords shall not extend through walls, ceilings, floors ...
Canal - Buffalo	Albion	Tower - Lift Bridge - Holley	08/28/2014	1	0	1) Confined space not labeled. ...
Canal - Buffalo	Albion	Tower - Lift Bridge - Murray (Hulberton)	08/28/2014	1	0	1) Confined space not labeled. ...
Canal - Buffalo	Albion	Tower - Main Street Lift Bridge - Albion	08/26/2014	1	0	1) Confined space not labeled. ...
Canal - Buffalo	Albion	Tower - Main Street Lift Bridge - Brockport	08/28/2014	2	0	1) Confined space not labeled. ... 2) B.C.1106.1 PARKING AND PASSENGER LOADING FACILITIES Required. Where parking is provided, accessible ...
Canal - Buffalo	Albion	Tower - Prospect Street Lift Bridge - Medina	08/26/2014	4	0	1) Confined space not labeled. ... 2) PM302.3 Sidewalks and driveways. All sidewalks, walkways, stairs, driveways, parking spaces and simi ... 3) F1008.1.8.4 Bolt locks. Manually operated flush bolts or surface bolts are not permitted. ... 4) B.C.1106.1.1 Access aisles. Accessible parking spaces shall be in conformance with ICC/ANSI A117.1 e ...
Canal - Buffalo	Albion	Tower Control Building - Bridge E-216 - Middleport	08/26/2014	2	0	1) Confined space not labeled. ... 2) F605.1 Abatement of electrical hazards. Identified electrical hazards shall be abated. Identified ha ...

Canal - Buffalo	Albion	Tower Control Building - Bridge E-222 - Royalton (Gasport)	08/26/2014	2	0	1) Confined space not labeled. ... 2) F605.1 Abatement of electrical hazards. Identified electrical hazards shall be abated. Identified ha ...
Canal - Buffalo	Albion	Tower Control Building - Spencerport Lift Bridge - Spencerport	08/28/2014	2	0	1) Confined space not labeled. ... 2) B.C.1106.1 PARKING AND PASSENGER LOADING FACILITIES Required. Where parking is provided, accessible ...
Canal - Buffalo	Albion	Tractor Shed - Lockport	08/25/2014	0	0	
Canal - Buffalo	Albion	Warehouse - Albion	08/29/2014	2	0	1) F605.1 Abatement of electrical hazards. Identified electrical hazards shall be abated. Identified ha ... 2) F605.1 Abatement of electrical hazards. Identified electrical hazards shall be abated. Identified ha ...
Canal - Buffalo	Albion	Warehouse - Lockport	08/25/2014	2	0	1) PM304.6 Exterior walls. All exterior walls shall be free from holes, breaks, and loose or rotting ma ... 2) PM304.7 Roofs and drainage. The roof and flashing shall be sound, tight and not have defects that ad ...
Canal - Syracuse	Lyons	Carpenter Shop - Lyons	08/26/2014	0	0	
Canal - Syracuse	Lyons	Concrete Block Garage - Lyons	08/26/2014	0	0	
Canal - Syracuse	Lyons	Frame Garage - Lyons	08/26/2014	0	0	
Canal - Syracuse	Lyons	Frame Shed - Lyons	08/26/2014	1	0	1) §F906.2 General requirements. Portable fire extinguishers shall be selected, installed and maintain ...
Canal - Syracuse	Lyons	Main Shop - Lyons	08/26/2014	0	0	
Canal - Syracuse	Lyons	Mechanics Storage Shed - Lyons	08/26/2014	0	0	
Canal - Syracuse	Lyons	Section Office - Lyons	08/26/2014	0	0	
Canal - Syracuse	Lyons	Steel Garage - Lyons	08/26/2014	1	0	1) §F906.2 General requirements. Portable fire extinguishers shall be selected, installed and maintain ...
Canal - Syracuse	Lyons	Steel Shed - Lyons	08/26/2014	0	0	
Canal - Syracuse	Lysander	Bridge House - Lock O-1 - Phoenix	07/31/2014	0	0	
Canal - Syracuse	Lysander	Buoy Tender Building - Lock O-2 - Fulton	09/15/2014	0	0	
Canal - Syracuse	Lysander	Lockhouse - Lock E-23 - Clay	07/30/2014	1	0	1) Title 19 Part 1204 NYCRR#9 Requires a construction permit for structures that are built on State Own ...
Canal - Syracuse	Lysander	Lockhouse - Lock E-23 - Clay	07/31/2014	1	0	1) §F906.2 General requirements. Portable fire extinguishers shall be selected, installed and maintain ...
Canal - Syracuse	Lysander	Lockhouse - Lock O-1 - Phoenix	07/31/2014	0	0	
Canal - Syracuse	Lysander	Lockhouse - Lock O-2 - Fulton	09/15/2014	0	0	
Canal - Syracuse	Lysander	Lockhouse - Lock O-3 - Fulton	09/15/2014	0	0	
Canal - Syracuse	Lysander	Lockhouse - Lock O-5 - Minetto	09/15/2014	1	0	1) §P504.6.1 Discharge. The relief valve shall discharge full size to a safe place of disposal such as ...
Canal - Syracuse	Lysander	Lockhouse - Lock O-6	09/15/2014	1	0	1) Required to have proper lables and markings. ...
Canal - Syracuse	Lysander	Lockhouse - Lock O-7	09/15/2014	1	0	1) F605.4 Multiplug adaptors. Multiplug adaptors, such as cube adaptors, unfused plug strips or any oth ...
Canal - Syracuse	Lysander	Lockhouse - Lock O-8	09/15/2014	6	0	1) F605.4 Multiplug adaptors. Multiplug adaptors, such as cube adaptors, unfused plug strips or any oth ... 2) F906.9 Height above floor. Portable fire extinguishers having a gross weight not exceeding 40 pounds ... 3) PM505.4 Water heating facilities. Water heating facilities shall be properly installed, maintained a ... 4) PM604.3 Electrical system hazards. Where it is found that the electrical system in

						a structure const ... 5) PM505.4 Water heating facilities. Water heating facilities shall be properly installed, maintained a ... 6) F605.1 Abatement of electrical hazards. Identified electrical hazards shall be abated. Identified ha ...
Canal - Syracuse	Lysander	Maintenance Facility - Solar Street- Syracuse	07/31/2014	7	0	1) PM Maintain the condition of the fuel tanks. ... 2) PM304.1 Waste accumulation prohibited. Combustible waste material creating a fire hazard shall not ... 3) §PM704.1 General. All systems, devices and equipment to detect a fire, actuate an alarm, or suppress ... 4) §F1011.3 Obstructions. A means of egress shall be free from obstructions that would prevent its use, ... 5) §F605.3 Working space and clearance. A working space of not less than 30 inches (762 mm) in width, 3 ... 6) §F906.2 General requirements. Portable fire extinguishers shall be selected, installed and maintain ... 7) §F906.1 Where required. Portable fire extinguishers shall be installed in the following locations. ...
Canal - Syracuse	Lysander	Pavilion - Village of Phoenix - Phoenix	07/31/2014	1	0	1) Part 1204 Title 19 of NYCRR#9 Executive Law requires a construction permit for the replacement of th ...
Canal - Syracuse	Lysander	Powerhouse - Lock E-23 - Clay	07/31/2014	1	0	1) §F906.2 General requirements. Portable fire extinguishers shall be selected, installed and maintain ...
Canal - Syracuse	Lysander	Powerhouse - Lock O-5 - Minetto	09/15/2014	0	0	
Canal - Syracuse	Lysander	Storage Building - Minetto	09/15/2014	0	0	
Canal - Syracuse	Lysander	Storage Bulding - Lock O-6	09/15/2014	0	0	
Canal - Syracuse	Lysander	Storage Shed - Lock E-23 - Clay	07/31/2014	1	0	1) §F906.2 General requirements. Portable fire extinguishers shall be selected, installed and maintain ...
Canal - Syracuse	Lysander	Storage Shed - Lock O-1 - Phoenix	07/31/2014	0	0	
Canal - Syracuse	Lysander	Storage Shed - Lock O-7	09/15/2014	0	0	
Canal - Syracuse	Lysander	Storage Shed - Lock O-8	09/15/2014	0	0	
Canal - Syracuse	Utica	Carpenter Shop - Utica Terminal - Utica	07/30/2014	3	0	1) FC3404.3.4.4 Liquids for maintenance and operation of equipment. In all occupancies, quantities of ... 2) §F605.6 Unapproved conditions. Open junction boxes and open-wiring splices shall be prohibited. App ... 3) §P504.6.1 Discharge. The relief valve shall discharge full size to a safe place of disposal such as ...
Canal - Syracuse	Utica	Garage - Lock E-19 - Schuyler	09/08/2014	1	0	1) Fire code requires an 18 inch clearance off the floor for furnaces subject to gasoline vapors. ...
Canal - Syracuse	Utica	Garage - Utica Terminal - Utica	07/30/2014	4	0	1) 3404.1 General. The storage of flammable and combustible liquids in containers and tanks shall be i ... 2) §F605.6 Unapproved conditions. Open junction boxes and open-wiring splices shall be prohibited. A ... 3) FC3404.3.4.4 Liquids for maintenance and operation of equipment. In all occupancies, quantities of ... 4) 3503.1.2 Storage containers. Cylinders and pressure vessels for flammable gases shall be designed, ...
Canal - Syracuse	Utica	Light House - Sylvan Beach - Verona	09/10/2014	2	0	1) PM304.6 Exterior walls. All exterior walls shall be free from holes, breaks, and loose or rotting m ... 2) 312.3 Other barriers. Physical barriers shall be a minimum of 36 inches (914 mm) in height and shal ...

Canal - Syracuse	Utica	Office & Shop - Lock E-18 - German Flatts	09/08/2014	1	0	1) PM604.3 Electrical system hazards. Where it is found that the electrical system in a structure con ...
Canal - Syracuse	Utica	Office & Shop - Lock E-19 - Schuyler	09/08/2014	0	0	
Canal - Syracuse	Utica	Office & Shop - Lock E-21 - Verona	07/30/2014	1	0	1) No lock on the fill cap. ...
Canal - Syracuse	Utica	Office & Shop - Lock E-22 - Verona	09/10/2014	4	0	1) PM305.4 Stairs and walking surfaces. Every stair, ramp, landing, balcony, porch, deck or other walk ... 2) 3404.1 General. The storage of flammable and combustible liquids in containers and tanks shall be i ... 3) §P504.6.1 Discharge. The relief valve shall discharge full size to a safe place of disposal such as ... 4) NO CONFINED SPACE SIGNS. ...
Canal - Syracuse	Utica	Office & Shop - Utica Terminal - Utica	07/30/2014	1	0	1) PM Tank Maintenance. Secondary containment shall be maintained. ...
Canal - Syracuse	Utica	Office & Shop - Utica Terminal - Utica	07/30/2014	2	0	1) §F605.3 Working space and clearance. A working space of not less than 30 inches (762 mm) in width, 3 ... 2) 3404.1 General. The storage of flammable and combustible liquids in containers and tanks shall be i ...
Canal - Syracuse	Utica	Office & Shop. Lock E-20 - Marcy	07/30/2014	0	0	
Canal - Syracuse	Utica	Office & Shop. Lock E-20 - Marcy	07/30/2014	4	0	1) Fill cap not locked. ... 2) Maintan fuel tank. ... 3) Eye wash is not being visually inspected weekly. ... 4) Maintain stair way. ...
Canal - Syracuse	Utica	Oil House - Utica Terminal - Utica	07/30/2014	1	0	1) §F906.2 General requirements. Portable fire extinguishers shall be selected, installed and maintain ...
Canal - Syracuse	Utica	Pole Barn - Utica Terminal - Utica	07/30/2014	1	0	1) §F1011.3 Obstructions. A means of egress shall be free from obstructions that would prevent its use, ...
Canal - Syracuse	Utica	Powerhouse - Lock E-18 - Little Falls	09/08/2014	0	0	
Canal - Syracuse	Utica	Powerhouse - Lock E-20 - Marcy	07/30/2014	1	0	1) Maintain tank and lock fill cap. ...
Canal - Syracuse	Utica	Powerhouse - Lock E-21 - Verona	07/30/2014	1	0	1) No lock on fill cap. ...
Canal - Syracuse	Utica	State House - Delta Reservoir - Rome	11/21/2014	24	0	1) §F603.6 Chimneys and appliances. Chimneys, incinerators, smokestacks or similar devices for conveyin ... 2) §F1011.3 Obstructions. A means of egress shall be free from obstructions that would prevent its use, ... 3) §F605.1 Abatement of electrical hazards. Identified electrical hazards shall be abated. Identified ... 4) §P504.6.1 Discharge. The relief valve shall discharge full size to a safe place of disposal such a ... 5) 305.1 General. The interior of a structure and equipment therein shall be maintained in good repair ... 6) 306.1 General. Every exterior and interior flight of stairs having more than four risers shall ... 7) 106.1 Maintenance. Equipment, systems, devices and safeguards required by this code or a previo ... 8) 305.2 Structural members. All structural members shall be maintained structurally sound, and be cap ... 9) 502.1 Dwelling units. Every dwelling unit shall contain its own bathtub or shower, lavatory, water ... 10) §F605.1 Abatement of electrical hazards. Identified electrical hazards shall be abated. Identified ... 11) 502.1 Dwelling units. Every dwelling unit shall contain its own bathtub or shower, lavatory, water ... 12) 502.1 Dwelling units. Every dwelling unit

						<p>shall contain its own bathtub or shower, lavatory, water ...</p> <p>13) 306.1 General. Every exterior and interior flight of stairs having more than four risers shall hav ...</p> <p>14) F605.1 Abatement of electrical hazards. Identified electrical hazards shall be abated. Identified ha ...</p> <p>15) 306.1 General. Every exterior and interior flight of stairs having more than four risers shall hav ...</p> <p>16) F605.1 Abatement of electrical hazards. Identified electrical hazards shall be abated. Identified ha ...</p> <p>17) 304.7 Roofs and drainage. The roof and flashing shall be sound, tight and not have defects that adm ...</p> <p>18) 304.11 Chimneys and towers. All chimneys, cooling towers, smoke stacks, and similar appurtenances s ...</p> <p>19) F605.1 Abatement of electrical hazards. Identified electrical hazards shall be abated. Identified ha ...</p> <p>20) 304.6 Exterior walls. All exterior walls shall be free from holes, breaks, and loose or rotting mat ...</p> <p>21) 304.6 Exterior walls. All exterior walls shall be free from holes, breaks, and loose or rotting mat ...</p> <p>22) 304.7 Roofs and drainage. The roof and flashing shall be sound, tight and not have defects that adm ...</p> <p>23) 304.4 Structural members. All structural members shall be maintained free from deterioration, and s ...</p> <p>24) The exterior was covered with about 6 inches of fresh snow that made it unvisable. The first floor ...</p>
Canal - Syracuse	Utica	Storage House - Utica Terminal - Utica	07/30/2014	1	0	1) §F605.6 Unapproved conditions. Open junction boxes and open-wiring splices shall be prohibited. App ...
Canal - Syracuse	Utica	Tool Shed - Lock E-22 - Verona	09/10/2014	0	0	
Canal - Syracuse	Utica	Tool Shed - Utica Terminal - Utica	07/30/2014	1	0	1) 3404.1 General. The storage of flammable and combustible liquids in containers and tanks shall be i ...
Canal - Syracuse	Utica	Toolshed - Lock E-18 - German Flatts	09/08/2014	1	0	1) PM604.3 Electrical system hazards. Where it is found that the electrical system in a structure con ...
Facilities - Albany	Malden Fac	S2101 Ulster - restaurant	09/18/2014	16	0	<p>1) F901.6 Inspection, testing and maintenance. Fire detection, alarm and extinguishing systems shall be ...</p> <p>2) PM604.3 Electrical system hazards. Where it is found that the electrical system in a structure const ...</p> <p>3) PM604.3 Electrical system hazards. Where it is found that the electrical system in a structure const ...</p> <p>4) F703.2.3 Door operation. Swinging fire doors shall close from the full-open position and latch autom ...</p> <p>5) F901.6 Inspection, testing and maintenance. Fire detection, alarm and extinguishing systems shall be ...</p> <p>6) PM106.1 Maintenance. Equipment, systems, devices and safeguards required by this code or a previous ...</p> <p>7) F605.4 Multiplug adapters. Multiplug adaptors, such as cube adaptors, unfused plug strips or any oth ...</p> <p>8) PM106.1 Maintenance. Equipment, systems, devices and safeguards required by this code or a previous ...</p> <p>9) F703.2.3 Door operation. Swinging fire doors shall close from the full-open position and latch autom ...</p> <p>10) PM305.1 General. The interior of a structure and equipment therein shall be maintained in good repai ...</p>

						<p>11) F605.1 Abatement of electrical hazards. Identified electrical hazards shall be abated. Identified ha ...</p> <p>12) F703.2.3 Door operation. Swinging fire doors shall close from the full-open position and latch autom ...</p> <p>13) PM106.1 Maintenance. Equipment, systems, devices and safeguards required by this code or a previous ...</p> <p>14) PM106.1 Maintenance. Equipment, systems, devices and safeguards required by this code or a previous ...</p> <p>15) PM604.3 Electrical system hazards. Where it is found that the electrical system in a structure const ...</p> <p>16) PM604.3 Electrical system hazards. Where it is found that the electrical system in a structure const ...</p>
Facilities - Albany	Malden Fac	S2102 Malden - restaurant	09/17/2014	13	0	<p>1) F605.1 Abatement of electrical hazards. Identified electrical hazards shall be abated. Identified ha ...</p> <p>2) PM505.4 Water heating facilities. Water heating facilities shall be properly installed, maintained a ...</p> <p>3) F901.6 Inspection, testing and maintenance. Fire detection, alarm and extinguishing systems shall be ...</p> <p>4) F605.5 Extension cords. Extension cords and flexible cords shall not be a substitute for permanent w ...</p> <p>5) PM106.1 Maintenance. Equipment, systems, devices and safeguards required by this code or a previous ...</p> <p>6) PM106.1 Maintenance. Equipment, systems, devices and safeguards required by this code or a previous ...</p> <p>7) PM504.1 General. All plumbing fixtures shall be properly installed and maintained in working order, ...</p> <p>8) F703.2.3 Door operation. Swinging fire doors shall close from the full-open position and latch autom ...</p> <p>9) PM106.1 Maintenance. Equipment, systems, devices and safeguards required by this code or a previous ...</p> <p>10) F605.4 Multiplug adapters. Multiplug adaptors, such as cube adaptors, unfused plug strips or any oth ...</p> <p>11) 1008.1.9 Panic and fire exit hardware. (2) The maximum unlatching force shall not exceed 15 pounds ...</p> <p>12) PM304.2 Protective treatment. All exterior surfaces, including but not limited to, doors, door and w ...</p> <p>13) F901.6.2 Records. Records of all system inspections, tests, and maintenance required by the referenc ...</p>
Facilities - Albany	Malden Fac	S2103 New Baltimore - restaurant	09/09/2014	24	0	<p>1) PM106.1 Maintenance. Equipment, systems, devices and safeguards required by this code or a previous ...</p> <p>2) PM305.1 General. The interior of a structure and equipment therein shall be maintained in good repai ...</p> <p>3) PM305.1 General. The interior of a structure and equipment therein shall be maintained in good repai ...</p> <p>4) PM504.1 General. All plumbing fixtures shall be properly installed and maintained in working order, ...</p> <p>5) PM305.1 General. The interior of a structure and equipment therein shall be maintained in good repai ...</p> <p>6) PM504.1 General. All plumbing fixtures shall be properly installed and maintained in working order, ...</p> <p>7) PM305.1 General. The interior of a structure and equipment therein shall be maintained in good repai ...</p> <p>8) PM305.1 General. The interior of a</p>

						<p>structure and equipment therein shall be maintained in good repair ...</p> <p>9) PM305.1 General. The interior of a structure and equipment therein shall be maintained in good repair ...</p> <p>10) PM305.1 General. The interior of a structure and equipment therein shall be maintained in good repair ...</p> <p>11) PM305.1 General. The interior of a structure and equipment therein shall be maintained in good repair ...</p> <p>12) PM305.1 General. The interior of a structure and equipment therein shall be maintained in good repair ...</p> <p>13) F703.1 Maintenance. The required fire-resistance rating of fire-resistance-rated construction (inclu ...</p> <p>14) PM305.1 General. The interior of a structure and equipment therein shall be maintained in good repair ...</p> <p>15) F703.1 Maintenance. The required fire-resistance rating of fire-resistance-rated construction (inclu ...</p> <p>16) F1011.2 Illumination. Exit signs shall be internally or externally illuminated. Exception: Tactil ...</p> <p>17) PM305.1 General. The interior of a structure and equipment therein shall be maintained in good repair ...</p> <p>18) F605.1 Abatement of electrical hazards. Identified electrical hazards shall be abated. Identified ha ...</p> <p>19) PM305.1 General. The interior of a structure and equipment therein shall be maintained in good repair ...</p> <p>20) PM305.1 General. The interior of a structure and equipment therein shall be maintained in good repair ...</p> <p>21) PM106.2 Existing nonrequired equipment and systems. Whenever or wherever any nonrequired device, equ ...</p> <p>22) PM305.1 General. The interior of a structure and equipment therein shall be maintained in good repair ...</p> <p>23) PM305.1 General. The interior of a structure and equipment therein shall be maintained in good repair ...</p> <p>24) F605.1 Abatement of electrical hazards. Identified electrical hazards shall be abated. Identified ha ...</p>
Facilities - Albany	Malden Fac	S2121 Ulster - gas station/TWY office	09/18/2014	15	0	<p>1) F906.6 Unobstructed and unobscured. Portable fire extinguishers shall not be obstructed or obscured ...</p> <p>2) PM304.15 Doors. All exterior doors, door assemblies and hardware shall be maintained in good conditi ...</p> <p>3) PM504.1 General. All plumbing fixtures shall be properly installed and maintained in working order, ...</p> <p>4) PM106.2 Existing nonrequired equipment and systems. Whenever or wherever any nonrequired device, equ ...</p> <p>5) PM504.1 General. All plumbing fixtures shall be properly installed and maintained in working order, ...</p> <p>6) F1011.2 Illumination. Exit signs shall be internally or externally illuminated. Exception: Tactil ...</p> <p>7) PM604.3 Electrical system hazards. Where it is found that the electrical system in a structure const ...</p> <p>8) PM106.1 Maintenance. Equipment, systems, devices and safeguards required by this code or a previous ...</p> <p>9) F304.1 Waste accumulation prohibited. Combustible waste material creating a hazard shall not be all ...</p> <p>10) PM106.1 Maintenance. Equipment, systems, devices and safeguards required</p>

						<p>by this code or a previous ...</p> <p>11) PM305.1 General. The interior of a structure and equipment therein shall be maintained in good repair ...</p> <p>12) PM305.1 General. The interior of a structure and equipment therein shall be maintained in good repair ...</p> <p>13) PM305.1 General. The interior of a structure and equipment therein shall be maintained in good repair ...</p> <p>14) PM504.1 General. All plumbing fixtures shall be properly installed and maintained in working order, ...</p> <p>15) PM504.1 General. All plumbing fixtures shall be properly installed and maintained in working order, ...</p>
Facilities - Albany	Malden Fac	S2128 Ulster - Gas Station C-Store 24 x 41 Type VB	09/18/2014	2	0	<p>1) F901.6.1 Standards. Fire protection systems shall be inspected, tested and maintained in accordance ...</p> <p>2) PM304.2 Protective treatment. All exterior surfaces, including but not limited to, doors, door and w ...</p>
Facilities - Albany	Malden Fac	Z2446 Fiber regeneration bldg - mp 101.4	09/24/2014	1	0	<p>1) PM106.1 Maintenance. Equipment, systems, devices and safeguards required by this code or a previous ...</p>
Facilities - Albany	Pville Fac	S2105 Guilderland - restaurant	09/09/2014	13	0	<p>1) F906.6 Unobstructed and unobscured. Portable fire extinguishers shall not be obstructed or obscured ...</p> <p>2) PM305.1 General. The interior of a structure and equipment therein shall be maintained in good repair ...</p> <p>3) PM307.1 Accumulation of rubbish or garbage. All exterior property and premises, and the interior of ...</p> <p>4) F605.3 Working space and clearance. A working space of not less than 30 inches (762 mm) in width, 36 ...</p> <p>5) F904.11.5 Portable fire extinguishers for commercial cooking equipment. Portable fire extinguishers ...</p> <p>6) F605.1 Abatement of electrical hazards. Identified electrical hazards shall be abated. Identified ha ...</p> <p>7) PM305.1 General. The interior of a structure and equipment therein shall be maintained in good repair ...</p> <p>8) PM106.1 Maintenance. Equipment, systems, devices and safeguards required by this code or a previous ...</p> <p>9) PM106.1 Maintenance. Equipment, systems, devices and safeguards required by this code or a previous ...</p> <p>10) F605.1 Abatement of electrical hazards. Identified electrical hazards shall be abated. Identified ha ...</p> <p>11) F1011.2 Illumination. Exit signs shall be internally or externally illuminated. Exception: Tactil ...</p> <p>12) PM305.1 General. The interior of a structure and equipment therein shall be maintained in good repair ...</p> <p>13) F901.6.1 Standards. Fire protection systems shall be inspected, tested and maintained in accordance ...</p>
Facilities - Albany	Pville Fac	S2106 Pattersonville - restaurant	09/11/2014	10	0	<p>1) PM305.1 General. The interior of a structure and equipment therein shall be maintained in good repair ...</p> <p>2) PM305.1 General. The interior of a structure and equipment therein shall be maintained in good repair ...</p> <p>3) PM305.1 General. The interior of a structure and equipment therein shall be maintained in good repair ...</p> <p>4) F1003.6 Means of egress continuity. The path of egress travel along a means of egress shall not be i ...</p> <p>5) PM305.1 General. The interior of a structure and equipment therein shall be maintained in good repair ...</p>

						6) F906.6 Unobstructed and unobscured. Portable fire extinguishers shall not be obstructed or obscured ... 7) F703.1 Maintenance. The required fire-resistance rating of fire-resistance-rated construction (inclu ... 8) F605.1 Abatement of electrical hazards. Identified electrical hazards shall be abated. Identified ha ... 9) F703.1 Maintenance. The required fire-resistance rating of fire-resistance-rated construction (inclu ... 10) F904.11.5 Portable fire extinguishers for commercial cooking equipment. Portable fire extinguishers ...
Facilities - Albany	Pville Fac	S2107 Mohawk - restaurant	09/11/2014	11	0	1) F1011.1 Where required. Exits and exit access doors shall be marked by an approved exit sign readily ... 2) PM106.1 Maintenance. Equipment, systems, devices and safeguards required by this code or a previous ... 3) F605.1 Abatement of electrical hazards. Identified electrical hazards shall be abated. Identified ha ... 4) F1011.1 Where required. Exits and exit access doors shall be marked by an approved exit sign readily ... 5) PM305.1 General. The interior of a structure and equipment therein shall be maintained in good repai ... 6) PM305.1 General. The interior of a structure and equipment therein shall be maintained in good repai ... 7) PM106.1 Maintenance. Equipment, systems, devices and safeguards required by this code or a previous ... 8) PM305.1 General. The interior of a structure and equipment therein shall be maintained in good repai ... 9) PM305.1 General. The interior of a structure and equipment therein shall be maintained in good repai ... 10) PM305.1 General. The interior of a structure and equipment therein shall be maintained in good repai ... 11) F901.6.1 Standards. Fire protection systems shall be inspected, tested and maintained in accordance ...
Facilities - Albany	Pville Fac	S2151 Guilderland - garbage storage	09/09/2014	0	0	
Facilities - Albany	Pville Fac	S2165 Pattersonville - operator storage 12 x 12 (former remediation)	09/11/2014	0	0	
Facilities - Albany	Pville Fac	S2168 Pattersonville - operator storage 8 x 10	09/11/2014	0	0	
Facilities - Albany	Pville Fac	S2169 Pattersonville - operator storage 10 x 12	09/11/2014	1	0	1) PM304.6 Exterior walls. All exterior walls shall be free from holes, breaks, and loose or rotting ma ...
Facilities - Albany	Pville Fac	S2171 Mohawk - garbage storage	09/11/2014	0	0	
Facilities - Albany	Pville Fac	S2172 Mohawk - sewer lift station 12 x 12	09/11/2014	0	0	
Facilities - Albany	Pville Fac	Z2744 Fiber regeneration bldg - mp 187.3	09/23/2014	2	0	1) F605.1 Abatement of electrical hazards. Identified electrical hazards shall be abated. Identified ha ... 2) PM304.7 Roofs and drainage. The roof and flashing shall be sound, tight and not have defects that ad ...
Facilities - Albany	Selkrk Fac	Z2653 Fiber regeneration bldg - mp 142.4 nb	09/24/2014	2	0	1) PM304.7 Roofs and drainage. The roof and flashing shall be sound, tight and not have defects that ad ... 2) PM106.1 Maintenance. Equipment, systems, devices and safeguards required by this code or a previous ...
Facilities - Albany	Selkrk Fac	Z2848 Fiber regeneration bldg - mp B 0.6	09/24/2014	1	0	1) F605.3.1 Labeling. Doors into electrical control panel rooms shall be marked with a plainly visible ...
	Angola Fac		07/21/2014	1	0	

Facilities - Buffalo		P4203 Silver Creek - SP office trailer Int 58				1) F901.6 Inspection, testing and maintenance. Fire detection, alarm and extinguishing systems shall be ...
Facilities - Buffalo	Angola Fac	P4204 Silver Creek - SP office trailer Int 58	07/21/2014	1	0	1) F901.6 Inspection, testing and maintenance. Fire detection, alarm and extinguishing systems shall be ...
Facilities - Buffalo	Angola Fac	P4205 Silver Creek - SP lockerroom trailer Int 58	07/21/2014	3	0	1) PM304.1 General. The exterior of a structure shall be maintained in good repair, structurally sound ... 2) F3604.1 Indoor storage. Indoor storage of flammable solids in amounts exceeding the maximum allowab ... 3) F901.6 Inspection, testing and maintenance. Fire detection, alarm and extinguishing systems shall be ...
Facilities - Buffalo	Angola Fac	P4207 Dunkirk Barracks - Int 59	07/21/2014	1	0	1) NEC 700.8 Signs. (A) Emergency Sources. A sign shall be placed at the service-entrance equipment, ...
Facilities - Buffalo	Angola Fac	S4105 Angola - restaurant	01/13/2014	32	6	1) F605.1 Abatement of electrical hazards. Identified electrical hazards shall be abated. Identified ha ... 2) F605.1 Abatement of electrical hazards. Identified electrical hazards shall be abated. Identified ha ... 3) PMC305.4 Stairs and walking surfaces. Every stair, ramp, landing, balcony, porch, deck or other wal ... 4) F703.2.3 Door operation. Swinging fire doors shall close from the full-open position and latch autom ... 5) F901.6.1 Standards. Fire protection systems shall be inspected, tested and maintained in accordance ... 6) F605.1 Abatement of electrical hazards. Identified electrical hazards shall be abated. Identified ha ... 7) P903.3 Vent termination. Every vent stack or stack vent shall terminate outdoors to the open air or ... 8) F605.9 Temporary wiring. Temporary wiring for electrical power and lighting installations is allowed ... 9) F901.6.1 Standards. Fire protection systems shall be inspected, tested and maintained in accordance ... 10) F1011.2 Illumination. Exit signs shall be internally or externally illuminated. Exception: Tactil ... 11) PMC305.4 Stairs and walking surfaces. Every stair, ramp, landing, balcony, porch, deck or other wal ... 12) F605.1 Abatement of electrical hazards. Identified electrical hazards shall be abated. Identified ha ... 13) F305.1 Clearance from ignition sources. Clearances between ignition sources, such as luminaires, he ... 14) F901.6 Inspection, testing and maintenance. Fire detection, alarm and extinguishing systems shall be ... 15) F901.6.1 Standards. Fire protection systems shall be inspected, tested and maintained in accordance ... 16) F605.1 Abatement of electrical hazards. Identified electrical hazards shall be abated. Identified ha ... 17) F605.1 Abatement of electrical hazards. Identified electrical hazards shall be abated. Identified ha ... 18) F605.1 Abatement of electrical hazards. Identified electrical hazards shall be abated. Identified ha ... 19) F605.1 Abatement of electrical hazards. Identified electrical hazards shall be abated. Identified ha ... 20) F1011.2 Illumination. Exit signs shall be internally or externally illuminated. Exception: Tactil ... 21) F605.6 Unapproved conditions. Open

						<p>junction boxes and open-wiring splices shall be prohibited. App ...</p> <p>22) F605.6 Unapproved conditions. Open junction boxes and open-wiring splices shall be prohibited. App ...</p> <p>23) F605.3.1 Labeling. Doors into electrical control panel rooms shall be marked with a plainly visible ...</p> <p>24) F605.1 Abatement of electrical hazards. Identified electrical hazards shall be abated. Identified ha ...</p> <p>25) F605.6 Unapproved conditions. Open junction boxes and open-wiring splices shall be prohibited. App ...</p> <p>26) F906.7 Hangers and brackets. Hand-held portable fire extinguishers, not housed in cabinets, shall be ...</p> <p>27) F703.2.3 Door operation. Swinging fire doors shall close from the full-open position and latch autom ...</p> <p>28) F605.1 Abatement of electrical hazards. Identified electrical hazards shall be abated. Identified ha ...</p> <p>29) F605.3 Working space and clearance. A working space of not less than 30 inches (762 mm) in width, 36 ...</p> <p>30) F1011.2 Illumination. Exit signs shall be internally or externally illuminated. Exception: Tactil ...</p> <p>31) F901.6.2 Records. Records of all system inspections, tests, and maintenance required by the referenc ...</p> <p>32) F901.6.2 Records. Records of all system inspections, tests, and maintenance required by the referenc ...</p>
Facilities - Buffalo	Angola Fac	S4105 Angola - restaurant	11/26/2014	49	1	<p>1) F605.1 Abatement of electrical hazards. Identified electrical hazards shall be abated. Identified ha ...</p> <p>2) F605.1 Abatement of electrical hazards. Identified electrical hazards shall be abated. Identified ha ...</p> <p>3) F1003.4 Floor surface. Walking surfaces of the means of egress shall have a slip-resistant surface ...</p> <p>4) F906.6 Unobstructed and unobscured. Portable fire extinguishers shall not be obstructed or obscured ...</p> <p>5) F605.5 Extension cords. Extension cords and flexible cords shall not be a substitute for permanent w ...</p> <p>6) F703.2.3 Door operation. Swinging fire doors shall close from the full-open position and latch autom ...</p> <p>7) F901.6.1 Standards. Fire protection systems shall be inspected, tested and maintained in accordance ...</p> <p>8) NEC 422.51 Cord-and-Plug-Connected Vending Machines. Cord-and-plug-connected vending machines manuf ...</p> <p>9) F605.1 Abatement of electrical hazards. Identified electrical hazards shall be abated. Identified ha ...</p> <p>10) F1003.4 Floor surface. Walking surfaces of the means of egress shall have a slip-resistant surface ...</p> <p>11) F605.1 Abatement of electrical hazards. Identified electrical hazards shall be abated. Identified ha ...</p> <p>12) F703.2.3 Door operation. Swinging fire doors shall close from the full-open position and latch autom ...</p> <p>13) F605.1 Abatement of electrical hazards. Identified electrical hazards shall be abated. Identified ha ...</p> <p>14) F605.1 Abatement of electrical hazards. Identified electrical hazards shall be abated. Identified ha ...</p> <p>15) F1003.4 Floor surface. Walking surfaces of the means of egress shall have a slip-</p>

resistant surface ...

16) NEC422.51 Cord-and-Plug-Connected Vending Machines. Cord-and-plug-connected vending machines manufa ...

17) P903.4 Vent connection at base. Every vent stack shall connect to the base of the drainage stack. T ...

18) F605.9 Temporary wiring. Temporary wiring for electrical power and lighting installations is allowed ...

19) F605.1 Abatement of electrical hazards. Identified electrical hazards shall be abated. Identified ha ...

20) F605.1 Abatement of electrical hazards. Identified electrical hazards shall be abated. Identified ha ...

21) F605.3 Working space and clearance. A working space of not less than 30 inches (762 mm) in width, 36 ...

22) F1008.1.8.4 Bolt locks. Manually operated flush bolts or surface bolts are not permitted. Excep ...

23) F605.6 Unapproved conditions. Open junction boxes and open-wiring splices shall be prohibited. App ...

24) F605.1 Abatement of electrical hazards. Identified electrical hazards shall be abated. Identified ha ...

25) F605.6 Unapproved conditions. Open junction boxes and open-wiring splices shall be prohibited. App ...

26) F703.2.3 Door operation. Swinging fire doors shall close from the full-open position and latch autom ...

27) F605.3.1 Labeling. Doors into electrical control panel rooms shall be marked with a plainly visible ...

28) PM304.6 Exterior walls. All exterior walls shall be free from holes, breaks, and loose or rotting ma ...

29) F605.6 Unapproved conditions. Open junction boxes and open-wiring splices shall be prohibited. App ...

30) F605.6 Unapproved conditions. Open junction boxes and open-wiring splices shall be prohibited. App ...

31) NEC 210.8 Ground Fault Circuit Interrupter Protection for personnel. All 125-volt, single-phase, 15 ...

32) P 411EMERGENCY SHOWERS AND EYEWASH STATIONS Where required, emergency showers and eyewash stations ...

33) PM304.15 Doors. All exterior doors, door assemblies and hardware shall be maintained in good conditi ...

34) F605.6 Unapproved conditions. Open junction boxes and open-wiring splices shall be prohibited. App ...

35) F1003.6 Means of egress continuity. The path of egress travel along a means of egress shall not be i ...

36) NEC422.51 Cord-and-Plug-Connected Vending Machines. Cord-and-plug-connected vending machines manufa ...

37) PM504.1 General. All plumbing fixtures shall be properly installed and maintained in working order, ...

38) F305.1 Clearance from ignition sources. Clearances between ignition sources, such as luminaires, he ...

39) F1003.6 Means of egress continuity. The path of egress travel along a means of egress shall not be i ...

40) F315.2.1 Ceiling clearance. Storage shall be maintained 2 feet (610 mm) or more below the ceiling in ...

41) F605.1 Abatement of electrical hazards. Identified electrical hazards shall be abated. Identified ha ...

						<p>42) F315.2.1 Ceiling clearance. Storage shall be maintained 2 feet (610 mm) or more below the ceiling in ...</p> <p>43) F315.2.1 Ceiling clearance. Storage shall be maintained 2 feet (610 mm) or more below the ceiling in ...</p> <p>44) F901.6.1 Standards. Fire protection systems shall be inspected, tested and maintained in accordance ...</p> <p>45) F901.6.1 Standards. Fire protection systems shall be inspected, tested and maintained in accordance ...</p> <p>46) BC3001.2 Except as otherwise provided for in this code, the design, construction, installation, alte ...</p> <p>47) F901.6.2 Records. Records of all system inspections, tests, and maintenance required by the referenc ...</p> <p>48) F901.6.2 Records. Records of all system inspections, tests, and maintenance required by the referenc ...</p> <p>49) F901.6.2 Records. Records of all system inspections, tests, and maintenance required by the referenc ...</p>
Facilities - Buffalo	Angola Fac	S4106 Angola - gas station (west)	11/26/2014	2	0	<p>1) F605.2 Illumination. Illumination shall be provided for service equipment areas, motor control cent ...</p> <p>2) BC 1603.3 Live loads posted. Where the live loads for which each floor or portion thereof of a comm ...</p>
Facilities - Buffalo	Angola Fac	S4107 Angola - gas station (east)	11/26/2014	6	0	<p>1) F901.6 Inspection, testing and maintenance. Fire detection, alarm and extinguishing systems shall be ...</p> <p>2) F901.6 Inspection, testing and maintenance. Fire detection, alarm and extinguishing systems shall be ...</p> <p>3) F605.1 Abatement of electrical hazards. Identified electrical hazards shall be abated. Identified ha ...</p> <p>4) F605.6 Unapproved conditions. Open junction boxes and open-wiring splices shall be prohibited. Appro ...</p> <p>5) F1003.6 Means of egress continuity. The path of egress travel along a means of egress shall not be i ...</p> <p>6) PM304.7 Roofs and drainage. The roof and flashing shall be sound, tight and not have defects that ad ...</p>
Facilities - Buffalo	Angola Fac	Z4750 Fiber regeneration bldg - mp 445.2	09/30/2014	5	0	<p>1) PM304.7 Roofs and drainage. The roof and flashing shall be sound, tight and not have defects that ad ...</p> <p>2) F605.1 Abatement of electrical hazards. Identified electrical hazards shall be abated. Identified ha ...</p> <p>3) F901.6.2 Records. Records of all system inspections, tests, and maintenance required by the referenc ...</p> <p>4) F608.7.1 Equipment room and building signage. Doors into electrical equipment rooms or buildings co ...</p> <p>5) F901.6 Inspection, testing and maintenance. Fire detection, alarm and extinguishing systems shall be ...</p>
Facilities - Buffalo	Angola Fac	Z4854 Fiber regeneration bldg - mp 467.9	09/30/2014	3	0	<p>1) F901.6 Inspection, testing and maintenance. Fire detection, alarm and extinguishing systems shall be ...</p> <p>2) F608.7.1 Equipment room and building signage. Doors into electrical equipment rooms or buildings co ...</p> <p>3) F901.6.2 Records. Records of all system inspections, tests, and maintenance required by the referenc ...</p>
Facilities - Buffalo	Buff Fac	M4341 Div Headquarters - brick Walden Ave	03/18/2014	7	4	<p>1) F901.6 Inspection, testing and maintenance. Fire detection, alarm and extinguishing systems shall be ...</p> <p>2) F605.1 Abatement of electrical hazards. Identified electrical hazards shall be abated. Identified ha ...</p> <p>3) F315.2.1 Ceiling clearance. Storage shall</p>

						<p>be maintained 2 feet (610 mm) or more below the ceiling in ...</p> <p>4) F901.6 Inspection, testing and maintenance. Fire detection, alarm and extinguishing systems shall be ...</p> <p>5) F1008.1.8 Door operations. Except as specifically permitted by this section, egress doors shall be ...</p> <p>6) F315.2 Storage in Buildings. Storage of combustible materials in buildings shall be orderly. Stora ...</p> <p>7) F605.6 Unapproved conditions. Open junction boxes and open-wiring splices shall be prohibited. App ...</p>
Facilities - Buffalo	Buff Fac	M4341 Div Headquarters - brick Walden Ave	03/18/2014	8	6	<p>1) F605.5 Extension cords. Extension cords and flexible cords shall not be a substitute for permanent w ...</p> <p>2) F605.5 Extension cords. Extension cords and flexible cords shall not be a substitute for permanent w ...</p> <p>3) F605.5 Extension cords. Extension cords and flexible cords shall not be a substitute for permanent w ...</p> <p>4) F605.1 Abatement of electrical hazards. Identified electrical hazards shall be abated. Identified ha ...</p> <p>5) F605.3.1 Labeling. Doors into electrical control panel. The disconnecting means for each service, fe ...</p> <p>6) F1003.6 Means of egress continuity. The path of egress travel along a means of egress shall not be i ...</p> <p>7) F703.1 Maintenance. The required fire-resistance rating of fire-resistance-rated construction (inclu ...</p> <p>8) F605.1 Abatement of electrical hazards. Identified electrical hazards shall be abated. Identified ha ...</p>
Facilities - Buffalo	Buff Fac	M4341 Div Headquarters - brick Walden Ave	03/18/2014	1	0	<p>1) F901.6 Inspection, testing and maintenance. Fire detection, alarm and extinguishing systems shall be ...</p>
Facilities - Buffalo	Buff Fac	M4341 Div Headquarters - brick Walden Ave	03/18/2014	10	4	<p>1) F901.6 Inspection, testing and maintenance. Fire detection, alarm and extinguishing systems shall be ...</p> <p>2) F605.5 Extension cords. Extension cords and flexible cords shall not be a substitute for permanent w ...</p> <p>3) F605.5 Extension cords. Extension cords and flexible cords shall not be a substitute for permanent w ...</p> <p>4) F605.6 Unapproved conditions. Approved covers shall be provided for all switch and electrical outlet ...</p> <p>5) F901.6 Inspection, testing and maintenance. Fire detection, alarm and extinguishing systems shall be ...</p> <p>6) F901.6 Inspection, testing and maintenance. Fire detection, alarm and extinguishing systems shall be ...</p> <p>7) F605.1 Abatement of electrical hazards. Identified electrical hazards shall be abated. Identified ha ...</p> <p>8) F901.6 Inspection, testing and maintenance. Fire detection, alarm and extinguishing systems shall be ...</p> <p>9) F315.2.2 Means of egress. Combustible materials shall not be stored in exits or exit enclosures. (r ...</p> <p>10) F3404.2.3 Labeling and signs. Labeling and signs for storage tanks and storage tank areas shall comp ...</p>
Facilities - Buffalo	Buff Fac	M4342 Div Stores - metal	03/18/2014	9	0	<p>1) F901.6 Inspection, testing and maintenance. Fire detection, alarm and extinguishing systems shall be ...</p> <p>2) F605.1 Abatement of electrical hazards. Identified electrical hazards shall be abated. Identified ha ...</p> <p>3) F315.2.1 Ceiling clearance. Storage shall be maintained 2 feet (610 mm) or more</p>

						below the ceiling in ... 4) F901.6 Inspection, testing and maintenance. Fire detection, alarm and extinguishing systems shall be ... 5) PM304.6 Exterior walls. All exterior walls shall be free from holes, breaks, and loose or rotting ma ... 6) PM603.1 Mechanical appliances. All mechanical appliances, fireplaces, solid fuel-burning appliances, ... 7) F605.1 Abatement of electrical hazards. Identified electrical hazards shall be abated. Identified ha ... 8) F901.6 Inspection, testing and maintenance. Fire detection, alarm and extinguishing systems shall be ... 9) F1012.5 Handrail extensions. Handrails shall return to a wall, guard or the walking surface or shal ...
Facilities - Buffalo	Buff Fac	M4343 Buffalo Section - salt storage pole type	03/17/2014	2	0	1) PM304.4 Structural members. All structural members shall be maintained free from deterioration, and ... 2) F605.5 Extension cords. Extension cords and flexible cords shall not be a substitute for permanent w ...
Facilities - Buffalo	Buff Fac	M4345 Div Facilities - metal	03/17/2014	3	0	1) F315.2.1 Ceiling clearance. Storage shall be maintained 2 feet (610 mm) or more below the ceiling in ... 2) F315.2.1 Ceiling clearance. Storage shall be maintained 2 feet (610 mm) or more below the ceiling in ... 3) F605.6 Unapproved conditions. Open junction boxes and open-wiring splices shall be prohibited. App ...
Facilities - Buffalo	Buff Fac	M4347 Division Stores - timber column	03/17/2014	0	0	
Facilities - Buffalo	Buff Fac	M4348 Division ITSM - brick - Maryvale Drive - previously DSP Zone HQ	04/17/2014	4	0	1) F901.6 Inspection, testing and maintenance. Fire detection, alarm and extinguishing systems shall be ... 2) F605.1 Abatement of electrical hazards. Identified electrical hazards shall be abated. Identified ha ... 3) PM304.15 Doors. All exterior doors, door assemblies and hardware shall be maintained in good conditi ... 4) PM304.1 General. The exterior of a structure shall be maintained in good repair, structurally sound ...
Facilities - Buffalo	Buff Fac	M4350 Buffalo Section - abrasive storage pole type	03/17/2014	0	0	
Facilities - Buffalo	Buff Fac	M4354 Div Headquarters - propane storage Walden Ave	03/17/2014	1	0	1) F3003.5 Security. Compressed gas containers, cylinders, tanks and systems shall be secured against a ...
Facilities - Buffalo	Buff Fac	M4357 Div Facilities - storage wooden 12 x 24	03/17/2014	0	0	
Facilities - Buffalo	Buff Fac	M4931 Niagara Section - brick	04/03/2014	16	0	1) F605.1 Abatement of electrical hazards. Identified electrical hazards shall be abated. Identified ha ... 2) F605.3 Working space and clearance. A working space of not less than 30 inches (762 mm) in width, 36 ... 3) F605.1 Abatement of electrical hazards. Identified electrical hazards shall be abated. Identified ha ... 4) F605.1 Abatement of electrical hazards. Identified electrical hazards shall be abated. Identified ha ... 5) F315.2.3 Equipment Rooms. Combustible materials shall not be stored in boiler rooms, mechanical roo ... 6) F906.7 Hangers and brackets. Hand-held portable fire extinguishers, not housed in cabinets, shall be ... 7) F605.1 Abatement of electrical hazards. Identified electrical hazards shall be abated. Identified ha ... 8) F605.1 Abatement of electrical hazards. Identified electrical hazards shall be abated.

						<p>Identified ha ...</p> <p>9) F315.2.1 Ceiling clearance. Storage shall be maintained 2 feet (610 mm) or more below the ceiling in ...</p> <p>10) F605.1 Abatement of electrical hazards. Identified electrical hazards shall be abated. Identified ha ...</p> <p>11) NEC (NFPA 70) section 110.16 Arc Flash Hazard Warning. Electrical equipment, such as switchboards, ...</p> <p>12) F1015.2 Exit or exit access doorway arrangement. Required exits shall be located in a manner that ...</p> <p>13) F605.5 Extension cords. Extension cords and flexible cords shall not be a substitute for permanent w ...</p> <p>14) F605.6 Unapproved conditions. Open junction boxes and open-wiring splices shall be prohibited. App ...</p> <p>15) F901.6.1 Standards. Fire protection systems shall be inspected, tested and maintained in accordance ...</p> <p>16) F3404.2.3 Labeling and signs. Labeling and signs for storage tanks and storage tank areas shall comp ...</p>
Facilities - Buffalo	Buff Fac	M4932 Niagara Section - metal	04/07/2014	11	0	<p>1) F605.5.3 Maintenance. Extension cords shall be maintained in good condition without splices, deteri ...</p> <p>2) F906.7 Hangers and brackets. Hand-held portable fire extinguishers, not housed in cabinets, shall be ...</p> <p>3) F315.2.1 Ceiling clearance. Storage shall be maintained 2 feet (610 mm) or more below the ceiling in ...</p> <p>4) F906.7 Hangers and brackets. Hand-held portable fire extinguishers, not housed in cabinets, shall be ...</p> <p>5) F906.7 Hangers and brackets. Hand-held portable fire extinguishers, not housed in cabinets, shall be ...</p> <p>6) F3404.3.2.1.1 Materials. Cabinets shall be listed in accordance with UL 1275, or constructed of appr ...</p> <p>7) F605.3 Working space and clearance. A working space of not less than 30 inches (762 mm) in width, 36 ...</p> <p>8) 1009.10 Handrails. Stairways shall have handrails on each side and shall comply with Section 1012. ...</p> <p>9) F605.6 Unapproved conditions. Open junction boxes and open-wiring splices shall be prohibited. Appro ...</p> <p>10) F605.5 Extension cords. Extension cords and flexible cords shall not be a substitute for permanent w...</p> <p>11) F1008.1.8.4 Bolt locks. Manually operated flush bolts or surface bolts are not permitted. ...</p>
Facilities - Buffalo	Buff Fac	M4933 Niagara Section - column type open storage	04/03/2014	5	0	<p>1) F605.6 Unapproved conditions. Open junction boxes and open-wiring splices shall be prohibited. Appro ...</p> <p>2) F605.1 Abatement of electrical hazards. Identified electrical hazards shall be abated. Identified ha ...</p> <p>3) F605.1 Abatement of electrical hazards. Identified electrical hazards shall be abated. Identified ha ...</p> <p>4) F1008.1.8.4 Bolt locks. Manually operated flush bolts or surface bolts are not permitted. ...</p> <p>5) F1011.1 Where required. Exits and exit access doors shall be marked by an approved exit sign readily ...</p>
Facilities - Buffalo	Buff Fac	M4934 Niagara Section - salt storage pole type	04/03/2014	3	0	<p>1) F605.3.1 Labeling. Doors into electrical control panel shall be marked with a plainly visible and le ...</p> <p>2) PM304.4 Structural members. All structural members shall be maintained free from deterioration, and ...</p>

						3) F605.1 Abatement of electrical hazards. Identified electrical hazards shall be abated. Identified ha ...
Facilities - Buffalo	Buff Fac	M4935 Niagara Section - abrasive storage pole type	04/03/2014	1	0	1) F605.6 Unapproved conditions. Open junction boxes and open-wiring splices shall be prohibited. Appro ...
Facilities - Buffalo	Buff Fac	M4936 Div Highway & Bridge - block Dingens St.	03/11/2014	11	4	1) F605.1 Abatement of electrical hazards. Identified electrical hazards shall be abated. Identified ha ... 2) PM604.3 Electrical system hazards. Where it is found that the electrical system in a structure const ... 3) PM604.3 Electrical system hazards. Where it is found that the electrical system in a structure const ... 4) F605.6 Unapproved conditions. Open junction boxes and open-wiring splices shall be prohibited. App ... 5) F901.6 Inspection, testing and maintenance. Fire detection, alarm and extinguishing systems shall b ... 6) F605.3.1 Labeling. The disconnecting means for each service, feeder or branch circuit originating on ... 7) F605.6 Unapproved conditions. Open junction boxes and open-wiring splices shall be prohibited. App ... 8) F901.8 Removal of or tampering with equipment. It shall be prohibited for any person to remove, tamp ... 9) F901.6 Inspection, testing and maintenance. Fire detection, alarm and extinguishing systems shall be ... 10) F605.5 Extension cords. Extension cords and flexible cords shall not be a substitute for permanent w ... 11) F605.4.2 Power supply. Relocatable power taps shall be directly connected to a permanently installe ...
Facilities - Buffalo	Buff Fac	M4937 Division & Niagara Bridge - metal Dingens St.	03/11/2014	4	1	1) F605.3 Working space and clearance. A working space of not less than 30 inches (762 mm) in width, 36 ... 2) F605.6 Unapproved conditions. Open junction boxes and open-wiring splices shall be prohibited. App ... 3) F605.6 Unapproved conditions. Open junction boxes and open-wiring splices shall be prohibited. App ... 4) F3404.4.3 Spill control and secondary containment. Storage areas shall be provided with spill contr ...
Facilities - Buffalo	Buff Fac	M4938 Niagara Section - transformers concrete block mp N8.2 sb	03/31/2014	1	0	1) F605.1 Abatement of electrical hazards. Identified electrical hazards shall be abated. Identified ha ...
Facilities - Buffalo	Buff Fac	M4939 Niagara Section - pump house mp N9.1 nb	03/31/2014	1	0	1) F901.6 Inspection, testing and maintenance. Fire detection, alarm and extinguishing systems shall be ...
Facilities - Buffalo	Buff Fac	M4940 Niagara Section - equipment storage - pole 50 x 160	04/03/2014	8	0	1) F605.1 Abatement of electrical hazards. Identified electrical hazards shall be abated. Identified ha ... 2) F906.6 Unobstructed and unobscured. Portable fire extinguishers shall not be obstructed or obscured ... 3) F901.6 Inspection, testing and maintenance. Fire detection, alarm and extinguishing systems shall be ... 4) F605.1 Abatement of electrical hazards. Identified electrical hazards shall be abated. Identified ha ... 5) F605.1 Abatement of electrical hazards. Identified electrical hazards shall be abated. Identified ha ... 6) F1003.6 Means of egress continuity. The path of egress travel along a means of egress shall not be ... 7) F312.1 General. Vehicle impact protection required by this code shall be provided by posts that com ...

						8) PMC304.7 Roofs and drainage. The roof and flashing shall be sound, tight and not have defects that ...
Facilities - Buffalo	Buff Fac	M4943 Niagara Section - propane storage	04/03/2014	0	0	
Facilities - Buffalo	Buff Fac	M4944 Niagara Section - brick transformer Scott St (Buffalo News Vault)	03/31/2014	0	0	
Facilities - Buffalo	Buff Fac	M4945 Niagara Bridge - vault Michigan/Scott St.	03/31/2014	1	0	1) F605.6 Unapproved conditions. Open junction boxes and open-wiring splices shall be prohibited. Appro ...
Facilities - Buffalo	Buff Fac	M4950 Niagara Section - salt shed pole type Ogden Street	03/11/2014	1	0	1) F605.1 Abatement of electrical hazards. Identified electrical hazards shall be abated. Identified ha ...
Facilities - Buffalo	Buff Fac	M4951 Niagara Section - electrical meter shelter bldg 7 x 39 mp N 8.1 sb	03/31/2014	2	0	1) F605.6 Unapproved conditions. Open junction boxes and open-wiring splices shall be prohibited. App ... 2) F605.1 Abatement of electrical hazards. Identified electrical hazards shall be abated. Identified ha ...
Facilities - Buffalo	Buff Fac	P4202 Buffalo Barracks - Maryvale Drive	07/17/2014	8	0	1) F703.1 Maintenance. The required fire-resistance rating of fire-resistance-rated construction (inclu ... 2) F605.6 Unapproved conditions. Open junction boxes and open-wiring splices shall be prohibited. Appro ... 3) F605.1 Abatement of electrical hazards. Identified electrical hazards shall be abated. Identified ha ... 4) F605.1 Abatement of electrical hazards. Identified electrical hazards shall be abated. Identified ha ... 5) F315.2.3 Equipment Rooms. Combustible materials shall not be stored in boiler rooms, mechanical roo ... 6) F315.2.1 Ceiling clearance. Storage shall be maintained 2 feet (610 mm) or more below the ceiling in ... 7) F605.3.1 Labeling. Doors into electrical control panel rooms shall be marked with a plainly visible ... 8) Multiple heat producing appliances plugged into surge protector. ...
Facilities - Buffalo	Buff Fac	P4206 Buffalo - SP storage wooden Maryvale Drive	07/17/2014	1	0	1) F605.1 Abatement of electrical hazards. Identified electrical hazards shall be abated. Identified ha ...
Facilities - Buffalo	Buff Fac	R4351 Radio Shelter Building - Walden Ave maintenance yard mp 423.2 wb	04/16/2014	1	0	1) F901.6 Inspection, testing and maintenance. Fire detection, alarm and extinguishing systems shall be ...
Facilities - Buffalo	Buff Fac	T4651 Toll Utility Trailer - Maryvale Drive (Exit 51E)	10/27/2014	0	0	
Facilities - Buffalo	Buff Fac	T4651 Toll Utility Trailer - Maryvale Drive (Exit 51E)	10/28/2014	1	0	1) TEST ...
Facilities - Buffalo	Buff Fac	T4651 Toll Utility Trailer - Maryvale Drive (Exit 51E)	10/28/2014	0	0	
Facilities - Buffalo	Buff Fac	T4651 Toll Utility Trailer - Maryvale Drive (Exit 51E)	10/30/2014	1	0	1) TEST ...
Facilities - Buffalo	Buff Fac	T4901 Toll Equipment Maintenance - shop old City Line Barrier sb	03/10/2014	8	7	1) F605.1 Abatement of electrical hazards. Identified electrical hazards shall be abated. Identified ha ... 2) F605.1 Abatement of electrical hazards. Identified electrical hazards shall be abated. Identified ha ... 3) F315.2.1 Ceiling clearance. Storage shall be maintained 2 feet (610 mm) or more below the ceiling in ... 4) F315.2.1 Ceiling clearance. Storage shall be maintained 2 feet (610 mm) or more below the ceiling in ... 5) F901.6 Inspection, testing and maintenance. Fire detection, alarm and extinguishing systems shall be ... 6) F901.6 Inspection, testing and maintenance. Fire detection, alarm and extinguishing systems shall be ... 7) F605.5 Extension cords. Extension cords and flexible cords shall not be a substitute for permanent w ...

						8) F315.2 Storage in Buildings. Storage of combustible materials in buildings shall be orderly. Stora ...
Facilities - Buffalo	Buff Fac	T4902 City Line - Old TUB and attached trailer - nb	03/10/2014	1	0	1) PM302.3 Sidewalks and driveways. All sidewalks, walkways, stairs, driveways, parking spaces and simi ...
Facilities - Buffalo	Buff Fac	T4917 Tonawanda Barrier - South Grand Island Bridge (nb)	03/10/2014	9	1	1) F605.7 Appliances. Electrical appliances and fixtures shall be tested and listed in published report ... 2) F605.1 Abatement of electrical hazards. Identified electrical hazards shall be abated. Identified ha ... 3) F605.5 Extension cords. Extension cords and flexible cords shall not be a substitute for permanent w ... 4) F901.4.1 Required fire protection systems. Fire protection systems required by this code, the Bui ... 5) F605.1 Abatement of electrical hazards. Identified electrical hazards shall be abated. Identified ha ... 6) F605.1 Abatement of electrical hazards. Identified electrical hazards shall be abated. Identified ha ... 7) F605.1 Abatement of electrical hazards. Identified electrical hazards shall be abated. Identified ha ... 8) F906.7 Hangers and brackets. Hand-held portable fire extinguishers, not housed in cabinets, shall be ... 9) F605.1 Abatement of electrical hazards. Identified electrical hazards shall be abated. Identified ha ...
Facilities - Buffalo	Buff Fac	T4918 Tonawanda Barrier - generator/work shop (SGIB)	03/10/2014	1	0	1) F605.3.1 Labeling electrical control panel rooms shall be marked with a plainly visible and legible ...
Facilities - Buffalo	Buff Fac	T4920 Niagara Barrier - North Grand Island Bridge (sb)	03/10/2014	6	0	1) PM304.15 Doors. All exterior doors, door assemblies and hardware shall be maintained in good conditi ... 2) F605.6 Unapproved conditions. Open-wiring splices shall be prohibited. Approved covers shall be pr ... 3) F605.1 Abatement of electrical hazards. Identified electrical hazards shall be abated. Identified ha ... 4) F605.1 Abatement of electrical hazards. Identified electrical hazards shall be abated. Identified ha ... 5) F605.1 Abatement of electrical hazards. Identified electrical hazards shall be abated. Identified ha ... 6) F605.3.1 Labeling. Doors into electrical control panel rooms shall be marked with a plainly visible ...
Facilities - Buffalo	Buff Fac	Z4643 Fiber regeneration bldg - mp 427.0	09/30/2014	7	0	1) F605.1 Abatement of electrical hazards. Identified electrical hazards shall be abated. Identified ha ... 2) PM304.7 Roofs and drainage. The roof and flashing shall be sound, tight and not have defects that ad ... 3) F605.5 Extension cords. Extension cords and flexible cords shall not be a substitute for permanent w ... 4) F608.7.1 Equipment room and building signage. Doors into electrical equipment rooms or buildings co ... 5) F901.6.2 Records. Records of all system inspections, tests, and maintenance required by the referenc ... 6) F605.1 Abatement of electrical hazards. Identified electrical hazards shall be abated. Identified ha ... 7) F901.6 Inspection, testing and maintenance. Fire detection, alarm and extinguishing systems shall be ...
Facilities - Buffalo	Pembrk Fac	M4531 Batavia Section - brick	03/04/2014	5	0	1) F703.2.3 Door operation. Swinging fire doors shall close from the full-open position and latch autom ...

						<p>2) F605.1 Abatement of electrical hazards. Identified electrical hazards shall be abated. Identified ha ...</p> <p>3) F703.1 Maintenance. The required fire-resistance rating of fire-resistance-rated construction (inclu ...</p> <p>4) F605.1 Abatement of electrical hazards. Identified electrical hazards shall be abated. Identified ha ...</p> <p>5) F605.5 Extension cords. Extension cords and flexible cords shall not be a substitute for permanent w ...</p>
Facilities - Buffalo	Pembrk Fac	M4532 Batavia Section - metal	03/04/2014	8	5	<p>1) PM604.3 Electrical system hazards. Where it is found that the electrical system in a structure const ...</p> <p>2) F605.3.1 Labeling. Doors into electrical control panel rooms shall be marked with a plainly visible ...</p> <p>3) P504.6 Requirements for discharge piping. The discharge piping serving a pressure relief valve, tem ...</p> <p>4) PM504.1 General. All plumbing fixtures shall be properly installed and maintained in working order, ...</p> <p>5) F605.6 Unapproved conditions. Open-wiring splices shall be prohibited. Approved covers shall be pr ...</p> <p>6) F605.6 Unapproved conditions. Open-wiring splices shall be prohibited. Approved covers shall be pr ...</p> <p>7) F901.6 Inspection, testing and maintenance. Fire detection, alarm and extinguishing systems shall be ...</p> <p>8) F315.2.1 Ceiling clearance. Storage shall be maintained 2 feet (610 mm) or more below the ceiling in ...</p>
Facilities - Buffalo	Pembrk Fac	M4533 Batavia Section - salt storage concrete block	03/03/2014	3	0	<p>1) F605.5.3 Maintenance. Extension cords shall be maintained in good condition without splices, deteri ...</p> <p>2) F605.1 Abatement of electrical hazards. Identified electrical hazards shall be abated. Identified ha ...</p> <p>3) PM304.6 Exterior walls. All exterior walls shall be free from holes, breaks, and loose or rotting ma ...</p>
Facilities - Buffalo	Pembrk Fac	M4534 Batavia Section - storage metal tandem lot	03/03/2014	1	0	<p>1) BC1603.3 Live loads posted. Where the live loads for which each floor or portion thereof of a comme ...</p>
Facilities - Buffalo	Pembrk Fac	M4536 Batavia Section - salt storage pole type	03/03/2014	0	0	
Facilities - Buffalo	Pembrk Fac	M4537 Batavia Section - abrasive storage Hi Arch	03/03/2014	1	0	<p>1) F605.3.1 Labeling. Doors into electrical control panel rooms shall be marked with a plainly visible ...</p>
Facilities - Buffalo	Pembrk Fac	M4538 Batavia Section - saltshed Hi Arch LeRoy (Int 47)	03/03/2014	1	0	<p>1) F1011.1 Where required. Exits and exit access doors shall be marked by an approved exit sign readily ...</p>
Facilities - Buffalo	Pembrk Fac	M4539 Pembroke Facilities - office Pembroke SA mp 397.4 eb	11/03/2014	3	0	<p>1) F901.6 Inspection, testing and maintenance. Fire detection, alarm and extinguishing systems shall be ...</p> <p>2) P411.1 Approval. Where required, emergency showers and eyewash stations shall conform to ISEA Z358. ...</p> <p>3) F1008.1.2 Door swing. The opening force for interior side-swinging doors without closers shall not ...</p>
Facilities - Buffalo	Pembrk Fac	M4540 Batavia Section - equipment storage - pole 50 x 160	03/03/2014	2	0	<p>1) F605.3.1 Labeling. Doors into electrical control panel rooms shall be marked with a plainly visible ...</p> <p>2) F901.6 Inspection, testing and maintenance. Fire detection, alarm and extinguishing systems shall be ...</p>
Facilities - Buffalo	Pembrk Fac	M4633 Buffalo Section - salt shed pole type mp 409.8 eb	02/28/2014	0	0	
Facilities - Buffalo	Pembrk Fac	P4201 W. Henrietta Barracks - Int 46	07/14/2014	7	0	<p>1) F907.20 Inspection, testing and maintenance. The maintenance and testing schedules and procedures fo ...</p> <p>2) PM304.7 Roofs and drainage. The roof and flashing shall be sound, tight and not</p>

						<p>have defects that ad ...</p> <p>3) F315.2.1 Ceiling clearance. Storage shall be maintained 2 feet (610 mm) or more below the ceiling in ...</p> <p>4) F605.1 Abatement of electrical hazards. Identified electrical hazards shall be abated. Identified ha ...</p> <p>5) F605.1 Abatement of electrical hazards. Identified electrical hazards shall be abated. Identified ha ...</p> <p>6) PM304.1 General. The exterior of a structure shall be maintained in good repair, structurally sound ...</p> <p>7) BC 1106.1 Where parking is provided, accessible parking spaces shall be provided in compliance with ...</p>
Facilities - Buffalo	Pembrk Fac	S4101 Scottsville - restaurant/gas station	11/04/2014	11	0	<p>1) F605.3.1 Labeling. Doors into electrical control panel rooms shall be marked with a plainly visible ...</p> <p>2) F901.6.1 Standards. Fire protection systems shall be inspected, tested and maintained in accordance ...</p> <p>3) F901.6.1 Standards. Fire protection systems shall be inspected, tested and maintained in accordance ...</p> <p>4) F901.6 Inspection, testing and maintenance. Fire detection, alarm and extinguishing systems shall be ...</p> <p>5) F605.1 Abatement of electrical hazards. Identified electrical hazards shall be abated. Identified ha ...</p> <p>6) F1008.1.8.4 Bolt locks. Manually operated flush bolts or surface bolts are not permitted. ...</p> <p>7) F1008.1.8.4 Bolt locks. Manually operated flush bolts or surface bolts are not permitted. ...</p> <p>8) F1008.1.8 Door operations. Except as specifically permitted by this section, egress doors shall be ...</p> <p>9) F703.2.3 Door operation. Swinging fire doors shall close from the full-open position and latch autom ...</p> <p>10) F605.1 Abatement of electrical hazards. Identified electrical hazards shall be abated. Identified ha ...</p> <p>11) PM304.7 Roofs and drainage. The roof and flashing shall be sound, tight and not have defects that ad ...</p>
Facilities - Buffalo	Pembrk Fac	S4101 Scottsville - restaurant/gas station	11/04/2014	3	0	<p>1) F605.3 Working space and clearance. A working space of not less than 30 inches (762 mm) in width, 36 ...</p> <p>2) F2204.2.4 Obstructions to view. Dispensing devices shall be in clear view of the attendant at all t ...</p> <p>3) PM504.1 General. All plumbing fixtures shall be properly installed and maintained in working order, ...</p>
Facilities - Buffalo	Pembrk Fac	S4102 Ontario - restaurant	11/06/2014	12	0	<p>1) F901.6 Inspection, testing and maintenance. Fire detection, alarm and extinguishing systems shall be ...</p> <p>2) F605.3.1 Labeling. Doors into electrical control panel rooms shall be marked with a plainly visible ...</p> <p>3) F901.6 Inspection, testing and maintenance. Fire detection, alarm and extinguishing systems shall be ...</p> <p>4) PM305.1 General. The interior of a structure and equipment therein shall be maintained in good repai ...</p> <p>5) PM604.3 Electrical system hazards. Where it is found that the electrical system in a structure const ...</p> <p>6) F315.2.1 Ceiling clearance. Storage shall be maintained 2 feet (610 mm) or more below the ceiling in ...</p> <p>7) PM305.1 General. The interior of a structure and equipment therein shall be maintained in good repai ...</p>

						<p>8) F605.3 Working space and clearance. A working space of not less than 30 inches (762 mm) in width, 36 ...</p> <p>9) F605.1 Abatement of electrical hazards. Identified electrical hazards shall be abated. Identified ha ...</p> <p>10) F906.7 Hangers and brackets. Hand-held portable fire extinguishers, not housed in cabinets, shall be ...</p> <p>11) F605.6 Unapproved conditions. Open junction boxes and open-wiring splices shall be prohibited. Appro ...</p> <p>12) PM302.3 Sidewalks and driveways. All sidewalks, walkways, stairs, driveways, parking spaces and simi ...</p>
Facilities - Buffalo	Pembrk Fac	S4103 Pembroke - restaurant	11/03/2014	15	0	<p>1) F605.1 Abatement of electrical hazards. Identified electrical hazards shall be abated. Identified ha ...</p> <p>2) NEC 422.51 Cord-and-Plug-Connected Vending Machines. Cord-and-plug-connected vending machines manuf ...</p> <p>3) F901.6.1 Standards. Fire protection systems shall be inspected, tested and maintained in accordance ...</p> <p>4) F901.6.1 Standards. Fire protection systems shall be inspected, tested and maintained in accordance ...</p> <p>5) F605.3.1 Labeling. Doors into electrical control panel rooms shall be marked with a plainly visible ...</p> <p>6) F605.1 Abatement of electrical hazards. Identified electrical hazards shall be abated. Identified ha ...</p> <p>7) F315.2.1 Ceiling clearance. Storage shall be maintained 2 feet (610 mm) or more below the ceiling in ...</p> <p>8) F605.1 Abatement of electrical hazards. Identified electrical hazards shall be abated. Identified ha ...</p> <p>9) PM304.7 Roofs and drainage. The roof and flashing shall be sound, tight and not have defects that ad ...</p> <p>10) F3809.1 General. Storage of portable containers of 1,000 pounds (454 kg) or less, whether filled, pa ...</p> <p>11) PM504.1 General. All plumbing fixtures shall be properly installed and maintained in working order, ...</p> <p>12) 504.6 Requirements for discharge piping. The discharge piping serving a pressure relief valve, temp ...</p> <p>13) 408.4 Sediment trap. Where a sediment trap is not incorporated as part of the gas utilization equip ...</p> <p>14) FGC 307.4 Traps. Condensate drains shall be trapped as required by the equipment or appliance manu ...</p> <p>15) F901.6 Inspection, testing and maintenance. Fire detection, alarm and extinguishing systems shall be ...</p>
Facilities - Buffalo	Pembrk Fac	S4104 Clarence - restaurant	11/07/2014	10	0	<p>1) F605.3.1 Labeling. Doors into electrical control panel rooms shall be marked with a plainly visible ...</p> <p>2) F315.2.1 Ceiling clearance. Storage shall be maintained 2 feet (610 mm) or more below the ceiling in ...</p> <p>3) F703.2.3 Door operation. Swinging fire doors shall close from the full-open position and latch autom ...</p> <p>4) F901.6.1 Standards. Fire protection systems shall be inspected, tested and maintained in accordance ...</p> <p>5) F605.1 Abatement of electrical hazards. Identified electrical hazards shall be abated. Identified ha ...</p> <p>6) F605.1 Abatement of electrical hazards. Identified electrical hazards shall be abated. Identified ha ...</p> <p>7) F605.3.1 Labeling. Doors into electrical</p>

						control panel rooms shall be marked with a plainly visible ... 8) F605.6 Unapproved conditions. Open junction boxes and open-wiring splices shall be prohibited. Appro ... 9) F605.6 Unapproved conditions. Open junction boxes and open-wiring splices shall be prohibited. App ... 10) F315.2 Storage in Buildings. Storage of combustible materials in buildings shall be orderly. Stora ...
Facilities - Buffalo	Pembrk Fac	S4108 Scottsville - metal storage	11/04/2014	5	0	1) F605.1 Abatement of electrical hazards. Identified electrical hazards shall be abated. Identified ha ... 2) PM304.2 Protective treatment. All exterior surfaces, including but not limited to, doors, door and w ... 3) PM305.1 General. The interior of a structure and equipment therein shall be maintained in good repai ... 4) F1003.6 Means of egress continuity. The path of egress travel along a means of egress shall not be i ... 5) F901.6 Inspection, testing and maintenance. Fire detection, alarm and extinguishing systems shall be ...
Facilities - Buffalo	Pembrk Fac	S4109 Scottsville - travel information center (TIC)	11/04/2014	2	0	1) F605.1 Abatement of electrical hazards. Identified electrical hazards shall be abated. Identified ha ... 2) F605.3 Working space and clearance. A working space of not less than 30 inches (762 mm) in width, 36 ...
Facilities - Buffalo	Pembrk Fac	S4111 Clarence - metal storage	11/07/2014	2	0	1) F605.1 Abatement of electrical hazards. Identified electrical hazards shall be abated. Identified ha ... 2) PM304.2 Protective treatment. All exterior surfaces, including but not limited to, doors, door and w ...
Facilities - Buffalo	Pembrk Fac	S4112 Scottsville - generator building	11/04/2014	0	0	
Facilities - Buffalo	Pembrk Fac	S4120 Ontario - gas station/generator building	11/06/2014	4	0	1) F605.3.1 Labeling. Doors into electrical control panel rooms shall be marked with a plainly visible ... 2) PM304.15 Doors. All exterior doors, door assemblies and hardware shall be maintained in good conditi ... 3) F904.6 Dry-chemical systems. Dry-chemical extinguishing systems shall be installed, maintained, per ... 4) PM302.3 Sidewalks and driveways. All sidewalks, walkways, stairs, driveways, parking spaces and simi ...
Facilities - Buffalo	Pembrk Fac	S4121 Ontario - WWTP storage 12 x 16	03/27/2014	2	2	1) F605.1 Abatement of electrical hazards. Identified electrical hazards shall be abated. Identified ha ... 2) F605.1 Abatement of electrical hazards. Identified electrical hazards shall be abated. Identified ha ...
Facilities - Buffalo	Pembrk Fac	S4121 Ontario - WWTP storage 12 x 16	11/06/2014	1	0	1) F605.1 Abatement of electrical hazards. Identified electrical hazards shall be abated. Identified ha ...
Facilities - Buffalo	Pembrk Fac	S4122 Ontario - WWTP pumphouse RBC and equipment	03/27/2014	2	2	1) F605.1 Abatement of electrical hazards. Identified electrical hazards shall be abated. Identified ha ... 2) PM504.1 General. All plumbing fixtures shall be properly installed and maintained in working order, ...
Facilities - Buffalo	Pembrk Fac	S4122 Ontario - WWTP pumphouse RBC and equipment	11/06/2014	0	0	
Facilities - Buffalo	Pembrk Fac	S4123 Ontario - WWTP storage 12 x 24	03/27/2014	0	0	
Facilities - Buffalo	Pembrk Fac	S4123 Ontario - WWTP storage 12 x 24	11/06/2014	0	0	
Facilities - Buffalo	Pembrk Fac	S4124 Ontario - garbage storage	11/06/2014	0	0	
Facilities - Buffalo	Pembrk Fac	S4130 Pembroke - gas station/TWY office	11/03/2014	4	0	1) F605.1 Abatement of electrical hazards. Identified electrical hazards shall be abated. Identified ha ...

						2) F605.1 Abatement of electrical hazards. Identified electrical hazards shall be abated. Identified ha ... 3) F901.6 Inspection, testing and maintenance. Fire detection, alarm and extinguishing systems shall be ... 4) F1011.5.2 Exit sign illumination. The face of an exit sign illuminated from an external source shall ...
Facilities - Buffalo	Pembrk Fac	S4131 Pembroke - generator building	11/03/2014	0	0	
Facilities - Buffalo	Pembrk Fac	S4132 Pembroke - WWTP pumphouse and equipment	03/25/2014	0	0	
Facilities - Buffalo	Pembrk Fac	S4132 Pembroke - WWTP pumphouse and equipment	11/03/2014	0	0	
Facilities - Buffalo	Pembrk Fac	S4133 Pembroke - WWTP storage 12 x 24	03/25/2014	3	0	1) F3404.3.2.1.1 Materials. Cabinets shall be listed in accordance with UL 1275, or constructed of appr ... 2) F1003.6 Means of egress continuity. The path of egress travel along a means of egress shall not be i ... 3) F605.1 Abatement of electrical hazards. Identified electrical hazards shall be abated. Identified ha ...
Facilities - Buffalo	Pembrk Fac	S4133 Pembroke - WWTP storage 12 x 24	11/03/2014	3	0	1) F3404.3.2.1.1 Materials. Cabinets shall be listed in accordance with UL 1275, or constructed of appr ... 2) F1003.6 Means of egress continuity. The path of egress travel along a means of egress shall not be i ... 3) F605.1 Abatement of electrical hazards. Identified electrical hazards shall be abated. Identified ha ...
Facilities - Buffalo	Pembrk Fac	S4134 Pembroke - trickling filter	03/25/2014	1	0	1) PM304.6 Exterior walls. All exterior walls shall be free from holes, breaks, and loose or rotting ma ...
Facilities - Buffalo	Pembrk Fac	S4134 Pembroke - trickling filter	11/03/2014	0	0	
Facilities - Buffalo	Pembrk Fac	S4135 Pembroke - WWTP final contact chamber	03/25/2014	0	0	
Facilities - Buffalo	Pembrk Fac	S4135 Pembroke - WWTP final contact chamber	11/03/2014	0	0	
Facilities - Buffalo	Pembrk Fac	S4136 Pembroke - Gas Station C-Store 24 x 41 Type VB	11/03/2014	2	0	1) F1011.5.2 Exit sign illumination. The face of an exit sign illuminated from an external source shall ... 2) P608.1 General. A potable water supply system shall be designed, installed and maintained in such a ...
Facilities - Buffalo	Pembrk Fac	S4140 Clarence - gas station/generator	11/07/2014	3	0	1) P608.1 General. A potable water supply system shall be designed, installed and maintained in such a ... 2) PM504.1 General. All plumbing fixtures shall be properly installed and maintained in working order, ... 3) F901.6 Inspection, testing and maintenance. Fire detection, alarm and extinguishing systems shall be ...
Facilities - Buffalo	Pembrk Fac	S4141 Clarence - WWTP pumphouse RBC and equipment	03/21/2014	5	0	1) F605.1 Abatement of electrical hazards. Identified electrical hazards shall be abated. Identified ha ... 2) F605.1 Abatement of electrical hazards. Identified electrical hazards shall be abated. Identified ha ... 3) PM505.4 Water heating facilities. Water heating facilities shall be properly installed, maintained a ... 4) F1009.1 Stairway width. The width of stairways shall be determined as specified in Section 1005.1, ... 5) F1009.10 Handrails. Stairways shall have handrails on each side and shall comply with Section 1012. ...
Facilities - Buffalo	Pembrk Fac	S4141 Clarence - WWTP pumphouse RBC and equipment	11/07/2014	5	0	1) F1009.1 Stairway width. The width of stairways shall be determined as specified in Section 1005.1, ... 2) F1009.10 Handrails. Stairways shall have handrails on each side and shall comply with Section 1012. ...

						3) F605.1 Abatement of electrical hazards. Identified electrical hazards shall be abated. Identified ha ... 4) F605.1 Abatement of electrical hazards. Identified electrical hazards shall be abated. Identified ha ... 5) P504.6 Requirements for discharge piping. The discharge piping serving a pressure relief valve, tem ...
Facilities - Buffalo	Pembrk Fac	S4142 Clarence - WWTP storage 12 x 24	03/21/2014	0	0	
Facilities - Buffalo	Pembrk Fac	S4142 Clarence - WWTP storage 12 x 24	11/07/2014	2	0	1) F901.6 Inspection, testing and maintenance. Fire detection, alarm and extinguishing systems shall be ... 2) F605.1 Abatement of electrical hazards. Identified electrical hazards shall be abated. Identified ha ...
Facilities - Buffalo	Pembrk Fac	S4143 Clarence - WWTP storage 8 x 12	03/21/2014	0	0	
Facilities - Buffalo	Pembrk Fac	S4143 Clarence - WWTP storage 8 x 12	11/07/2014	0	0	
Facilities - Buffalo	Pembrk Fac	S4144 Clarence - WWTP final contact chamber	03/21/2014	1	1	1) PM304.6 Exterior walls. All exterior walls shall be free from holes, breaks, and loose or rotting ma ...
Facilities - Buffalo	Pembrk Fac	S4144 Clarence - WWTP final contact chamber	11/07/2014	1	0	1) F1008.1.5 Landings at doors. Landings shall have a width not less than the width of the stairway or ...
Facilities - Buffalo	Pembrk Fac	Z4450 Fiber regeneration bldg - mp 365.8	10/01/2014	4	0	1) F608.7.1 Equipment room and building signage. Doors into electrical equipment rooms or buildings co ... 2) F901.6.2 Records. Records of all system inspections, tests, and maintenance required by the referenc ... 3) F605.5 Extension cords. Extension cords and flexible cords shall not be a substitute for permanent w ... 4) F901.6 Inspection, testing and maintenance. Fire detection, alarm and extinguishing systems shall be ...
Facilities - New York	Nwbrg Fac	C5572 Out of Service - Newburgh upper lot - storage wooden 12 x 24	08/18/2014	2	0	1) F304.1 Waste accumulation prohibited. Combustible waste material creating a fire hazard shall not be ... 2) F901.6 Inspection, testing and maintenance. Fire detection, alarm and extinguishing systems shall be ...
Facilities - New York	Nwbrg Fac	C5573 Out of Service - Newburgh upper lot - storage wooden 10 x 24	08/18/2014	2	0	1) F901.6 Inspection, testing and maintenance. Fire detection, alarm and extinguishing systems shall be ... 2) F304.1 Waste accumulation prohibited. Combustible waste material creating a fire hazard shall not be ...
Facilities - New York	Nwbrg Fac	M1731 Harriman Section - brick	08/26/2014	2	0	1) F901.6 Inspection, testing and maintenance. Fire detection, alarm and extinguishing systems shall be ... 2) PM304.15 Doors. All exterior doors, door assemblies and hardware shall be maintained in good conditi ...
Facilities - New York	Nwbrg Fac	M1732 Harriman Section - metal	08/26/2014	1	0	1) F901.6 Inspection, testing and maintenance. Fire detection, alarm and extinguishing systems shall be ...
Facilities - New York	Nwbrg Fac	M1733 Harriman Section - bathroom locker room trailer - Sloatsburg Tandem lot mp 32.1 nb	08/26/2014	0	0	
Facilities - New York	Nwbrg Fac	M1734 Harriman Section - salt storage bldg Hi Arch	08/26/2014	1	0	1) F901.6 Inspection, testing and maintenance. Fire detection, alarm and extinguishing systems shall be ...
Facilities - New York	Nwbrg Fac	M1735 Harriman Section - salt storage pole type	08/26/2014	1	0	1) F901.6 Inspection, testing and maintenance. Fire detection, alarm and extinguishing systems shall be ...
Facilities - New York	Nwbrg Fac	M1736 Harriman Section - equipment storage - pole 50 x 160	08/26/2014	1	0	1) F901.6 Inspection, testing and maintenance. Fire detection, alarm and extinguishing systems shall be ...
Facilities - New York	Nwbrg Fac	M1738 Harriman Section - sand/salt storage Hi Arch Sloatsburg Tandem Lot mp 32.1 nb	08/26/2014	0	0	
	Nwbrg Fac		08/26/2014	1	0	

Facilities - New York		M1739 Harriman Section - womens lockerroom trailer				1) F901.6 Inspection, testing and maintenance. Fire detection, alarm and extinguishing systems shall be ...
Facilities - New York	Nwbrg Fac	M1831 Newburgh Section - main maintenance complex building	08/19/2014	22	1	<p>1) F605.1 Abatement of electrical hazards. Identified electrical hazards shall be abated. Identified ha ...</p> <p>2) F901.6 Inspection, testing and maintenance. Fire detection, alarm and extinguishing systems shall be ...</p> <p>3) F605.1 Abatement of electrical hazards. Identified electrical hazards shall be abated. Identified ha ...</p> <p>4) PM307.1 Accumulation of rubbish or garbage. All exterior property and premises, and the interior of ...</p> <p>5) PM106.1 Maintenance. Equipment, systems, devices and safeguards required by this code or a previous ...</p> <p>6) F901.6.1 Standards. Fire protection systems shall be inspected, tested and maintained in accordance ...</p> <p>7) 312.9 Inspection and testing of backflow prevention assemblies. Inspection and testing shall comply ...</p> <p>8) F315.2 Storage in Buildings. Storage of combustible materials in buildings shall be orderly. Stora ...</p> <p>9) F315.2.1 Ceiling clearance. Storage shall be maintained 2 feet (610 mm) or more below the ceiling in ...</p> <p>10) F907.20 Inspection, testing and maintenance. The maintenance and testing schedules and procedures fo ...</p> <p>11) F315.2 Storage in Buildings. Storage of combustible materials in buildings shall be orderly. Stora ...</p> <p>12) 313.1 General. Fueled equipment, including but not limited to motorcycles, mopeds, lawn-care equ ...</p> <p>13) PM305.1 General. The interior of a structure and equipment therein shall be maintained in good repai ...</p> <p>14) F605.1 Abatement of electrical hazards. Identified electrical hazards shall be abated. Identified ha ...</p> <p>15) PM106.1 Maintenance. Equipment, systems, devices and safeguards required by this code or a previous ...</p> <p>16) F901.6 Inspection, testing and maintenance. Fire detection, alarm and extinguishing systems shall be ...</p> <p>17) F1011.2 Illumination. Exit signs shall be internally or externally illuminated. Exception: Tactil ...</p> <p>18) F901.6 Inspection, testing and maintenance. Fire detection, alarm and extinguishing systems shall be ...</p> <p>19) PM304.1 General. The exterior of a structure shall be maintained in good repair, structurally sound ...</p> <p>20) PM106.1 Maintenance. Equipment, systems, devices and safeguards required by this code or a previous ...</p> <p>21) F901.6 Inspection, testing and maintenance. Fire detection, alarm and extinguishing systems shall be ...</p> <p>22) 2204.3.5 Emergency procedures. An approved emergency procedures sign, in addition to the signs requ ...</p>
Facilities - New York	Nwbrg Fac	M1831 Newburgh Section - main maintenance complex building	08/19/2014	5	0	<p>1) F3404.3 Container and portable tank storage. Storage of flammable and combustible liquids in closed ...</p> <p>2) PM302.4 Weeds. All premises and immediate exterior property shall be maintained free from weeds or p ...</p> <p>3) F3404.3.4.4 Liquids for maintenance and operation of equipment. In all occupancies, quantities of fl ...</p> <p>4) F605.5 Extension cords. Extension cords</p>

						and flexible cords shall not be a substitute for permanent w ... 5) F315.2 Storage in Buildings. Storage of combustible materials in buildings shall be orderly. Stora ...
Facilities - New York	Nwbrg Fac	M1831 Newburgh Section - main maintenance complex building	08/19/2014	11	0	1) F605.1 Abatement of electrical hazards. Identified electrical hazards shall be abated. Identified ha ... 2) F605.3 Working space and clearance. A working space of not less than 30 inches (762 mm) in width, 36 ... 3) F901.6 Inspection, testing and maintenance. Fire detection, alarm and extinguishing systems shall be ... 4) F304.1 Waste accumulation prohibited. Combustible waste material creating a fire hazard shall not be ... 5) F1003.6 Means of egress continuity. The path of egress travel along a means of egress shall not be i ... 6) SECTION 411 EMERGENCY SHOWERS AND EYEWASH STATIONS 411.1 Approval. Where required, emergency s ... 7) F901.6 Inspection, testing and maintenance. Fire detection, alarm and extinguishing systems shall be ... 8) CHAPTER 30 ELEVATORS AND CONVEYING SYSTEMS SECTION 3001 GENERAL 3001.1 Scope. This chapte ... 9) PM305.1 General. The interior of a structure and equipment therein shall be maintained in good repai ... 10) F1003.6 Means of egress continuity. The path of egress travel along a means of egress shall not be i ... 11) PM106.1 Maintenance. Equipment, systems, devices and safeguards required by this code or a previous ...
Facilities - New York	Nwbrg Fac	M1832 Newburgh Section - metal - cold storage	08/18/2014	13	0	1) F901.6.2 Records. Records of all system inspections, tests, and maintenance required by the referenc ... 2) F1003.6 Means of egress continuity. The path of egress travel along a means of egress shall not be i ... 3) PM307.1 Accumulation of rubbish or garbage. All exterior property and premises, and the interior of ... 4) 3403.5 Labeling and signage. The code enforcement official is authorized to require warning signs f ... 5) F901.6 Inspection, testing and maintenance. Fire detection, alarm and extinguishing systems shall be ... 6) PM106.1 Maintenance. Equipment, systems, devices and safeguards required by this code or a previous ... 7) SECTION 411 EMERGENCY SHOWERS AND EYEWASH STATIONS 411.1 Approval. Where required, emergency s ... 8) F1011.2 Illumination. Exit signs shall be internally or externally illuminated. Exception: Tactil ... 9) F901.6 Inspection, testing and maintenance. Fire detection, alarm and extinguishing systems shall be ... 10) F901.6 Inspection, testing and maintenance. Fire detection, alarm and extinguishing systems shall be ... 11) PM307.1 Accumulation of rubbish or garbage. All exterior property and premises, and the interior of ... 12) PM106.1 Maintenance. Equipment, systems, devices and safeguards required by this code or a previous ... 13) F605.5 Extension cords. Extension cords and flexible cords shall not be a substitute for permanent w ...
Facilities - New York	Nwbrg Fac	M1833 Newburgh Section - abrasive storage Hi Arch - South	08/18/2014	2	0	1) F901.6 Inspection, testing and maintenance. Fire detection, alarm and

						extinguishing systems shall be ... 2) 505.3 Buildings utilizing truss-type construction. Buildings utilizing truss-type construction sha ...
Facilities - New York	Nwbrg Fac	M1834 Newburgh Section - abrasive storage Hi Arch - New Paltz	08/21/2014	3	0	1) F901.6 Inspection, testing and maintenance. Fire detection, alarm and extinguishing systems shall be ... 2) PM307.1 Accumulation of rubbish or garbage. All exterior property and premises, and the interior of ... 3) F901.6 Inspection, testing and maintenance. Fire detection, alarm and extinguishing systems shall be ...
Facilities - New York	Nwbrg Fac	M1835 Newburgh Section - vehicle storage and power plant	08/18/2014	2	0	1) F3403.5 Labeling and signage. The code enforcement official is authorized to require warning signs ... 2) PM307.1 Accumulation of rubbish or garbage. All exterior property and premises, and the interior of ...
Facilities - New York	Nwbrg Fac	M1835 Newburgh Section - vehicle storage and power plant	08/18/2014	8	0	1) PM106.2 Existing nonrequired equipment and systems. Whenever or wherever any nonrequired device, equ ... 2) F901.6 Inspection, testing and maintenance. Fire detection, alarm and extinguishing systems shall be ... 3) F605.1 Abatement of electrical hazards. Identified electrical hazards shall be abated. Identified ha ... 4) F605.1 Abatement of electrical hazards. Identified electrical hazards shall be abated. Identified ha ... 5) F901.6 Inspection, testing and maintenance. Fire detection, alarm and extinguishing systems shall be ... 6) 304.2 Protective treatment. All exterior surfaces, including but not limited to, doors, door and wi ... 7) F901.6 Inspection, testing and maintenance. Fire detection, alarm and extinguishing systems shall be ... 8) F605.1 Abatement of electrical hazards. Identified electrical hazards shall be abated. Identified ha ...
Facilities - New York	Nwbrg Fac	M1836 Newburgh Section - abrasive storage Hi Arch - North	08/18/2014	4	0	1) F605.1 Abatement of electrical hazards. Identified electrical hazards shall be abated. Identified ha ... 2) F901.6 Inspection, testing and maintenance. Fire detection, alarm and extinguishing systems shall be ... 3) 505.3 Buildings utilizing truss-type construction. Buildings utilizing truss-type construction sha ... 4) F304.1 Waste accumulation prohibited. Combustible waste material creating a hazard shall not be all ...
Facilities - New York	Nwbrg Fac	M1838 Newburgh Section - bathroom locker room trailer - New Paltz Interchange mp 76.01 nb	08/21/2014	5	0	1) PM304.4 Structural members. All structural members shall be maintained free from deterioration, and ... 2) F901.6 Inspection, testing and maintenance. Fire detection, alarm and extinguishing systems shall be ... 3) PM604.3 Electrical system hazards. Where it is found that the electrical system in a structure const ... 4) PM604.3 Electrical system hazards. Where it is found that the electrical system in a structure const ... 5) PM305.1 General. The interior of a structure and equipment therein shall be maintained in good repai ...
Facilities - New York	Nwbrg Fac	M1841 Newburgh Section - New Paltz storage wooden 8 x 16	08/21/2014	1	0	1) F901.6 Inspection, testing and maintenance. Fire detection, alarm and extinguishing systems shall be ...
Facilities - New York	Nwbrg Fac	M5542 Out of Service - Newburgh upper lot - wooden storage 8 x 16	08/18/2014	2	0	1) F901.6 Inspection, testing and maintenance. Fire detection, alarm and extinguishing systems shall be ... 2) F304.1 Waste accumulation prohibited.

						Combustible waste material creating a fire hazard shall not be ...
Facilities - New York	Nwbrg Fac	M5543 Out of Service - Newburgh upper lot - wooden storage 8 x 16	08/18/2014	2	0	1) F304.1 Waste accumulation prohibited. Combustible waste material creating a fire hazard shall not be ... 2) F901.6 Inspection, testing and maintenance. Fire detection, alarm and extinguishing systems shall be ...
Facilities - New York	Nwbrg Fac	P1203 Newburgh Barracks - Interchange 17	08/18/2014	13	0	1) F605.1 Abatement of electrical hazards. Identified electrical hazards shall be abated. Identified ha ... 2) F605.1 Abatement of electrical hazards. Identified electrical hazards shall be abated. Identified ha ... 3) F605.1 Abatement of electrical hazards. Identified electrical hazards shall be abated. Identified ha ... 4) PM106.1 Maintenance. Equipment, systems, devices and safeguards required by this code or a previous ... 5) F901.6 Inspection, testing and maintenance. Fire detection, alarm and extinguishing systems shall be ... 6) 312.9 Inspection and testing of backflow prevention assemblies. Inspection and testing shall comply ... 7) F901.6 Inspection, testing and maintenance. Fire detection, alarm and extinguishing systems shall be ... 8) PM307.1 Accumulation of rubbish or garbage. All exterior property and premises, and the interior of ... 9) PM302.4 Weeds. All premises and immediate exterior property shall be maintained free from weeds or p ... 10) PM307.1 Accumulation of rubbish or garbage. All exterior property and premises, and the interior of ... 11) PM106.1 Maintenance. Equipment, systems, devices and safeguards required by this code or a previous ... 12) PM603.1 Mechanical appliances. All mechanical appliances, fireplaces, solid fuel-burning appliances, ... 13) PM106.1 Maintenance. Equipment, systems, devices and safeguards required by this code or a previous ...
Facilities - New York	Nwbrg Fac	R5552 Out of Service - Harriman maintenance yard - Radio Shelter Building	08/18/2014	2	2	1) F304.1 Waste accumulation prohibited. Combustible waste material creating a fire hazard shall not be ... 2) F901.6 Inspection, testing and maintenance. Fire detection, alarm and extinguishing systems shall be ...
Facilities - New York	Nwbrg Fac	S1103 Ramapo - restaurant	08/19/2014	2	0	1) F901.6 Inspection, testing and maintenance. Fire detection, alarm and extinguishing systems shall be ... 2) F901.6.2 Records. Records of all system inspections, tests, and maintenance required by the referenc ...
Facilities - New York	Nwbrg Fac	S1104 Plattekill - restaurant	09/04/2014	63	1	1) 1106.5 Signage. Each accessible parking space shall be provided with signage displaying the intern ... 2) F605.5 Extension cords. Extension cords and flexible cords shall not be a substitute for permanent w ... 3) F1003.6 Means of egress continuity. The path of egress travel along a means of egress shall not be i ... 4) PM307.1 Accumulation of rubbish or garbage. All exterior property and premises, and the interior of ... 5) F304.1 Waste accumulation prohibited. Combustible waste material creating a fire hazard shall not be ... 6) PM106.1 Maintenance. Equipment, systems, devices and safeguards required by this code or a previous ... 7) F1003.6 Means of egress continuity. The path of egress travel along a means of

egress shall not be i ...

8) F901.6 Inspection, testing and maintenance. Fire detection, alarm and extinguishing systems shall be ...

9) F605.5 Extension cords. Extension cords and flexible cords shall not be a substitute for permanent w ...

10) F906.7 Hangers and brackets. Hand-held portable fire extinguishers, not housed in cabinets, shall be ...

11) PM305.1 General. The interior of a structure and equipment therein shall be maintained in good repair ...

12) F605.3 Working space and clearance. A working space of not less than 30 inches (762 mm) in width, 36 ...

13) F315.2.1 Ceiling clearance. Storage shall be maintained 2 feet (610 mm) or more below the ceiling in ...

14) F901.6 Inspection, testing and maintenance. Fire detection, alarm and extinguishing systems shall be ...

15) F605.3 Working space and clearance. A working space of not less than 30 inches (762 mm) in width, 36 ...

16) F605.5 Extension cords. Extension cords and flexible cords shall not be a substitute for permanent w ...

17) F605.5 Extension cords. Extension cords and flexible cords shall not be a substitute for permanent w ...

18) F315.2.1 Ceiling clearance. Storage shall be maintained 2 feet (610 mm) or more below the ceiling in ...

19) F901.6 Inspection, testing and maintenance. Fire detection, alarm and extinguishing systems shall be ...

20) F1003.6 Means of egress continuity. The path of egress travel along a means of egress shall not be i ...

21) F605.4 Multiplug adapters. Multiplug adapters, such as cube adapters, unfused plug strips or any oth ...

22) PM106.1 Maintenance. Equipment, systems, devices and safeguards required by this code or a previous ...

23) F1011.5.2 Exit sign illumination. The face of an exit sign illuminated from an external source shall ...

24) F901.6 Inspection, testing and maintenance. Fire detection, alarm and extinguishing systems shall be ...

25) F315.2 Storage in Buildings. Storage of combustible materials in buildings shall be orderly. Stora ...

26) PM604.3 Electrical system hazards. Where it is found that the electrical system in a structure const ...

27) F703.1 Maintenance. The required fire-resistance rating of fire-resistance-rated construction (inclu ...

28) F901.6 Inspection, testing and maintenance. Fire detection, alarm and extinguishing systems shall be ...

29) F901.6 Inspection, testing and maintenance. Fire detection, alarm and extinguishing systems shall be ...

30) PM604.3 Electrical system hazards. Where it is found that the electrical system in a structure const ...

31) F904.5 Wet-Chemical systems. Wet-chemical extinguishing systems shall be installed, maintained, per ...

32) F906.7 Hangers and brackets. Hand-held portable fire extinguishers, not housed in cabinets, shall be ...

33) F605.3 Working space and clearance. A working space of not less than 30 inches (762 mm) in width, 36 ...

- 34) PM106.1 Maintenance. Equipment, systems, devices and safeguards required by this code or a previous ...
- 35) PM106.1 Maintenance. Equipment, systems, devices and safeguards required by this code or a previous ...
- 36) F901.8 Removal of or tampering with equipment. It shall be prohibited for any person to remove, tamp ...
- 37) PM604.3 Electrical system hazards. Where it is found that the electrical system in a structure const ...
- 38) F901.6 Inspection, testing and maintenance. Fire detection, alarm and extinguishing systems shall be ...
- 39) F703.1 Maintenance. The required fire-resistance rating of fire-resistance-rated construction (inclu ...
- 40) F605.1 Abatement of electrical hazards. Identified electrical hazards shall be abated. Identified ha ...
- 41) PM106.1 Maintenance. Equipment, systems, devices and safeguards required by this code or a previous ...
- 42) F703.1 Maintenance. The required fire-resistance rating of fire-resistance-rated construction (inclu ...
- 43) F901.6 Inspection, testing and maintenance. Fire detection, alarm and extinguishing systems shall be ...
- 44) PM106.1 Maintenance. Equipment, systems, devices and safeguards required by this code or a previous ...
- 45) F605.5 Extension cords. Extension cords and flexible cords shall not be a substitute for permanent w ...
- 46) PM106.1 Maintenance. Equipment, systems, devices and safeguards required by this code or a previous ...
- 47) PM604.3 Electrical system hazards. Where it is found that the electrical system in a structure const ...
- 48) PM604.3 Electrical system hazards. Where it is found that the electrical system in a structure const ...
- 49) F906.7 Hangers and brackets. Hand-held portable fire extinguishers, not housed in cabinets, shall be ...
- 50) F901.6 Inspection, testing and maintenance. Fire detection, alarm and extinguishing systems shall be ...
- 51) F605.4 Multiplug adapters. Multiplug adaptors, such as cube adaptors, unfused plug strips or any oth ...
- 52) PM305.1 General. The interior of a structure and equipment therein shall be maintained in good repai ...
- 53) PM604.3 Electrical system hazards. Where it is found that the electrical system in a structure const ...
- 54) PM604.3 Electrical system hazards. Where it is found that the electrical system in a structure const ...
- 55) F901.6.2 Records. Records of all system inspections, tests, and maintenance required by the referenc ...
- 56) F605.5 Extension cords. Extension cords and flexible cords shall not be a substitute for permanent w ...
- 57) PM604.3 Electrical system hazards. Where it is found that the electrical system in a structure const ...
- 58) F901.6 Inspection, testing and maintenance. Fire detection, alarm and extinguishing systems shall be ...
- 59) F901.6 Inspection, testing and maintenance. Fire detection, alarm and extinguishing systems shall be ...
- 60) F901.6 Inspection, testing and

						<p>maintenance. Fire detection, alarm and extinguishing systems shall be ...</p> <p>61) PM106.1 Maintenance. Equipment, systems, devices and safeguards required by this code or a previous ...</p> <p>62) F1011.1 Where required. Exits and exit access doors shall be marked by an approved exit sign readily ...</p> <p>63) F605.1 Abatement of electrical hazards. Identified electrical hazards shall be abated. Identified ha ...</p>
Facilities - New York	Nwbrg Fac	S1105 Modena - restaurant	08/20/2014	64	0	<p>1) F901.6 Inspection, testing and maintenance. Fire detection, alarm and extinguishing systems shall be ...</p> <p>2) F901.6 Inspection, testing and maintenance. Fire detection, alarm and extinguishing systems shall be ...</p> <p>3) PM604.3 Electrical system hazards. Where it is found that the electrical system in a structure const ...</p> <p>4) F605.5 Extension cords. Extension cords and flexible cords shall not be a substitute for permanent w ...</p> <p>5) F605.6 Unapproved conditions. Open junction boxes and open-wiring splices shall be prohibited. App ...</p> <p>6) F901.6 Inspection, testing and maintenance. Fire detection, alarm and extinguishing systems shall be ...</p> <p>7) PM305.1 General. The interior of a structure and equipment therein shall be maintained in good repai ...</p> <p>8) PM305.1 General. The interior of a structure and equipment therein shall be maintained in good repai ...</p> <p>9) F1003.6 Means of egress continuity. The path of egress travel along a means of egress shall not be i ...</p> <p>10) F1011.2 Illumination. Exit signs shall be internally or externally illuminated. Exception: Tactil ...</p> <p>11) F605.3 Working space and clearance. A working space of not less than 30 inches (762 mm) in width, 36 ...</p> <p>12) F605.1 Abatement of electrical hazards. Identified electrical hazards shall be abated. Identified ha ...</p> <p>13) PM305.1 General. The interior of a structure and equipment therein shall be maintained in good repai ...</p> <p>14) PM604.3 Electrical system hazards. Where it is found that the electrical system in a structure const ...</p> <p>15) PM604.3 Electrical system hazards. Where it is found that the electrical system in a structure const ...</p> <p>16) PM106.1 Maintenance. Equipment, systems, devices and safeguards required by this code or a previous ...</p> <p>17) PM106.1 Maintenance. Equipment, systems, devices and safeguards required by this code or a previous ...</p> <p>18) PM106.1 Maintenance. Equipment, systems, devices and safeguards required by this code or a previous ...</p> <p>19) PM106.1 Maintenance. Equipment, systems, devices and safeguards required by this code or a previous ...</p> <p>20) PM106.1 Maintenance. Equipment, systems, devices and safeguards required by this code or a previous ...</p> <p>21) F605.3 Working space and clearance. A working space of not less than 30 inches (762 mm) in width, 36 ...</p> <p>22) PM505.4 Water heating facilities. Water heating facilities shall be properly installed, maintained a ...</p> <p>23) F605.5 Extension cords. Extension cords and flexible cords shall not be a substitute</p>

for permanent w ...

24) F1011.2 Illumination. Exit signs shall be internally or externally illuminated.  
Exception: Tactil ...

25) F906.7 Hangers and brackets. Hand-held portable fire extinguishers, not housed in cabinets, shall be ...

26) F901.6 Inspection, testing and maintenance. Fire detection, alarm and extinguishing systems shall be ...

27) F605.5 Extension cords. Extension cords and flexible cords shall not be a substitute for permanent w ...

28) PM106.2 Existing nonrequired equipment and systems. Whenever or wherever any nonrequired device, equ ...

29) PM603.1 Mechanical appliances. All mechanical appliances, fireplaces, solid fuel-burning appliances, ...

30) F605.3 Working space and clearance. A working space of not less than 30 inches (762 mm) in width, 36 ...

31) F1011.4 Internally illuminated exit signs. Internally illuminated exit signs shall be listed and lab ...

32) PM604.3 Electrical system hazards. Where it is found that the electrical system in a structure const ...

33) PM604.3 Electrical system hazards. Where it is found that the electrical system in a structure const ...

34) F605.6 Unapproved conditions. Open junction boxes and open-wiring splices shall be prohibited. App ...

35) PM106.2 Existing nonrequired equipment and systems. Whenever or wherever any nonrequired device, equ ...

36) F904.11.5 Portable fire extinguishers for commercial cooking equipment. Portable fire extinguishers ...

37) F901.6 Inspection, testing and maintenance. Fire detection, alarm and extinguishing systems shall be ...

38) F605.1 Abatement of electrical hazards. Identified electrical hazards shall be abated. Identified ha ...

39) F901.6 Inspection, testing and maintenance. Fire detection, alarm and extinguishing systems shall be ...

40) F1003.6 Means of egress continuity. The path of egress travel along a means of egress shall not be i ...

41) F605.6 Unapproved conditions. Open junction boxes and open-wiring splices shall be prohibited. App ...

42) F1011.2 Illumination. Exit signs shall be internally or externally illuminated.  
Exception: Tactil ...

43) F703.2.3 Door operation. Swinging fire doors shall close from the full-open position and latch autom ...

44) PM603.3 Clearances. All required clearances to combustible materials shall be maintained. (rev. 201 ...

45) F315.2.1 Ceiling clearance. Storage shall be maintained 2 feet (610 mm) or more below the ceiling in ...

46) ICC/Ansi A117.1 section, 606.6, Exposed pipes and surfaces. Water supply and drain pipes under lava ...

47) PM604.3 Electrical system hazards. Where it is found that the electrical system in a structure const ...

48) F605.3 Working space and clearance. A working space of not less than 30 inches (762 mm) in width, 36 ...

49) PM106.1 Maintenance. Equipment, systems, devices and safeguards required by this code or a previous ...

						<p>50) F605.4 Multiplug adapters. Multiplug adapters, such as cube adapters, unfused plug strips or any oth ...</p> <p>51) PM304.15 Doors. All exterior doors, door assemblies and hardware shall be maintained in good conditi ...</p> <p>52) F605.1 Abatement of electrical hazards. Identified electrical hazards shall be abated. Identified ha ...</p> <p>53) F605.3 Working space and clearance. A working space of not less than 30 inches (762 mm) in width, 36 ...</p> <p>54) F315.2.1 Ceiling clearance. Storage shall be maintained 2 feet (610 mm) or more below the ceiling in ...</p> <p>55) PM504.1 General. All plumbing fixtures shall be properly installed and maintained in working order, ...</p> <p>56) PM305.1 General. The interior of a structure and equipment therein shall be maintained in good repai ...</p> <p>57) PM304.1 General. The exterior of a structure shall be maintained in good repair, structurally sound ...</p> <p>58) PM106.1 Maintenance. Equipment, systems, devices and safeguards required by this code or a previous ...</p> <p>59) PM604.3 Electrical system hazards. Where it is found that the electrical system in a structure const ...</p> <p>60) F901.6.2 Records. Records of all system inspections, tests, and maintenance required by the referenc ...</p> <p>61) PM106.1 Maintenance. Equipment, systems, devices and safeguards required by this code or a previous ...</p> <p>62) F605.1 Abatement of electrical hazards. Identified electrical hazards shall be abated. Identified ha ...</p> <p>63) PM604.3 Electrical system hazards. Where it is found that the electrical system in a structure const ...</p> <p>64) F901.6 Inspection, testing and maintenance. Fire detection, alarm and extinguishing systems shall be ...</p>
Facilities - New York	Nwbrg Fac	S1107 Plattekill - metal storage	09/04/2014	2	0	<p>1) F906.7 Hangers and brackets. Hand-held portable fire extinguishers, not housed in cabinets, shall be ...</p> <p>2) F901.6 Inspection, testing and maintenance. Fire detection, alarm and extinguishing systems shall be ...</p>
Facilities - New York	Nwbrg Fac	S1121 Sloatsburg - generator	11/12/2014	0	0	
Facilities - New York	Nwbrg Fac	S1122 Sloatsburg - pumphouse (old) south of S/A	11/12/2014	0	0	
Facilities - New York	Nwbrg Fac	S1125 Sloatsburg - Gas Station C-Store 24 x 41 Type VB	11/12/2014	1	0	1) PM106.1 Maintenance. Equipment, systems, devices and safeguards required by this code or a previous ...
Facilities - New York	Nwbrg Fac	S1130 Ramapo - gas station/generator	08/19/2014	1	0	1) PM304.1 General. The exterior of a structure shall be maintained in good repair, structurally sound ...
Facilities - New York	Nwbrg Fac	S1131 Ramapo - generator	08/19/2014	0	0	
Facilities - New York	Nwbrg Fac	S1132 Ramapo - water meter pit Ballard Ave Town of Sloatsburg	08/19/2014	0	0	
Facilities - New York	Nwbrg Fac	S1134 Ramapo - WWTP pumphouse equipment and lagoon	08/19/2014	0	0	
Facilities - New York	Nwbrg Fac	S1135 Ramapo - WWTP storage woden 12 x 20 ...	08/19/2014	0	0	
Facilities - New York	Nwbrg Fac	S1140 Plattekill - gas station/TWY office	09/04/2014	6	0	<p>1) F315.2.1 Ceiling clearance. Storage shall be maintained 2 feet (610 mm) or more below the ceiling in ...</p> <p>2) F901.6 Inspection, testing and maintenance. Fire detection, alarm and extinguishing systems shall be ...</p> <p>3) PM604.3 Electrical system hazards. Where it is found that the electrical system in</p>

						a structure const ... 4) F605.5 Extension cords. Extension cords and flexible cords shall not be a substitute for permanent w ... 5) PM106.1 Maintenance. Equipment, systems, devices and safeguards required by this code or a previous ... 6) F703.1 Maintenance. The required fire-resistance rating of fire-resistance-rated construction (inclu ...
Facilities - New York	Nwbrg Fac	S1141 Plattekill - water treatment/pumphouse	09/04/2014	3	0	1) F901.6 Inspection, testing and maintenance. Fire detection, alarm and extinguishing systems shall be ... 2) 411.1 Approval. Where required, emergency showers and eyewash stations shall conform to ISEA Z358.1 ... 3) PM305.1 General. The interior of a structure and equipment therein shall be maintained in good repai ...
Facilities - New York	Nwbrg Fac	S1142 Plattekill - generator/storage	09/04/2014	5	0	1) F901.6 Inspection, testing and maintenance. Fire detection, alarm and extinguishing systems shall be ... 2) PM604.3 Electrical system hazards. Where it is found that the electrical system in a structure const ... 3) PM106.1 Maintenance. Equipment, systems, devices and safeguards required by this code or a previous ... 4) F1011.1 Where required. Exits and exit access doors shall be marked by an approved exit sign readily ... 5) PM304.1 General. The exterior of a structure shall be maintained in good repair, structurally sound ...
Facilities - New York	Nwbrg Fac	S1143 Plattekill - WWTP pumphouse RBCs & equipment	09/04/2014	9	0	1) F901.6 Inspection, testing and maintenance. Fire detection, alarm and extinguishing systems shall be ... 2) F901.6 Inspection, testing and maintenance. Fire detection, alarm and extinguishing systems shall be ... 3) PM604.3 Electrical system hazards. Where it is found that the electrical system in a structure const ... 4) F605.3 Working space and clearance. A working space of not less than 30 inches (762 mm) in width, 36 ... 5) PM505.4 Water heating facilities. Water heating facilities shall be properly installed, maintained a ... 6) PM604.3 Electrical system hazards. Where it is found that the electrical system in a structure const ... 7) PM604.3 Electrical system hazards. Where it is found that the electrical system in a structure const ... 8) PM304.7 Roofs and drainage. The roof and flashing shall be sound, tight and not have defects that ad ... 9) PM106.1 Maintenance. Equipment, systems, devices and safeguards required by this code or a previous ...
Facilities - New York	Nwbrg Fac	S1144 Plattekill - WWTP wooden storage 12 x 24	09/04/2014	1	0	1) F901.6 Inspection, testing and maintenance. Fire detection, alarm and extinguishing systems shall be ...
Facilities - New York	Nwbrg Fac	S1146 Plattekill - WWTP storage metal (old radio bldg)	09/04/2014	2	0	1) PM304.6 Exterior walls. All exterior walls shall be free from holes, breaks, and loose or rotting ma ... 2) PM305.1 General. The interior of a structure and equipment therein shall be maintained in good repai ...
Facilities - New York	Nwbrg Fac	S1147 Plattekill - WWTP sand filtration	09/04/2014	2	0	1) F906.7 Hangers and brackets. Hand-held portable fire extinguishers, not housed in cabinets, shall be ... 2) F901.6 Inspection, testing and maintenance. Fire detection, alarm and extinguishing systems shall be ...
Facilities - New York	Nwbrg Fac	S1148 Plattekill - WWTP chlorine shed 12 x 20	09/04/2014	2	0	1) F605.1 Abatement of electrical hazards. Identified electrical hazards shall be abated.

						Identified ha ... 2) PM604.3 Electrical system hazards. Where it is found that the electrical system in a structure const ...
Facilities - New York	Nwbrg Fac	S1149 Plattekil - Gas Station C-Store 24 x 41 Type VB	09/04/2014	5	0	1) PM106.1 Maintenance. Equipment, systems, devices and safeguards required by this code or a previous ... 2) PM106.1 Maintenance. Equipment, systems, devices and safeguards required by this code or a previous ... 3) 403.4 Required public toilet facilities. Customers, patrons and visitors shall be provided with pub ... 4) F904.6 Dry-chemical systems. Dry-chemical extinguishing systems shall be installed, maintained, per ... 5) F901.6 Inspection, testing and maintenance. Fire detection, alarm and extinguishing systems shall be ...
Facilities - New York	Nwbrg Fac	S1150 Modena - gas station/generator	08/21/2014	18	1	1) PM603.1 Mechanical appliances. All mechanical appliances, fireplaces, solid fuel-burning appliances, ... 2) F901.6.2 Records. Records of all system inspections, tests, and maintenance required by the referenc ... 3) 2205.2.2 Emergency shutoff valves. Automatic emergency shutoff valves required by Section 2206.7.4 ... 4) F901.6 Inspection, testing and maintenance. Fire detection, alarm and extinguishing systems shall be ... 5) PM106.1 Maintenance. Equipment, systems, devices and safeguards required by this code or a previous ... 6) PM106.1 Maintenance. Equipment, systems, devices and safeguards required by this code or a previous ... 7) F901.6 Inspection, testing and maintenance. Fire detection, alarm and extinguishing systems shall be ... 8) F605.6 Unapproved conditions. Open junction boxes and open-wiring splices shall be prohibited. Appro ... 9) PM106.1 Maintenance. Equipment, systems, devices and safeguards required by this code or a previous ... 10) F605.6 Unapproved conditions. Open junction boxes and open-wiring splices shall be prohibited. Appro ... 11) F703.1 Maintenance. The required fire-resistance rating of fire-resistance-rated construction (inclu ... 12) F901.6 Inspection, testing and maintenance. Fire detection, alarm and extinguishing systems shall be ... 13) F1011.2 Illumination. Exit signs shall be internally or externally illuminated. Exception: Tactil ... 14) F605.6 Unapproved conditions. Open junction boxes and open-wiring splices shall be prohibited. Appro ... 15) PM106.1 Maintenance. Equipment, systems, devices and safeguards required by this code or a previous ... 16) F906.7 Hangers and brackets. Hand-held portable fire extinguishers, not housed in cabinets, shall be ... 17) 403.4 Required public toilet facilities. Customers, patrons and visitors shall be provided with pub ... 18) F901.6.2 Records. Records of all system inspections, tests, and maintenance required by the referenc ...
Facilities - New York	Nwbrg Fac	S1151 Modena - garbage storage	09/02/2014	4	0	1) PM604.3 Electrical system hazards. Where it is found that the electrical system in a structure const ... 2) PM106.1 Maintenance. Equipment, systems, devices and safeguards required by this code or a previous ...

						3) 3403.5 Labeling and signage. The code enforcement official is authorized to require warning signs f ... 4) 3801.1 Scope. Storage, handling and transportation of liquefied petroleum gas (LP-gas) and the inst ...
Facilities - New York	Nwbrg Fac	S1152 Modena - WWTP pumphouse RBCs and equipment	09/04/2014	5	0	1) PM304.1 General. The exterior of a structure shall be maintained in good repair, structurally sound ... 2) F605.3 Working space and clearance. A working space of not less than 30 inches (762 mm) in width, 36 ... 3) F305.1 Clearance from ignition sources. Clearances between ignition sources, such as luminaires, he ... 4) PM505.4 Water heating facilities. Water heating facilities shall be properly installed, maintained a ... 5) PM106.1 Maintenance. Equipment, systems, devices and safeguards required by this code or a previous ...
Facilities - New York	Nwbrg Fac	S1153 Modena - WWTP wooden storage 12 x 24	09/04/2014	2	0	1) F906.7 Hangers and brackets. Hand-held portable fire extinguishers, not housed in cabinets, shall be ... 2) PM106.1 Maintenance. Equipment, systems, devices and safeguards required by this code or a previous ...
Facilities - New York	Nwbrg Fac	S1154 Modena - WWTP final contact chamber	09/04/2014	0	0	
Facilities - New York	Nwbrg Fac	S1155 Modena - WWTP sand filtration	09/04/2014	0	0	
Facilities - New York	Nwbrg Fac	T1716 Interchange 16 - Harriman Routes 6 and 17	08/26/2014	2	0	1) F901.6 Inspection, testing and maintenance. Fire detection, alarm and extinguishing systems shall be ... 2) PM304.15 Doors. All exterior doors, door assemblies and hardware shall be maintained in good conditi ...
Facilities - New York	Nwbrg Fac	T1717 Woodbury Barrier	08/26/2014	1	0	1) F901.6 Inspection, testing and maintenance. Fire detection, alarm and extinguishing systems shall be ...
Facilities - New York	Nwbrg Fac	T1817 Interchange 17 - Newburgh - I-84	08/20/2014	10	0	1) F901.6 Inspection, testing and maintenance. Fire detection, alarm and extinguishing systems shall be ... 2) F901.6 Inspection, testing and maintenance. Fire detection, alarm and extinguishing systems shall be ... 3) PM307.1 Accumulation of rubbish or garbage. All exterior property and premises, and the interior of ... 4) PM305.1 General. The interior of a structure and equipment therein shall be maintained in good repai ... 5) 308.1 Infestation. All structures shall be kept free from insect and rodent infestation. All struct ... 6) F901.6 Inspection, testing and maintenance. Fire detection, alarm and extinguishing systems shall be ... 7) F605.1 Abatement of electrical hazards. Identified electrical hazards shall be abated. Identified ha ... 8) F304.1 Waste accumulation prohibited. Combustible waste material creating a hazard shall not be all ... 9) 304.7 Roofs and drainage. The roof and flashing shall be sound, tight and not have defects that adm ... 10) PM305.1 General. The interior of a structure and equipment therein shall be maintained in good repai ...
Facilities - New York	Nwbrg Fac	T1817TB Interchange 17 - Newburgh Toll Utility Building	08/20/2014	10	0	1) F901.6 Inspection, testing and maintenance. Fire detection, alarm and extinguishing systems shall be ... 2) F901.6 Inspection, testing and maintenance. Fire detection, alarm and extinguishing systems shall be ... 3) PM307.1 Accumulation of rubbish or garbage. All exterior property and premises,

						<p>and the interior of ...</p> <p>4) PM305.1 General. The interior of a structure and equipment therein shall be maintained in good repair ...</p> <p>5) 308.1 Infestation. All structures shall be kept free from insect and rodent infestation. All struct ...</p> <p>6) F901.6 Inspection, testing and maintenance. Fire detection, alarm and extinguishing systems shall be ...</p> <p>7) F605.1 Abatement of electrical hazards. Identified electrical hazards shall be abated. Identified ha ...</p> <p>8) F304.1 Waste accumulation prohibited. Combustible waste material creating a hazard shall not be all ...</p> <p>9) 304.7 Roofs and drainage. The roof and flashing shall be sound, tight and not have defects that adm ...</p> <p>10) PM305.1 General. The interior of a structure and equipment therein shall be maintained in good repair ...</p>
Facilities - New York	Nwbrg Fac	T1817TN Interchange 17 - Newburgh Toll Entry Plaza and Walkway	08/20/2014	10	0	<p>1) F901.6 Inspection, testing and maintenance. Fire detection, alarm and extinguishing systems shall be ...</p> <p>2) F901.6 Inspection, testing and maintenance. Fire detection, alarm and extinguishing systems shall be ...</p> <p>3) PM307.1 Accumulation of rubbish or garbage. All exterior property and premises, and the interior of ...</p> <p>4) PM305.1 General. The interior of a structure and equipment therein shall be maintained in good repair ...</p> <p>5) 308.1 Infestation. All structures shall be kept free from insect and rodent infestation. All struct ...</p> <p>6) F901.6 Inspection, testing and maintenance. Fire detection, alarm and extinguishing systems shall be ...</p> <p>7) F605.1 Abatement of electrical hazards. Identified electrical hazards shall be abated. Identified ha ...</p> <p>8) F304.1 Waste accumulation prohibited. Combustible waste material creating a hazard shall not be all ...</p> <p>9) 304.7 Roofs and drainage. The roof and flashing shall be sound, tight and not have defects that adm ...</p> <p>10) PM305.1 General. The interior of a structure and equipment therein shall be maintained in good repair ...</p>
Facilities - New York	Nwbrg Fac	T1817TX Interchange 17 - Newburgh Toll Exit Plaza and Walkway	08/20/2014	10	0	<p>1) F901.6 Inspection, testing and maintenance. Fire detection, alarm and extinguishing systems shall be ...</p> <p>2) F901.6 Inspection, testing and maintenance. Fire detection, alarm and extinguishing systems shall be ...</p> <p>3) PM307.1 Accumulation of rubbish or garbage. All exterior property and premises, and the interior of ...</p> <p>4) PM305.1 General. The interior of a structure and equipment therein shall be maintained in good repair ...</p> <p>5) 308.1 Infestation. All structures shall be kept free from insect and rodent infestation. All struct ...</p> <p>6) F901.6 Inspection, testing and maintenance. Fire detection, alarm and extinguishing systems shall be ...</p> <p>7) F605.1 Abatement of electrical hazards. Identified electrical hazards shall be abated. Identified ha ...</p> <p>8) F304.1 Waste accumulation prohibited. Combustible waste material creating a hazard shall not be all ...</p> <p>9) 304.7 Roofs and drainage. The roof and flashing shall be sound, tight and not have defects that adm ...</p>

						10) PM305.1 General. The interior of a structure and equipment therein shall be maintained in good repair ...
Facilities - New York	Nwbrg Fac	T1818 Interchange 18 - New Paltz Route 199.	08/21/2014	5	0	1) F901.6 Inspection, testing and maintenance. Fire detection, alarm and extinguishing systems shall be ... 2) F605.1 Abatement of electrical hazards. Identified electrical hazards shall be abated. Identified ha ... 3) F605.1 Abatement of electrical hazards. Identified electrical hazards shall be abated. Identified ha ... 4) F304.1 Waste accumulation prohibited. Combustible waste material creating a fire hazard shall not be ... 5) 411.1 Approval. Where required, emergency showers and eyewash stations shall conform to ISEA Z358.1 ...
Facilities - New York	Nwbrg Fac	Z1751 Fiber regeneration bldg - mp 45.5	09/24/2014	3	0	1) F901.6.2 Records. Records of all system inspections, tests, and maintenance required by the referenc ... 2) PM604.3 Electrical system hazards. Where it is found that the electrical system in a structure const ... 3) F605.1 Abatement of electrical hazards. Identified electrical hazards shall be abated. Identified ha ...
Facilities - New York	Nwbrg Fac	Z1847 CNG fuel facility - Intch 18 (New Paltz)	08/21/2014	1	0	1) F901.6 Inspection, testing and maintenance. Fire detection, alarm and extinguishing systems shall be ...
Facilities - New York	Nwbrg Fac	Z1853 Fiber regeneration bldg - mp 76.6	09/24/2014	5	0	1) F901.6.2 Records. Records of all system inspections, tests, and maintenance required by the referenc ... 2) F605.1 Abatement of electrical hazards. Identified electrical hazards shall be abated. Identified ha ... 3) PM304.6 Exterior walls. All exterior walls shall be free from holes, breaks, and loose or rotting ma ... 4) PM304.7 Roofs and drainage. The roof and flashing shall be sound, tight and not have defects that ad ... 5) PM604.3 Electrical system hazards. Where it is found that the electrical system in a structure const ...
Facilities - New York	Nyack Fac	M1340 TZ Brdg Offices and Zone 1 DSP Headquarters - Tarrytown brick	09/30/2014	0	0	
Facilities - New York	Nyack Fac	M1342 Div Hwy - Nyack (T-111) office and garage	11/12/2014	0	0	
Facilities - New York	Nyack Fac	M1343 Div Stores/Bridge/Hwy - Nyack metal storage	11/04/2014	0	0	
Facilities - New York	Nyack Fac	M1344 Div Stores - Nyack metal storage	11/04/2014	0	0	
Facilities - New York	Nyack Fac	M1345 Div Bridge - Nyack metal office and shop	11/04/2014	0	0	
Facilities - New York	Nyack Fac	M1348 Div Bridge - Nyack metal storage container 40 x 8	11/04/2014	0	0	
Facilities - New York	Nyack Fac	M1350 Div Hazmat/Pesticide Storage - Nyack	09/25/2014	0	0	
Facilities - New York	Nyack Fac	M1351 Div Facilities - Nyack wooden storage	11/04/2014	0	0	
Facilities - New York	Nyack Fac	M1352 Div Equipment Mtce - Nyack wooden	11/04/2014	0	0	
Facilities - New York	Nyack Fac	M1353 Div - Nyack sand/salt storage Hi-Arch	12/08/2014	1	0	1) PM304.6 Exterior walls. All exterior walls shall be free from holes, breaks, and loose or rotting ma ...
Facilities - New York	Nyack Fac	M1354 Div - Nyack block cylinder storage 8 x 12	12/08/2014	0	0	
Facilities - New York	Nyack Fac	M1357 Division Equipment Maintenance - Nyack storage wooden 8 x 16	12/08/2014	0	0	
Facilities - New York	Nyack Fac	M1358 Div Stores - Nyack storage columnar pole	11/12/2014	2	0	1) PM304.2 Protective treatment. All exterior surfaces, including but not limited to, doors, door and w ... 2) PM106.1 Maintenance. Equipment, systems, devices and safeguards required by this code or a previous ...

Facilities - New York	Nyack Fac	M1361 Div Stores - Nyack concrete block	11/12/2014	0	0	
Facilities - New York	Nyack Fac	M1362 Div Hwy - Nyack mens restroom trailer	11/04/2014	0	0	
Facilities - New York	Nyack Fac	M1363 Div Hwy - Nyack wooden storage	11/04/2014	0	0	
Facilities - New York	Nyack Fac	M1364 Division Stores - storage trailer with deck - Nyack	11/04/2014	0	0	
Facilities - New York	Nyack Fac	M1365 Division Stores - storage trailer attached to M1364 deck - Nyack	11/04/2014	0	0	
Facilities - New York	Nyack Fac	M1366 Division Stores - storage trailer attached to M1364 deck - Nyack	11/04/2014	0	0	
Facilities - New York	Nyack Fac	M1369 Div Admin HQ - leased space 4 Executive Blvd Suffern	12/24/2014	0	0	
Facilities - New York	Nyack Fac	M1431 New England Section - brick	05/07/2014	3	0	1) F901.6 Inspection, testing and maintenance. Fire detection, alarm and extinguishing systems shall be ... 2) PM106.1 Maintenance. Equipment, systems, devices and safeguards required by this code or a previous ... 3) PM302.3 Sidewalks and driveways. All sidewalks, walkways, stairs, driveways, parking spaces and simi ...
Facilities - New York	Nyack Fac	M1432 New England Section - metal	05/07/2014	4	0	1) F901.6 Inspection, testing and maintenance. Fire detection, alarm and extinguishing systems shall be ... 2) F605.3 Working space and clearance. A working space of not less than 30 inches (762 mm) in width, 36 ... 3) F605.1 Abatement of electrical hazards. Identified electrical hazards shall be abated. Identified ha ... 4) PM603.3 Clearances. All required clearances to combustible materials shall be maintained. (rev. 201 ...
Facilities - New York	Nyack Fac	M1433 New England Section - sand/salt storage Hi-Arch	05/07/2014	3	0	1) F901.6 Inspection, testing and maintenance. Fire detection, alarm and extinguishing systems shall be ... 2) F304.1.2 Vegetation. Weeds, grass, vines or other growth that is capable of being ignited and endang ... 3) PM304.1 General. The exterior of a structure shall be maintained in good repair, structurally sound ...
Facilities - New York	Nyack Fac	M1436 New England Section - Toll Equipment New Rochelle Barrier	05/07/2014	0	0	
Facilities - New York	Nyack Fac	M1533 Nyack Section - abrasive storage at Yonkers Toll Barrier Hi Arch	05/12/2014	0	0	
Facilities - New York	Nyack Fac	M1534 Nyack Section - sand/salt storage Hi Arch	12/08/2014	0	0	
Facilities - New York	Nyack Fac	M1535 Nyack Section - Yonkers Toll Barrier storage shed	05/12/2014	0	0	
Facilities - New York	Nyack Fac	M1536 Nyack Section - office restroom trailer - Yonkers Toll Barrier mp 5.47 sb	05/12/2014	1	0	1) F901.6 Inspection, testing and maintenance. Fire detection, alarm and extinguishing systems shall be ...
Facilities - New York	Nyack Fac	M1632 TZ Bridge - metal and brick wrecker crew	08/14/2014	0	0	
Facilities - New York	Nyack Fac	M1633 TZ Bridge - movable barrier storage (east)	08/14/2014	0	0	
Facilities - New York	Nyack Fac	M1634 TZ Bridge - movable barrier storage (west)	08/14/2014	0	0	
Facilities - New York	Nyack Fac	M1637 TZ Bridge - block cylinder storage for movable Barrier	08/14/2014	0	0	
Facilities - New York	Nyack Fac	M1640 Tappan Zee Bridge - concrete block paint and storage shed 20 x 30	08/14/2014	1	1	1) PM106.1 Maintenance. Equipment, systems, devices and safeguards required by this code or a previous ...
Facilities - New York	Nyack Fac	M1645 Tappan Zee Bridge - equipment storage - wood - 12 x 16 - Dockside west	08/18/2014	0	0	
Facilities - New York	Nyack Fac	M1932 Cross Westchester Section - storage trailer	05/08/2014	1	0	1) F901.6 Inspection, testing and maintenance. Fire detection, alarm and extinguishing systems shall be ...
	Nyack Fac		05/08/2014	1	0	

Facilities - New York		M1933 Cross Westchester Section - mechanic storage trailer					1) F901.6 Inspection, testing and maintenance. Fire detection, alarm and extinguishing systems shall be ...
Facilities - New York	Nyack Fac	M1934 Cross Westchester Section - modular office/lunchroom/lockerroom	05/08/2014	1	0		1) F901.6 Inspection, testing and maintenance. Fire detection, alarm and extinguishing systems shall be ...
Facilities - New York	Nyack Fac	M1935 Cross Westchester Section - salt shed/garage	05/08/2014	1	0		1) F901.6 Inspection, testing and maintenance. Fire detection, alarm and extinguishing systems shall be ...
Facilities - New York	Nyack Fac	M1936 Cross Westchester Section - lockerroom wood Exit 10 East	05/08/2014	2	0		1) F901.6 Inspection, testing and maintenance. Fire detection, alarm and extinguishing systems shall be ... 2) PM304.7 Roofs and drainage. The roof and flashing shall be sound, tight and not have defects that ad ...
Facilities - New York	Nyack Fac	M1937 Cross Westchester Section - garage 30 x 24 Exit 10 East	05/08/2014	1	0		1) F901.6 Inspection, testing and maintenance. Fire detection, alarm and extinguishing systems shall be ...
Facilities - New York	Nyack Fac	M1939 Cross Westchester Section - wooden storage Exit 10 East	05/08/2014	0	0		
Facilities - New York	Nyack Fac	P1204 Larchmont Barracks - Maintenance Area	07/22/2014	0	0		
Facilities - New York	Nyack Fac	R1349 Radio Shelter Building - Taxter Rd Town of Greenburg Exit 8A	12/08/2014	1	0		1) F901.6 Inspection, testing and maintenance. Fire detection, alarm and extinguishing systems shall be ...
Facilities - New York	Nyack Fac	R1548 Radio Shelter Building - Ardsley SA mp 6.0 nb	08/20/2014	0	0		
Facilities - New York	Nyack Fac	R1553 Radio Shelter Building - Nyack Mtce yard mp 18.76 sb	12/08/2014	1	0		1) F901.6 Inspection, testing and maintenance. Fire detection, alarm and extinguishing systems shall be ...
Facilities - New York	Nyack Fac	R1741 Radio Shelter Building - Mahwah New Jersey Exit 15 mp 30	07/10/2014	1	0		1) F901.6 Inspection, testing and maintenance. Fire detection, alarm and extinguishing systems shall be ...
Facilities - New York	Nyack Fac	S1101 Ardsley - Restaurant/TWY Office	08/20/2014	0	0		
Facilities - New York	Nyack Fac	S1106 Ardsley - remediation shed	08/20/2014	0	0		
Facilities - New York	Nyack Fac	S1108 Ardsley - Gas Station storage	08/20/2014	0	0		
Facilities - New York	Nyack Fac	S1110 Ardsley Service Station	08/20/2014	0	0		
Facilities - New York	Nyack Fac	T1408 New Rochelle Barrier	05/07/2014	1	0		1) F901.6 Inspection, testing and maintenance. Fire detection, alarm and extinguishing systems shall be ...
Facilities - New York	Nyack Fac	T1409 New Rochelle Barrier - generator	05/07/2014	1	0		1) F901.6 Inspection, testing and maintenance. Fire detection, alarm and extinguishing systems shall be ...
Facilities - New York	Nyack Fac	T1506 Yonkers Barrier	05/12/2014	1	0		1) F901.6 Inspection, testing and maintenance. Fire detection, alarm and extinguishing systems shall be ...
Facilities - New York	Nyack Fac	T1507 Yonkers Barrier - ticket storage shed 10 x 12	05/12/2014	0	0		
Facilities - New York	Nyack Fac	T1509 Tarrytown Barrier (Tappan Zee Bridge)	08/14/2014	0	0		
Facilities - New York	Nyack Fac	T1514 Spring Valley Barrier	08/18/2014	0	0		
Facilities - New York	Nyack Fac	Z1546 Fiber regeneration bldg - mp 6.02	09/24/2014	4	0		1) F605.1 Abatement of electrical hazards. Identified electrical hazards shall be abated. Identified ha ... 2) PM302.3 Sidewalks and driveways. All sidewalks, walkways, stairs, driveways, parking spaces and simi ... 3) PM604.3 Electrical system hazards. Where it is found that the electrical system in a structure const ... 4) F901.6.2 Records. Records of all system inspections, tests, and maintenance required by the referenc ...
Facilities - Syracuse	JPonds Fac	M3731 Weedsport Section - brick	05/21/2014	1	0		1) PM304.15 Doors. All exterior doors, door assemblies and hardware shall be maintained in good condit ...
Facilities - Syracuse	JPonds Fac	M3732 Weedsport Section - metal	05/21/2014	3	0		1) PM304.15 Doors. All exterior doors, door assemblies and hardware shall be maintained in good condit ... 2) PM304.15 Doors. All exterior doors, door assemblies and hardware shall be

						maintained in good condit ... 3) PM304.4 Structural members. All structural members shall be maintained free from deterioration, and ...
Facilities - Syracuse	JPonds Fac	M3732 Weedsport Section - metal	05/21/2014	0	0	
Facilities - Syracuse	JPonds Fac	M3734 Weedsport Section - salt storage pole type	05/21/2014	0	0	
Facilities - Syracuse	JPonds Fac	M3735 Weedsport Section - sand/salt storage Hi Arch	05/21/2014	1	0	1) PM304.6 Exterior walls. All exterior walls shall be free from holes, breaks, and loose or rotting m ...
Facilities - Syracuse	JPonds Fac	M3736 Weedsport Section - abrasive storage Hi Arch Waterloo (Int 41)	05/19/2014	2	0	1) PM304.6 Exterior walls. All exterior walls shall be free from holes, breaks, and loose or rotting m ... 2) §F906.2 General requirements. Portable fire extinguishers shall be selected, installed and maintain ...
Facilities - Syracuse	JPonds Fac	M3737 Weedsport Section - equipment storage - pole 50 x 160	05/21/2014	0	0	
Facilities - Syracuse	JPonds Fac	M3831 Manchester Section - brick	05/13/2014	0	0	
Facilities - Syracuse	JPonds Fac	M3832 Manchester Section - metal	05/13/2014	2	0	1) 315.2.3 Equipment rooms. Combustible material shall not be stored in boiler rooms, mechanical rooms ... 2) F603 The furnaces need to be located 18 inches above the floor where exceptable to gasoline vapors. ...
Facilities - Syracuse	JPonds Fac	M3833 Manchester Section - salt storage	05/13/2014	1	0	1) PM305.2 Structural members. All structural members shall be maintained structurally sound, and be c ...
Facilities - Syracuse	JPonds Fac	M3834 Manchester Section - wood	05/13/2014	0	0	
Facilities - Syracuse	JPonds Fac	M3835 Manchester Section - salt storage pole type	05/13/2014	0	0	
Facilities - Syracuse	JPonds Fac	M3836 Manchester Section - abrasive storage Hi Arch	05/13/2014	1	0	1) FC604.4.2 Emergency Lighting Equipment. Emergency lighting systems shall be inspected and tested in ...
Facilities - Syracuse	JPonds Fac	M3841 Manchester Section - equipment storage - pole 50 x 160	05/13/2014	0	0	
Facilities - Syracuse	JPonds Fac	M3845 Junius Ponds Facilities - office/shop Junius Ponds SA mp 323.8 wb	03/03/2014	1	1	1) Record Keeping §F901.6.2 Records. Records of all system inspections, tests and maintenance require ...
Facilities - Syracuse	JPonds Fac	P3203 Junius Ponds Barracks - Junius Ponds Service Area	07/08/2014	3	0	1) FC703.1 Maintenance. The required fire-resistance rating of fire-resistance-rated construction (incl ... 2) §F603.6.2 Metal chimneys. Metal chimneys which are corroded or improperly supported shall be repaire ... 3) §F605.1 Abatement of electrical hazards. Identified electrical hazards shall be abated. Identified ...
Facilities - Syracuse	JPonds Fac	R3743 Radio Shelter Building - Port Byron Service Area mp 310.2 eb	05/21/2014	2	0	1) §F906.2 General requirements. Portable fire extinguishers shall be selected, installed and maintain ... 2) §F605.3 Working space and clearance. A working space of not less than 30 inches (762 mm) in width, 3 ...
Facilities - Syracuse	JPonds Fac	S3108 Port Byron - restaurant	03/19/2014	14	0	1) §F605.5 Extension cords. Extension cords and flexible cords shall not be a substitute for permanent ... 2) 603.1 Mechanical appliances. All mechanical appliances, fireplaces, solid fuel-burning appliances, ... 3) F605.3.1 Labeling. Doors into electrical control panel rooms shall be marked with a plainly visible ... 4) §F605.5 Extension cords. Extension cords and flexible cords shall not be a substitute for permanent ... 5) §F1011.3 Obstructions. A means of egress shall be free from obstructions that would prevent its use, ... 6) §F912.4 Signs. A metal sign with raised letters at least 1 inch (25 mm) in size shall be mounted on ... 7) F605.3.1 Labeling. Doors into electrical

						<p>control panel rooms shall be marked with a plainly visible ...</p> <p>8) §F605.4 Multiplug adapters. Multiplug adapters, such as cube adapters, unfused plug strips or any o ...</p> <p>9) F605.3.1 Labeling. Doors into electrical control panel rooms shall be marked with a plainly visible ...</p> <p>10) §F605.1 Abatement of electrical hazards. Identified electrical hazards shall be abated. Identified ...</p> <p>11) §F605.3 Working space and clearance. A working space of not less than 30 inches (762 mm) in width, 3 ...</p> <p>12) PM315.2 Storage in buildings. Storage of combustible materials in buildings shall be orderly. Stora ...</p> <p>13) §F604.3.2 Written record. Written records of the inspection, testing and maintenance of emergency a ...</p> <p>14) Record Keeping §F901.6.2 Records. Records of all system inspections, tests and maintenance require ...</p>
Facilities - Syracuse	JPonds Fac	S3109 Junius Ponds - restaurant	03/03/2014	7	0	<p>1) Record Keeping §F901.6.2 Records. Records of all system inspections, tests and maintenance require ...</p> <p>2) Egress §F1011.3 Obstructions. A means of egress shall be free from obstructions that would prevent ...</p> <p>3) Egress §F1011.3 Obstructions. A means of egress shall be free from obstructions that would prevent ...</p> <p>4) PM305.3 Interior surfaces. All interior surfaces, including windows and doors, shall be maintained ...</p> <p>5) PM304.1 Waste accumulation prohibited. Combustible waste material creating a fire hazard shall not ...</p> <p>6) PM304.1 Waste accumulation prohibited. Combustible waste material creating a fire hazard shall not ...</p> <p>7) §F605.1 Abatement of electrical hazards. Identified electrical hazards shall be abated. Identified ...</p>
Facilities - Syracuse	JPonds Fac	S3110 Clifton Springs - restaurant	02/27/2014	14	0	<p>1) §F605.4 Multiplug adapters. Multiplug adapters, such as cube adapters, unfused plug strips or any o ...</p> <p>2) §F605.3 Working space and clearance. A working space of not less than 30 inches (762 mm) in width, 3 ...</p> <p>3) PM305.1 General. The interior of a structure and equipment therein shall be maintained in good repa ...</p> <p>4) PM305.3 Interior surfaces. All interior surfaces, including windows and doors, shall be maintained ...</p> <p>5) 315.2.1 Ceiling clearance. Storage shall be maintained 2 feet (610 mm) or more below the ceiling in ...</p> <p>6) PM604.3 Electrical system hazards. Where it is found that the electrical system in a structure con ...</p> <p>7) 315.2.3 Equipment rooms. Combustible material shall not be stored in boiler rooms, mechanical rooms ...</p> <p>8) §F605.3 Working space and clearance. A working space of not less than 30 inches (762 mm) in width, 3 ...</p> <p>9) F901.6.1 Standards. Fire protection systems shall be inspected, tested and maintained in accordance ...</p> <p>10) PM604.3 Electrical system hazards. Where it is found that the electrical system in a structure con ...</p> <p>11) PM604.3 Electrical system hazards. Where it is found that the electrical system in a structure con ...</p> <p>12) §F912.4 Signs. A metal sign with raised letters at least 1 inch (25 mm) in size shall</p>

						be mounted ... 13) PM304.1 General. The exterior of a structure shall be maintained in good repair, structurally sound ... 14) Record Keeping §F901.6.2 Records. Records of all system inspections, tests and maintenance require ...
Facilities - Syracuse	JPonds Fac	S3111 Seneca - restaurant/gas station	02/26/2014	0	0	
Facilities - Syracuse	JPonds Fac	S3111 Seneca - restaurant/gas station	02/26/2014	19	0	1) §F605.1 Abatement of electrical hazards. Identified electrical hazards shall be abated. Identified ... 2) §F605.1 Abatement of electrical hazards. Identified electrical hazards shall be abated. Identified ... 3) §F605.5 Extension cords. Extension cords and flexible cords shall not be a substitute for permanent ... 4) §F1011.3 Obstructions. A means of egress shall be free from obstructions that would prevent its use, ... 5) §F314.3 Highly combustible goods. The display of highly combustible goods, including but not limited ... 6) §F605.3 Working space and clearance. A working space of not less than 30 inches (762 mm) in width, 3 ... 7) PM305.1 General. The interior of a structure and equipment therein shall be maintained in good repair ... 8) §F605.6 Unapproved conditions. Open junction boxes and open-wiring splices shall be prohibited. App ... 9) §F605.1 Abatement of electrical hazards. Identified electrical hazards shall be abated. Identified ... 10) F1011.2 Illumination. Exit signs shall be internally or externally illuminated. Exception: Tactil ... 11) PM304.11 Chimneys and towers. All chimneys, cooling towers, smoke stacks, and similar appurtenances ... 12) PM604.3 Electrical system hazards. Where it is found that the electrical system in a structure con ... 13) PM604.3 Electrical system hazards. Where it is found that the electrical system in a structure con ... 14) PM604.3 Electrical system hazards. Where it is found that the electrical system in a structure con ... 15) 904.2.1 Commercial hood and duct systems. Each required commercial kitchen exhaust hood and duct sy ... 16) PM404.7 Food preparation. All spaces to be occupied for food preparation purposes shall contain sui ... 17) §F912.4 Signs. A metal sign with raised letters at least 1 inch (25 mm) in size shall be mounted on ... 18) §F901.6.2 Records. Records of all system inspections, tests and maintenance required by the referen ... 19) §F901.6.2 Records. Records of all system inspections, tests and maintenance required by the referen ...
Facilities - Syracuse	JPonds Fac	S3111 Seneca - restaurant/gas station	08/04/2014	1	0	1) PM307.1 Accumulation of rubbish or garbage. All exterior property and premises, and the interior of ...
Facilities - Syracuse	JPonds Fac	S3124 Clifton Springs - metal	05/13/2014	1	0	1) PM304.6 Exterior walls. All exterior walls shall be free from holes, breaks, and loose or rotting m ...
Facilities - Syracuse	JPonds Fac	S3125 Seneca - metal	05/13/2014	0	0	
Facilities - Syracuse	JPonds Fac	S3161 Port Byron - gas station/generator	03/19/2014	0	0	
Facilities - Syracuse	JPonds Fac	S3161 Port Byron - gas station/generator	08/04/2014	2	0	1) §F906.2 General requirements. Portable fire extinguishers shall be selected, installed

						and maintain ... 2) No lock provided on the monitoring well that is located near the hand hole diamond plate cover. ...
Facilities - Syracuse	JPonds Fac	S3163 Port Byron - WWTP storage 10 x 12	05/21/2014	1	0	1) PM304.15 Doors. All exterior doors, door assemblies and hardware shall be maintained in good condit ...
Facilities - Syracuse	JPonds Fac	S3164 Port Byron - garbage storage	05/21/2014	2	0	1) §F605.6 Unapproved conditions. Open junction boxes and open-wiring splices shall be prohibited. A ... 2) F407 Hazardous materials. Lp storage tanks shall be maintained free from the accumulation of rust. ...
Facilities - Syracuse	JPonds Fac	S3165 Port Byron - WWTP pumphouse and equipment	05/21/2014	1	0	1) PM304.7 Roofs and drainage. The roof and flashing shall be sound, tight and not have defects that a ...
Facilities - Syracuse	JPonds Fac	S3166 Port Byron - WWTP final contact chamber	05/21/2014	1	0	1) PM304.15 Doors. All exterior doors, door assemblies and hardware shall be maintained in good condit ...
Facilities - Syracuse	JPonds Fac	S3168 Junius Ponds - gas station/TWY office	03/03/2014	1	0	1) Record Keeping §F901.6.2 Records. Records of all system inspections, tests and maintenance require ...
Facilities - Syracuse	JPonds Fac	S3168 Junius Ponds - gas station/TWY office	08/08/2014	0	0	
Facilities - Syracuse	JPonds Fac	S3170 Junius Ponds - WWTP pumphouse RBCs and equipment	05/19/2014	2	0	1) BOSH There is no weekly inspection being done on the eye wash station. No documentation on the tag ... 2) PM106.2 Existing nonrequired equipment and systems. Whenever or wherever any nonrequired device, e ...
Facilities - Syracuse	JPonds Fac	S3172 Clifton Springs - gas station/TWY office	02/27/2014	2	2	1) Record Keeping §F901.6.2 Records. Records of all system inspections, tests and maintenance require ... 2) Record Keeping §F901.6.2 Records. Records of all system inspections, tests and maintenance require ...
Facilities - Syracuse	JPonds Fac	S3173 Clifton Springs - generator/storage	08/08/2014	0	0	
Facilities - Syracuse	JPonds Fac	S3174 Clifton Springs - WWTP storage 10 x 12	05/19/2014	1	0	1) PM304.15 Doors. All exterior doors, door assemblies and hardware shall be maintained in good condit ...
Facilities - Syracuse	JPonds Fac	S3175 Clifton Springs - WWTP pumphouse and equipment	05/19/2014	0	0	
Facilities - Syracuse	JPonds Fac	S3184 Junius Ponds - WWTP storage 16 x 24	05/19/2014	0	0	
Facilities - Syracuse	JPonds Fac	T3740 Int 40 - Weedsport Route 34	05/07/2014	5	0	1) 907.4.4 Signs. Where fire alarm systems are not monitored by a supervising station, an approved per ... 2) §F605.1 Abatement of electrical hazards. Identified electrical hazards shall be abated. Identified ... 3) §F605.3.1 Labeling. Doors into electrical control panel rooms shall be marked with a plainly visi ... 4) §F605.3.1 Labeling. Doors into electrical control panel rooms shall be marked with a plainly visi ... 5) §F605.1 Abatement of electrical hazards. Identified electrical hazards shall be abated. Identified ...
Facilities - Syracuse	JPonds Fac	T3741 Int 41 - Waterloo Route 414	05/06/2014	3	0	1) §F605.1 Abatement of electrical hazards. Identified electrical hazards shall be abated. Identified ... 2) 907.4.4 Signs. Where fire alarm systems are not monitored by a supervising station, an approved per ... 3) §F605.3.1 Labeling. Doors into electrical control panel rooms shall be marked with a plainly visi ...
Facilities - Syracuse	JPonds Fac	T3828 Int 44 - Canandaigua toll storage shed	05/13/2014	0	0	
Facilities - Syracuse	JPonds Fac	T3842 Int 42 - Geneva Route 14	05/06/2014	2	0	1) §F605.1 Abatement of electrical hazards. Identified electrical hazards shall be abated. Identified ... 2) §F605.1 Abatement of electrical hazards. Identified electrical hazards shall be abated. Identified ...
	JPonds Fac		05/06/2014	4	0	

Facilities - Syracuse		T3843 Int 43 - Manchester Route 21				1) §F605.1 Abatement of electrical hazards. Identified electrical hazards shall be abated. Identified ... 2) 907.4.4 Signs. Where fire alarm systems are not monitored by a supervising station, an approved per ... 3) §F605.1 Abatement of electrical hazards. Identified electrical hazards shall be abated. Identified ... 4) Egress §F1011.3 Obstructions. A means of egress shall be free from obstructions that would prevent ...
Facilities - Syracuse	JPonds Fac	T3844 Int 44 - Canandaigua Route 332	05/13/2014	2	0	1) §F605.1 Abatement of electrical hazards. Identified electrical hazards shall be abated. Identified ... 2) §F605.1 Abatement of electrical hazards. Identified electrical hazards shall be abated. Identified ...
Facilities - Syracuse	JPonds Fac	Z3750 Fiber regeneration bldg - mp 320.7	10/14/2014	0	0	
Facilities - Syracuse	Syr Fac	M3341 Div Headquarters - brick	04/10/2014	19	0	1) 3503.1.2 Storage containers. Cylinders and pressure vessels for flammable gases shall be designed ... 2) 3503.1.2 Storage containers. Cylinders and pressure vessels for flammable gases shall be designed ... 3) PM305.5 Handrails and guards. Every handrail and guard shall be firmly fastened and capable of supp ... 4) Inspect eye wash station weekly and record. ... 5) §F605.1 Abatement of electrical hazards. Identified electrical hazards shall be abated. Identified ... 6) 2701.3.3.2 Reliability of equipment and operations. Equipment and operations involving hazardous ma ... 7) 315.2.2 Means of egress. Combustible materials shall not be stored in exits or exit enclosures. ... 8) 315.2.2 Means of egress. Combustible materials shall not be stored in exits or exit enclosures. ... 9) §F605.3 Working space and clearance. A working space of not less than 30 inches (762 mm) in width, 3 ... 10) Eye wash station shall be inspected weekly and a record kept. ... 11) 3404.1 General. The storage of flammable and combustible liquids in containers and tanks shall be i ... 12) PM305.6 Interior doors. Every interior door shall fit reasonably well within its frame and shall be ... 13) Eye wash station does not meet regulations. ... 14) 703.2 Opening protectives. Opening protectives shall be maintained in an operative condition in acc ... 15) 703.2 Opening protectives. Opening protectives shall be maintained in an operative condition in acc ... 16) §F605.5 Extension cords. Extension cords and flexible cords shall not be a substitute for permanent ... 17) 3404.1 General. The storage of flammable and combustible liquids in containers and tanks shall be i ... 18) 3404.1 General. The storage of flammable and combustible liquids in containers and tanks shall be i ... 19) 304.3.1 Spontaneous ignition. Materials susceptible to spontaneous ignition, such as oily rags, sha ...
Facilities - Syracuse	Syr Fac	M3342 Div Headquarters - metal	04/10/2014	0	0	
Facilities - Syracuse	Syr Fac	M3343 Div Bridge - cold storage pole type	04/10/2014	0	0	

Facilities - Syracuse	Syr Fac	M3344 Div Headquarters - storage metal	04/10/2014	13	0	<p>1) Lp cylinders are not secured. ...</p> <p>2) PM315.2 Storage in buildings. Storage of combustible materials in buildings shall be orderly. Stora ...</p> <p>3) Loft Area - broken chains, missing toe boards and load capacity not posted. ...</p> <p>4) PM315.2 Storage in buildings. Storage of combustible materials in buildings shall be orderly. Stora ...</p> <p>5) PM305.5 Handrails and guards. Every handrail and guard shall be firmly fastened and capable of supp ...</p> <p>6) PM305.4 Stairs and walking surfaces. Every stair, ramp, landing, balcony, porch, deck or other walk ...</p> <p>7) 310.2 Prohibited areas. Smoking shall be prohibited where conditions are such as to make smoking a ...</p> <p>8) 3404.1 General. The storage of flammable and combustible liquids in containers and tanks shall b ...</p> <p>9) F906.6 Unobstructed and unobscured. Portable fire extinguishers shall not be obstructed or obscured ...</p> <p>10) F906.6 Unobstructed and unobscured. Portable fire extinguishers shall not be obstructed or obscured ...</p> <p>11) PM305.5 Handrails and guards. Every handrail and guard shall be firmly fastened and capable of supp ...</p> <p>12) Storage of LP gas inside of buildings prohibited. ...</p> <p>13) PM315.2 Storage in buildings. Storage of combustible materials in buildings shall be orderly. Stora ...</p>
Facilities - Syracuse	Syr Fac	M3345 Div Facilities - concrete block	04/10/2014	6	0	<p>1) PM315.2 Storage in buildings. Storage of combustible materials in buildings shall be orderly. Stora ...</p> <p>2) §F605.3 Working space and clearance. A working space of not less than 30 inches (762 mm) in width, 3 ...</p> <p>3) F1011.2 Illumination. Exit signs shall be internally or externally illuminated. Exception: Tactil ...</p> <p>4) §F605.3 Working space and clearance. A working space of not less than 30 inches (762 mm) in width, 3 ...</p> <p>5) §F906.2 General requirements. Portable fire extinguishers shall be selected, installed and maintain ...</p> <p>6) Maintain the first aid kit. ...</p>
Facilities - Syracuse	Syr Fac	M3347 Div Headquarters - acetylene/oxygen storage	04/10/2014	1	0	<p>1) F3404.3 Container and portable tank storage. Storage of flammable and combustible liquids in closed ...</p>
Facilities - Syracuse	Syr Fac	M3348 Div Headquarters - metal	04/10/2014	2	0	<p>1) No eye wash station ...</p> <p>2) §F605.3 Working space and clearance. A working space of not less than 30 inches (762 mm) in width, 3 ...</p>
Facilities - Syracuse	Syr Fac	M3348 Div Headquarters - metal	04/10/2014	7	0	<p>1) Eye Wash Station not inspected properly. ...</p> <p>2) No MSDS book in the shop. ...</p> <p>3) F304.1 Waste accumulation prohibited. Combustible waste material creating a fire hazard shall not be ...</p> <p>4) §F906.2 General requirements. Portable fire extinguishers shall be selected, installed and maintain ...</p> <p>5) 603.1 Mechanical appliances. All mechanical appliances, fireplaces, solid fuel-burning appliances, ...</p> <p>6) First Aid Kit must be mounted and maintained. ...</p> <p>7) PM305.1 General. The interior of a structure and equipment therein shall be maintained in good repai ...</p>
Facilities - Syracuse	Syr Fac	M3349 Div Bridge - concrete block	04/10/2014	4	0	<p>1) §F605.6 Unapproved conditions. Open junction boxes and open-wiring splices shall be prohibited. App ...</p> <p>2) Lock-out tag-out not being used properly.</p>

						... 3) §F906.2 General requirements. Portable fire extinguishers shall be selected, installed and maintain ... 4) Eye wash station not being inspected weekly. ...
Facilities - Syracuse	Syr Fac	M3350 Div Bridge - pole barn	04/10/2014	2	0	1) 310.2 Prohibited areas. Smoking shall be prohibited where conditions are such as to make smoking a ... 2) PM315.2 Storage in buildings. Storage of combustible materials in buildings shall be orderly. Stora ...
Facilities - Syracuse	Syr Fac	M3351 Div Stores - timber column	04/10/2014	0	0	
Facilities - Syracuse	Syr Fac	M3354 Div Headquarters - block/metal garage	04/10/2014	0	0	
Facilities - Syracuse	Syr Fac	M3354 Div Headquarters - block/metal garage	04/10/2014	2	0	1) 3503.1.2 Storage containers. Cylinders and pressure vessels for flammable gases shall be designed, ... 2) Eye wash station is not being tested when inspected. ...
Facilities - Syracuse	Syr Fac	M3362 Div Stores - metal storage	04/10/2014	1	0	1) §F906.2 General requirements. Portable fire extinguishers shall be selected, installed and maintain ...
Facilities - Syracuse	Syr Fac	M3633 Syracuse Section - sand/salt storage Hi Arch DeWitt SA mp 279.5 eb	05/29/2014	2	0	1) §F906.2 General requirements. Portable fire extinguishers shall be selected, installed and maintain ... 2) §F906.2 General requirements. Portable fire extinguishers shall be selected, installed and maintain ...
Facilities - Syracuse	Syr Fac	M3639 Syracuse Section - abrasive storage Hi Arch Chittenango SA mp 266 wb	05/30/2014	0	0	
Facilities - Syracuse	Syr Fac	M3640 Syracuse Section - sand/salt storage Hi Arch DeWitt SA mp 279.5 eb	05/29/2014	2	0	1) §F906.2 General requirements. Portable fire extinguishers shall be selected, installed and maintain ... 2) §F605.3 Working space and clearance. A working space of not less than 30 inches (762 mm) in width, 3 ...
Facilities - Syracuse	Syr Fac	M3643 Syracuse Section - sand/salt storage Old State Fair Intch mp 288.6 eb	05/30/2014	0	0	
Facilities - Syracuse	Syr Fac	S3105 Chittenango - restaurant	03/25/2014	10	0	1) §F605.1 Abatement of electrical hazards. Identified electrical hazards shall be abated. Identified ... 2) Egress §F1011.3 Obstructions. A means of egress shall be free from obstructions that would prevent ... 3) §F605.3 Working space and clearance. A working space of not less than 30 inches (762 mm) in width, 3 ... 4) §F605.3 Working space and clearance. A working space of not less than 30 inches (762 mm) in width, 3 ... 5) §F605.1 Abatement of electrical hazards. Identified electrical hazards shall be abated. Identified ... 6) §F605.1 Abatement of electrical hazards. Identified electrical hazards shall be abated. Identified ... 7) PM305.3 Interior surfaces. All interior surfaces, including windows and doors, shall be maintained ... 8) 912.2.2 Existing buildings. On existing buildings, wherever the fire department connection is not v ... 9) §F603.6 Chimneys and appliances. Chimneys, incinerators, smokestacks or similar devices for conveyin ... 10) §F605.1 Abatement of electrical hazards. Identified electrical hazards shall be abated. Identified ...
Facilities - Syracuse	Syr Fac	S3106 DeWitt - restaurant	03/25/2014	8	6	1) §F605.6 Unapproved conditions. Open junction boxes and open-wiring splices shall be prohibited. App ... 2) §F605.5 Extension cords. Extension cords and flexible cords shall not be a substitute for permanent ...

						<p>3) 603.1 Mechanical appliances. All mechanical appliances, fireplaces, solid fuel-burning appliances, ...</p> <p>4) 315.2.1 Ceiling clearance. Storage shall be maintained 2 feet (610 mm) or more below the ceiling in ...</p> <p>5) §F605.1 Abatement of electrical hazards. Identified electrical hazards shall be abated. Identified ...</p> <p>6) §F605.3 Working space and clearance. A working space of not less than 30 inches (762 mm) in width, 3 ...</p> <p>7) §F605.3 Working space and clearance. A working space of not less than 30 inches (762 mm) in width, 3 ...</p> <p>8) PM305.3 Interior surfaces. All interior surfaces, including windows and doors, shall be maintained ...</p>
Facilities - Syracuse	Syr Fac	S3107 Warners - restaurant	03/24/2014	11	7	<p>1) F605.1 Abatement of electrical hazards. Identified electrical hazards shall be abated. Identified ha ...</p> <p>2) F605.1 Abatement of electrical hazards. Identified electrical hazards shall be abated. Identified ha ...</p> <p>3) §F605.5 Extension cords. Extension cords and flexible cords shall not be a substitute for permanent ...</p> <p>4) §F605.5 Extension cords. Extension cords and flexible cords shall not be a substitute for permanent ...</p> <p>5) §F605.6 Unapproved conditions. Open junction boxes and open-wiring splices shall be prohibited. App ...</p> <p>6) §F605.1 Abatement of electrical hazards. Identified electrical hazards shall be abated. Identified ...</p> <p>7) PM305.1 General. The interior of a structure and equipment therein shall be maintained in good repa ...</p> <p>8) §F605.3 Working space and clearance. A working space of not less than 30 inches (762 mm) in width, 3 ...</p> <p>9) PM305.1 General. The interior of a structure and equipment therein shall be maintained in good repa ...</p> <p>10) PM315.2 Storage in buildings. Storage of combustible materials in buildings shall be orderly. Stora ...</p> <p>11) §F906.2 General requirements. Portable fire extinguishers shall be selected, installed and maintain ...</p>
Facilities - Syracuse	Syr Fac	S3147 Chittenango - gas station/TWY office	03/25/2014	0	0	
Facilities - Syracuse	Syr Fac	S3147 Chittenango - gas station/TWY office	08/19/2014	1	0	1) §F906.2 General requirements. Portable fire extinguishers shall be selected, installed and maintain ...
Facilities - Syracuse	Syr Fac	S3150 Chittenango - WWTP pumphouse and equipment	05/30/2014	1	0	1) FC1011.1 Where required. Exits and exit access doors shall be marked by an approved exit sign readi ...
Facilities - Syracuse	Syr Fac	S3153 DeWitt - gas station/generator	03/25/2014	2	0	<p>1) §F605.6 Unapproved conditions. Open junction boxes and open-wiring splices shall be prohibited. App ...</p> <p>2) §F605.3 Working space and clearance. A working space of not less than 30 inches (762 mm) in width, 3 ...</p>
Facilities - Syracuse	Syr Fac	S3153 DeWitt - gas station/generator	08/19/2014	1	0	1) §F906.2 General requirements. Portable fire extinguishers shall be selected, installed and maintain ...
Facilities - Syracuse	Syr Fac	S3155 Warners - gas station/generator	03/24/2014	0	0	
Facilities - Syracuse	Syr Fac	S3155 Warners - gas station/generator	08/04/2014	2	0	<p>1) §F906.2 General requirements. Portable fire extinguishers shall be selected, installed and maintain ...</p> <p>2) §F2204.2.4 Obstructions to view. Dispensing devices shall be in clear view of the attendant at all ...</p>
Facilities - Syracuse	Syr Fac	S3158 Warners - WWTP pumphouse and equipment	05/26/2014	1	0	

						1) FC1011.1 Where required. Exits and exit access doors shall be marked by an approved exit sign readi ...
Facilities - Syracuse	Syr Fac	S3182 Chittenango - WWTP storage 10 x 12	05/29/2014	1	0	1) §F906.2 General requirements. Portable fire extinguishers shall be selected, installed and maintain ...
Facilities - Syracuse	Syr Fac	T3634 Int 34A - Syracuse I-481 (Collamer)	05/29/2014	0	0	
Facilities - Syracuse	Syr Fac	T3635 Int 35 - Syracuse Route 298 (Thompson Rd)	05/29/2014	0	0	
Facilities - Syracuse	Syr Fac	T3636 Int 36 - Syracuse I-81 (Mattydale)	05/29/2014	0	0	
Facilities - Syracuse	Syr Fac	T3637 Int 37 - Electronics Parkway	05/07/2014	5	0	1) §F605.3.1 Labeling. Doors into electrical control panel rooms shall be marked with a plainly visi ... 2) §F605.3.1 Labeling. Doors into electrical control panel rooms shall be marked with a plainly visi ... 3) 907.4.4 Signs. Where fire alarm systems are not monitored by a supervising station, an approved per ... 4) FC1011.1 Where required. Exits and exit access doors shall be marked by an approved exit sign readi ... 5) PM305.4 Stairs and walking surfaces. Every stair, ramp, landing, balcony, porch, deck or other walk ...
Facilities - Syracuse	Syr Fac	T3638 Int 38 - Liverpool Route 57	05/07/2014	6	0	1) 907.4.4 Signs. Where fire alarm systems are not monitored by a supervising station, an approved per ... 2) FC1011.1 Where required. Exits and exit access doors shall be marked by an approved exit sign readi ... 3) §F605.1 Abatement of electrical hazards. Identified electrical hazards shall be abated. Identified ... 4) §F605.3.1 Labeling. Doors into electrical control panel rooms shall be marked with a plainly visi ... 5) §F605.3.1 Labeling. Doors into electrical control panel rooms shall be marked with a plainly visi ... 6) §F605.1 Abatement of electrical hazards. Identified electrical hazards shall be abated. Identified ...
Facilities - Syracuse	Syr Fac	T3739 Int 39 - Syracuse I-690 (State Fair)	05/07/2014	7	0	1) 907.4.4 Signs. Where fire alarm systems are not monitored by a supervising station, an approved per ... 2) 907.4.4 Signs. Where fire alarm systems are not monitored by a supervising station, an approved p ... 3) FC1011.1 Where required. Exits and exit access doors shall be marked by an approved exit sign readi ... 4) §F605.1 Abatement of electrical hazards. Identified electrical hazards shall be abated. Identified ... 5) §F605.1 Abatement of electrical hazards. Identified electrical hazards shall be abated. Identified ... 6) §F605.1 Abatement of electrical hazards. Identified electrical hazards shall be abated. Identified ... 7) §F605.3.1 Labeling. Doors into electrical control panel rooms shall be marked with a plainly visi ...
Facilities - Syracuse	Syr Fac	Z3654 Fiber regeneration bldg - mp 283.1	09/23/2014	0	0	
Facilities - Syracuse	Utica Fac	M3432 Herkimer Section - sand/salt storage Hi Arch	05/29/2014	1	0	1) §F906.2 General requirements. Portable fire extinguishers shall be selected, installed and maintain ...
Facilities - Syracuse	Utica Fac	M3433 Herkimer Section - salt storage pole type	05/29/2014	0	0	
Facilities - Syracuse	Utica Fac	M3435 Herkimer Section - brick	05/29/2014	0	0	
Facilities - Syracuse	Utica Fac	M3436 Herkimer Section - metal	05/29/2014	0	0	
	Utica Fac	M3436 Herkimer Section - metal	05/29/2014	0	0	

Facilities - Syracuse						
Facilities - Syracuse	Utica Fac	M3437 Herkimer Section - equipment storage - pole 50 x 160	05/29/2014	0	0	
Facilities - Syracuse	Utica Fac	M3439 Herkimer Section - sand/salt storage Hi Arch Little Falls (Int 29A)	05/29/2014	1	0	1) FC505.1 Address numbers. New and existing buildings shall have approved address numbers, building n ...
Facilities - Syracuse	Utica Fac	M3440 Utica Facilities - office/shop/lockerroom Utica (Int 31)	04/07/2014	1	0	1) §F605.1 Abatement of electrical hazards. Identified electrical hazards shall be abated. Identified ...
Facilities - Syracuse	Utica Fac	M3442 Herkimer Section - abrasive storage Hi Arch Utica (Int 31)	04/07/2014	0	0	
Facilities - Syracuse	Utica Fac	M3535 Verona Section - brick	05/29/2014	1	0	1) §F906.2 General requirements. Portable fire extinguishers shall be selected, installed and maintain ...
Facilities - Syracuse	Utica Fac	M3535 Verona Section - brick	08/12/2014	1	0	1) Eye wash station requires weekly visual inspection and testing. ...
Facilities - Syracuse	Utica Fac	M3536 Verona Section - metal	05/29/2014	1	0	1) §F906.2 General requirements. Portable fire extinguishers shall be selected, installed and maintain ...
Facilities - Syracuse	Utica Fac	M3536 Verona Section - metal	05/29/2014	1	0	1) §F906.2 General requirements. Portable fire extinguishers shall be selected, installed and maintain ...
Facilities - Syracuse	Utica Fac	M3536 Verona Section - metal	08/12/2014	0	0	
Facilities - Syracuse	Utica Fac	M3539 Verona Section - salt storage pole type	05/29/2014	0	0	
Facilities - Syracuse	Utica Fac	M3539 Verona Section - salt storage pole type	08/12/2014	1	0	1) PM304.6 Exterior walls. All exterior walls shall be free from holes, breaks, and loose or rotting m ...
Facilities - Syracuse	Utica Fac	M3542 Verona Section - timber column storage	08/12/2014	0	0	
Facilities - Syracuse	Utica Fac	M3545 Verona Section - remediation	08/12/2014	0	0	
Facilities - Syracuse	Utica Fac	M3546 Verona Section - sand/salt storage Hi Arch	05/29/2014	2	0	1) §F906.2 General requirements. Portable fire extinguishers shall be selected, installed and maintain ... 2) PM604.3 Electrical system hazards. Where it is found that the electrical system in a structure con ...
Facilities - Syracuse	Utica Fac	M3546 Verona Section - sand/salt storage Hi Arch	08/12/2014	0	0	
Facilities - Syracuse	Utica Fac	M3547 Verona Section - vehicle storage	05/29/2014	0	0	
Facilities - Syracuse	Utica Fac	M3547 Verona Section - vehicle storage	08/12/2014	0	0	
Facilities - Syracuse	Utica Fac	P3201 Schuyler Barracks - Schuyler Service Area	07/09/2014	6	0	1) §F906.2 General requirements. Portable fire extinguishers shall be selected, installed and maintain ... 2) §F605.1 Abatement of electrical hazards. Identified electrical hazards shall be abated. Identified ... 3) §F605.1 Abatement of electrical hazards. Identified electrical hazards shall be abated. Identified ... 4) PM304.11 Chimneys and towers. All chimneys, cooling towers, smoke stacks, and similar appurtenances ... 5) PM304.4 Structural members. All structural members shall be maintained free from deterioration, and ... 6) §F3403.5.4 Identification. Color coding or other approved identification means shall be provided on ...
Facilities - Syracuse	Utica Fac	R3451 Radio Shelter Building - Summit near Little Falls mp 213 wb	11/12/2014	3	0	1) F901.6.1 Standards. Fire protection systems shall be inspected, tested and maintained in accordance ... 2) PM302.4 Weeds. All premises and immediate exterior property shall be maintained free from weeds or p ... 3) 308.5 Occupant. The occupant of any structure shall be responsible for the continued rodent and pes ...
Facilities - Syracuse	Utica Fac	S3101 Iroquois - restaurant	06/09/2014	6	0	1) §F605.5 Extension cords. Extension cords and flexible cords shall not be a substitute for permanent ...

						<p>2) §F605.5 Extension cords. Extension cords and flexible cords shall not be a substitute for permanent ...</p> <p>3) PM604.3 Electrical system hazards. Where it is found that the electrical system in a structure con ...</p> <p>4) PM315.2 Storage in buildings. Storage of combustible materials in buildings shall be orderly. Sto ...</p> <p>5) §F912.4 Signs. A metal sign with raised letters at least 1 inch (25 mm) in size shall be mounted on ...</p> <p>6) Fire Apparatus Access §F508.5.4 Obstruction. Posts, fences, vehicles, growth, trash, storage and o ...</p>
Facilities - Syracuse	Utica Fac	S3102 Indian Castle - restaurant	05/12/2014	7	0	<p>1) §F605.5 Extension cords. Extension cords and flexible cords shall not be a substitute for permanent ...</p> <p>2) §F605.6 Unapproved conditions. Open junction boxes and open-wiring splices shall be prohibited. App ...</p> <p>3) §F906.2 General requirements. Portable fire extinguishers shall be selected, installed and maintain ...</p> <p>4) §F906.2 General requirements. Portable fire extinguishers shall be selected, installed and maintain ...</p> <p>5) §F605.3 Working space and clearance. A working space of not less than 30 inches (762 mm) in width, 3 ...</p> <p>6) PM315.2 Storage in buildings. Storage of combustible materials in buildings shall be orderly. Sto ...</p> <p>7) PM305.1 General. The interior of a structure and equipment therein shall be maintained in good repa ...</p>
Facilities - Syracuse	Utica Fac	S3103 Schuyler - restaurant	03/27/2014	8	0	<p>1) §F605.1 Abatement of electrical hazards. Identified electrical hazards shall be abated. Identified ...</p> <p>2) §F605.1 Abatement of electrical hazards. Identified electrical hazards shall be abated. Identified ...</p> <p>3) §F605.5 Extension cords. Extension cords and flexible cords shall not be a substitute for permanent ...</p> <p>4) §F605.5 Extension cords. Extension cords and flexible cords shall not be a substitute for permanent ...</p> <p>5) §F605.5 Extension cords. Extension cords and flexible cords shall not be a substitute for permanent ...</p> <p>6) §F906.2 General requirements. Portable fire extinguishers shall be selected, installed and maintain ...</p> <p>7) §F906.2 General requirements. Portable fire extinguishers shall be selected, installed and maintain ...</p> <p>8) 912.2.2 Existing buildings. On existing buildings, wherever the fire department connection is not v ...</p>
Facilities - Syracuse	Utica Fac	S3104 Oneida - restaurant	03/27/2014	5	0	<p>1) PM 504.1 General. All plumbing fixtures shall be properly installed and maintained in working order ...</p> <p>2) §F605.1 Abatement of electrical hazards. Identified electrical hazards shall be abated. Identified ...</p> <p>3) §F906.2 General requirements. Portable fire extinguishers shall be selected, installed and maintain ...</p> <p>4) §F901.6.2 Records. Records of all system inspections, tests and maintenance required by the referen ...</p> <p>5) 912.2.2 Existing buildings. On existing buildings, wherever the fire department connection is not v ...</p>
Facilities - Syracuse	Utica Fac	S3112 Iroquois - gas station	06/09/2014	2	0	<p>1) §F2204.2.4 Obstructions to view. Dispensing devices shall be in clear view of the attendant at all ...</p> <p>2) PM604.3 Electrical system hazards.</p>

						Where it is found that the electrical system in a structure con ...
Facilities - Syracuse	Utica Fac	S3112 Iroquois - gas station	08/18/2014	0	0	
Facilities - Syracuse	Utica Fac	S3118 Oneida - metal	03/27/2014	0	0	
Facilities - Syracuse	Utica Fac	S3129 Iroquois - WWTP pumphouse and equipment	05/29/2014	2	0	1) §F906.2 General requirements. Portable fire extinguishers shall be selected, installed and maintain ... 2) FC1011.1 Where required. Exits and exit access doors shall be marked by an approved exit sign readi ...
Facilities - Syracuse	Utica Fac	S3132 Indian Castle - gas station/TWY office	05/12/2014	1	0	1) §F2204.2.4 Obstructions to view. Dispensing devices shall be in clear view of the attendant at all ...
Facilities - Syracuse	Utica Fac	S3132 Indian Castle - gas station/TWY office	08/18/2014	1	0	1) §F2204.2.4 Obstructions to view. Dispensing devices shall be in clear view of the attendant at all ...
Facilities - Syracuse	Utica Fac	S3136 Schuyler - gas station/generator	03/27/2014	0	0	
Facilities - Syracuse	Utica Fac	S3136 Schuyler - gas station/generator	08/18/2014	1	0	1) §F2204.2.4 Obstructions to view. Dispensing devices shall be in clear view of the attendant at all ...
Facilities - Syracuse	Utica Fac	S3137 Schuyler - WWTP storage 12 x 14	05/29/2014	0	0	
Facilities - Syracuse	Utica Fac	S3138 Schuyler - TIC storage	03/27/2014	0	0	
Facilities - Syracuse	Utica Fac	S3139 Schuyler - garbage storage	03/27/2014	0	0	
Facilities - Syracuse	Utica Fac	S3140 Schuyler - WWTP pumphouse and equipment	05/29/2014	0	0	
Facilities - Syracuse	Utica Fac	S3142 Oneida - gas station/TWY office	03/27/2014	0	0	
Facilities - Syracuse	Utica Fac	S3142 Oneida - gas station/TWY office	08/19/2014	1	0	1) §F906.2 General requirements. Portable fire extinguishers shall be selected, installed and maintain ...
Facilities - Syracuse	Utica Fac	S3143 Oneida - generator	03/27/2014	0	0	
Facilities - Syracuse	Utica Fac	S3145 Oneida - WWTP storage 16 x 24	05/29/2014	1	0	1) §F906.2 General requirements. Portable fire extinguishers shall be selected, installed and maintain ...
Facilities - Syracuse	Utica Fac	S3146 Oneida - WWTP pumphouse RBCs and equipment	05/29/2014	2	0	1) FC1011.1 Where required. Exits and exit access doors shall be marked by an approved exit sign readi ... 2) FC505.1 Address numbers. New and existing buildings shall have approved address numbers, building n ...
Facilities - Syracuse	Utica Fac	T3429 Int 29A - Little Falls Route 169	01/24/2014	7	0	1) 906.2 General requirements. Portable fire extinguishers shall be selected, installed and maintained ... 2) F605.1 Abatement of electrical hazards. Identified electrical hazards shall be abated. Identified ha ... 3) 407.2 Material Safety Data Sheets. Material Safety Data Sheets (MSDS) for all hazardous materials s ... 4) F605.1 Abatement of electrical hazards. Identified electrical hazards shall be abated. Identified ha ... 5) F605.1 Abatement of electrical hazards. Identified electrical hazards shall be abated. Identified ha ... 6) F605.1 Abatement of electrical hazards. Identified electrical hazards shall be abated. Identified ha ... 7) F605.1 Abatement of electrical hazards. Identified electrical hazards shall be abated. Identified ha ...
Facilities - Syracuse	Utica Fac	T3429 Int 29A - Little Falls Route 169	01/29/2014	3	0	1) F901.6 Inspection, testing and maintenance. Fire detection, alarm and extinguishing systems shall be ... 2) 906.1 Where required. Portable fire extinguishers shall be installed in the following locations. ... 3) 906.1 Where required. Portable fire extinguishers shall be installed in the following locations. ...
	Utica Fac	T3430 Int 30 - Herkimer Route 28	01/24/2014	3	0	

Facilities - Syracuse						<p>1) 407.2 Material Safety Data Sheets. Material Safety Data Sheets (MSDS) for all hazardous materials s ...</p> <p>2) 906.2 General requirements. Portable fire extinguishers shall be selected, installed and maintained ...</p> <p>3) F605.1 Abatement of electrical hazards. Identified electrical hazards shall be abated. Identified ha ...</p>
Facilities - Syracuse	Utica Fac	T3430 Int 30 - Herkimer Route 28	01/29/2014	3	0	<p>1) 906.1 Where required. Portable fire extinguishers shall be installed in the following locations. ...</p> <p>2) F901.6 Inspection, testing and maintenance. Fire detection, alarm and extinguishing systems shall be ...</p> <p>3) F605.1 Abatement of electrical hazards. Identified electrical hazards shall be abated. Identified ha ...</p>
Facilities - Syracuse	Utica Fac	T3431 Int 31 - Utica Routes 8 and 12	01/29/2014	6	0	<p>1) 906.1 Where required. Portable fire extinguishers shall be installed in the following locations. ...</p> <p>2) F901.6.1 Standards. Fire protection systems shall be inspected, tested and maintained in accordance ...</p> <p>3) F605.1 Abatement of electrical hazards. Identified electrical hazards shall be abated. Identified ha ...</p> <p>4) F901.6.1 Standards. Fire protection systems shall be inspected, tested and maintained in accordance ...</p> <p>5) §F603.6.1 Masonry chimneys. Masonry chimneys that, upon inspection, are found to be without a flue ...</p> <p>6) F605.1 Abatement of electrical hazards. Identified electrical hazards shall be abated. Identified ha ...</p>
Facilities - Syracuse	Utica Fac	T3532 Int 32 - Westmoreland Route 233	01/29/2014	9	0	<p>1) 906.1 Where required. Portable fire extinguishers shall be installed in the following locations. ...</p> <p>2) F605.1 Abatement of electrical hazards. Identified electrical hazards shall be abated. Identified ha ...</p> <p>3) F901.6 Inspection, testing and maintenance. Fire detection, alarm and extinguishing systems shall be ...</p> <p>4) F901.6 Inspection, testing and maintenance. Fire detection, alarm and extinguishing systems shall be ...</p> <p>5) F605.1 Abatement of electrical hazards. Identified electrical hazards shall be abated. Identified ha ...</p> <p>6) F605.3.1 Labeling. Doors into electrical control panel rooms shall be marked with a plainly visible ...</p> <p>7) F605.1 Abatement of electrical hazards. Identified electrical hazards shall be abated. Identified ha ...</p> <p>8) F605.3.1 Labeling. Doors into electrical control panel rooms shall be marked with a plainly visible ...</p> <p>9) F605.3.1 Labeling. Doors into electrical control panel rooms shall be marked with a plainly visible ...</p>
Facilities - Syracuse	Utica Fac	T3533 Int 33 - Verona Route 365	01/29/2014	7	0	<p>1) 906.1 Where required. Portable fire extinguishers shall be installed in the following locations. ...</p> <p>2) F901.6 Inspection, testing and maintenance. Fire detection, alarm and extinguishing systems shall be ...</p> <p>3) F901.6 Inspection, testing and maintenance. Fire detection, alarm and extinguishing systems shall be ...</p> <p>4) F605.3.1 Labeling. Doors into electrical control panel rooms shall be marked with a plainly visible ...</p> <p>5) F605.3.1 Labeling. Doors into electrical control panel rooms shall be marked with a plainly visible ...</p> <p>6) F605.3.1 Labeling. Doors into electrical control panel rooms shall be marked with a plainly visible ...</p>

						control panel rooms shall be marked with a plainly visible ... 7) F605.3.1 Labeling. Doors into electrical control panel rooms shall be marked with a plainly visible ...
Facilities - Syracuse	Utica Fac	T3534 Int 34 - Canastota Route 13	05/30/2014	1	0	1) PM305.3 Interior surfaces. All interior surfaces, including windows and doors, shall be maintained ...
Facilities - Syracuse	Utica Fac	Z3450 Fiber regeneration bldg - mp 233.1	09/23/2014	0	0	